



**Groundwater  
& Environmental Services, Inc.**

---

1350 Blair Drive • Suite A • Odenton, Maryland 21113 • (800) 220-3606 • FAX (410) 721-3733

November 18, 2016

Sharon Delgado  
3922 Greenpeak Rd  
Jarrettsville, MD 21084

Re: Potable Well Sampling Results  
3922 Greenpeak Rd, Jarrettsville, MD 21084

Dear Ms. Delgado:

Groundwater & Environmental Services, Inc. (GES), on behalf of High's of Baltimore, would like to thank you for your cooperation in allowing us to conduct sampling of your drinking water well on October 13, 2016.

The water sample from your well was tested in accordance to USEPA standards for the presence of several petroleum related compounds including methyl tertiary butyl ether (MTBE). The results from the most recent sampling event demonstrate detections in your well water of MTBE at 7.6 micrograms per liter ( $\mu\text{g/L}$ ). For reference, the Maryland Department of the Environment (MDE) action level for MTBE is 20  $\mu\text{g/L}$ . A copy of the laboratory analysis report for this sampling event is attached to this correspondence.

The tests conducted on your drinking water well are part of an ongoing groundwater investigation being conducted in cooperation with the MDE and the Harford County Health Department (HCHD). Therefore we would like to continue sampling the water from your drinking water well on a periodic basis while the groundwater investigation is being conducted. We will notify you in advance of the next scheduled sampling event.

If you have any questions concerning this sampling event, please feel free to contact me at 800-220-3606, Ext. 3726. You may also contact Ms. Jeannette DeBartolomeo of the MDE at 410-537-3427.

Sincerely,  
**GROUNDWATER & ENVIRONMENTAL SERVICES, INC.**

A handwritten signature in black ink, appearing to read 'Peter Reichardt', written in a cursive style.

Peter Reichardt  
Project Hydrogeologist

Attachment

c: Jeannette DeBartolomeo, MDE (3 copies & CD)  
Peter Smith, HCHD  
Herb Meade, CIFIC (e-copy)  
Todd Passmore, Apex

Sample Description: 3922 GREEN PEAK-INF Grab Potable Water  
4101 Norrisville Rd, Jarrettsville, MD  
Carroll Madonna

LL Sample # PW 8648866  
LL Group # 1722241  
Account # 08390

Project Name: Carroll Madonna

Collected: 10/13/2016 09:40 by JP

GES, Inc.  
Suite A  
1350 Blair Dr  
Odenton MD 21113

Submitted: 10/14/2016 16:30  
Reported: 10/26/2016 15:25

22GPI

CAT No.	Analysis Name	CAS Number	Result	Method Detection Limit	Dilution Factor
<b>GC/MS</b>	<b>Volatiles</b>	<b>EPA 524.2</b>	<b>ug/l</b>	<b>ug/l</b>	
03648	t-Amyl Methyl Ether	994-05-8	N.D.	0.1	1
03648	Benzene	71-43-2	N.D.	0.1	1
03648	t-Butyl Alcohol	75-65-0	N.D.	2.5	1
03648	Carbon Tetrachloride	56-23-5	N.D.	0.1	1
03648	Chlorobenzene	108-90-7	N.D.	0.1	1
03648	1,2-Dichlorobenzene	95-50-1	N.D.	0.1	1
03648	1,3-Dichlorobenzene	541-73-1	N.D.	0.1	1
03648	1,2-Dichloroethane	107-06-2	N.D.	0.1	1
03648	1,1-Dichloroethene	75-35-4	N.D.	0.1	1
03648	cis-1,2-Dichloroethene	156-59-2	N.D.	0.1	1
03648	trans-1,2-Dichloroethene	156-60-5	N.D.	0.1	1
03648	1,2-Dichloropropane	78-87-5	N.D.	0.1	1
03648	Ethyl t-Butyl Ether	637-92-3	N.D.	0.1	1
03648	Ethylbenzene	100-41-4	N.D.	0.1	1
03648	di-Isopropyl Ether	108-20-3	N.D.	0.1	1
03648	Methyl Tertiary Butyl Ether	1634-04-4	7.6	0.1	1
03648	Methylene Chloride	75-09-2	N.D.	0.3	1
03648	Naphthalene	91-20-3	N.D.	0.2	1
03648	Styrene	100-42-5	N.D.	0.1	1
03648	Tetrachloroethene	127-18-4	N.D.	0.1	1
03648	Toluene	108-88-3	N.D.	0.1	1
03648	1,2,4-Trichlorobenzene	120-82-1	N.D.	0.2	1
03648	1,1,1-Trichloroethane	71-55-6	N.D.	0.1	1
03648	1,1,2-Trichloroethane	79-00-5	N.D.	0.1	1
03648	Trichloroethene	79-01-6	N.D.	0.1	1
03648	Vinyl Chloride	75-01-4	N.D.	0.1	1
03648	Xylene (Total)	1330-20-7	N.D.	0.1	1

### Sample Comments

All QC is compliant unless otherwise noted. Please refer to the Quality Control Summary for overall QC performance data and associated samples.

### Laboratory Sample Analysis Record

CAT No.	Analysis Name	Method	Trial#	Batch#	Analysis Date and Time	Analyst	Dilution Factor
03648	VOCs- 25ml Water by 524.2	EPA 524.2	1	S162992AA	10/25/2016 21:24	Joshua S Hess	1

# Explanation of Symbols and Abbreviations

The following defines common symbols and abbreviations used in reporting technical data:

<b>RL</b>	Reporting Limit	<b>BMQL</b>	Below Minimum Quantitation Level
<b>N.D.</b>	none detected	<b>MPN</b>	Most Probable Number
<b>TNTC</b>	Too Numerous To Count	<b>CP Units</b>	cobalt-chloroplatinate units
<b>IU</b>	International Units	<b>NTU</b>	nephelometric turbidity units
<b>umhos/cm</b>	micromhos/cm	<b>ng</b>	nanogram(s)
<b>C</b>	degrees Celsius	<b>F</b>	degrees Fahrenheit
<b>meq</b>	milliequivalents	<b>lb.</b>	pound(s)
<b>g</b>	gram(s)	<b>kg</b>	kilogram(s)
<b>µg</b>	microgram(s)	<b>mg</b>	milligram(s)
<b>mL</b>	milliliter(s)	<b>L</b>	liter(s)
<b>m<sup>3</sup></b>	cubic meter(s)	<b>µL</b>	microliter(s)
		<b>pg/L</b>	picogram/liter
<b>&lt;</b>	less than		
<b>&gt;</b>	greater than		
<b>ppm</b>	parts per million - One ppm is equivalent to one milligram per kilogram (mg/kg) or one gram per million grams. For aqueous liquids, ppm is usually taken to be equivalent to milligrams per liter (mg/l), because one liter of water has a weight very close to a kilogram. For gases or vapors, one ppm is equivalent to one microliter per liter of gas.		
<b>ppb</b>	parts per billion		
<b>Dry weight basis</b>	Results printed under this heading have been adjusted for moisture content. This increases the analyte weight concentration to approximate the value present in a similar sample without moisture. All other results are reported on an as-received basis.		

## Laboratory Data Qualifiers:

- B - Analyte detected in the blank
- C - Result confirmed by reanalysis
- E - Concentration exceeds the calibration range
- J (or G, I, X) - estimated value  $\geq$  the Method Detection Limit (MDL or DL) and  $<$  the Limit of Quantitation (LOQ or RL)
- P - Concentration difference between the primary and confirmation column  $>40\%$ . The lower result is reported.
- U - Analyte was not detected at the value indicated
- V - Concentration difference between the primary and confirmation column  $>100\%$ . The reporting limit is raised due to this disparity and evident interference...

Additional Organic and Inorganic CLP qualifiers may be used with Form 1 reports as defined by the CLP methods. Qualifiers specific to Dioxin/Furans and PCB Congeners are detailed on the individual Analysis Report.

**Analytical test results meet all requirements of the associated regulatory program (i.e., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis.**

Measurement uncertainty values, as applicable, are available upon request.

Tests results relate only to the sample tested. Clients should be aware that a critical step in a chemical or microbiological analysis is the collection of the sample. Unless the sample analyzed is truly representative of the bulk of material involved, the test results will be meaningless. If you have questions regarding the proper techniques of collecting samples, please contact us. We cannot be held responsible for sample integrity, however, unless sampling has been performed by a member of our staff.

This report shall not be reproduced except in full, without the written approval of the laboratory.

Times are local to the area of activity. Parameters listed in the 40 CFR Part 136 Table II as "analyze immediately" are not performed within 15 minutes.

**WARRANTY AND LIMITS OF LIABILITY** - In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. THE FOREGOING EXPRESS WARRANTY IS EXCLUSIVE AND IS GIVEN IN LIEU OF ALL OTHER WARRANTIES, EXPRESSED OR IMPLIED. WE DISCLAIM ANY OTHER WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING A WARRANTY OF FITNESS FOR PARTICULAR PURPOSE AND WARRANTY OF MERCHANTABILITY. IN NO EVENT SHALL EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL, LLC BE LIABLE FOR INDIRECT, SPECIAL, CONSEQUENTIAL, OR INCIDENTAL DAMAGES INCLUDING, BUT NOT LIMITED TO, DAMAGES FOR LOSS OF PROFIT OR GOODWILL REGARDLESS OF (A) THE NEGLIGENCE (EITHER SOLE OR CONCURRENT) OF EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL AND (B) WHETHER EUROFINS LANCASTER LABORATORIES ENVIRONMENTAL HAS BEEN INFORMED OF THE POSSIBILITY OF SUCH DAMAGES. We accept no legal responsibility for the purposes for which the client uses the test results. No purchase order or other order for work shall be accepted by Eurofins Lancaster Laboratories Environmental which includes any conditions that vary from the Standard Terms and Conditions, and Eurofins Lancaster Laboratories Environmental hereby objects to any conflicting terms contained in any acceptance or order submitted by client.