

**NUTSHELL
ENTERPRISES, LTD.**

Environmental
Consulting,
Engineering and
Construction

4059 Norrisville Road
Jarrettsville, MD 21084
Phone (410) 557-7583
Fax (410) 557-8804

September 14, 2011

Ms. Jeannette DeBartolomeo
Compliance Specialist
Maryland Department of the Environment
Oil Control Program
1800 Washington Boulevard, Suite 620
Baltimore, MD 21230-1719

**High's Harford County Stores
Request to Reduce Supply Well Sampling Frequency**

Dear Ms. DeBartolomeo:

Attached is a copy of a report prepared for the Harford County Health Department documenting the VOC sampling results of the High's stores supply wells, located in Harford County. Please review the report and consider reducing the sampling frequency of the supply wells at #68 Street, #81 Darlington, #86 Jarrettsville and #130 Madonna to *Annual*.

Thank you for your consideration of this request.

Sincerely,


Arthur A. Shellhouse, CPEA

Attachment: Report

cc: Susan Bull, MDE
Melissa Nickol, High's
Ed Broderick, High's

NUTSHELL ENTERPRISES, LTD.

Environmental
Consulting,
Engineering and
Construction

4059 Norrisville Road
Jarrettsville, MD 21084
Phone (410) 557-7583
Fax (410) 557-8804

September 14, 2011

Mr. Rich Gordon, Sanitarian
Harford County Health Department
Environmental Water Quality
120 S. Hay Street
P.O. Box 797
Bel Air, MD 21014-0797

**High's of Baltimore, Inc.
Harford County**

Dear Mr. Gordon:

This report documents the sampling of the supply wells at High's of Baltimore, Inc. Harford County locations, during the year 2011 to date. The drinking water samples are collected, prior to any treatment, by MDE certified drinking water samplers. The samples are collected in laboratory-prepared containers, placed on ice and delivered to a certified laboratory, to be analyzed for VOC's + fuel oxygenates, using EPA Method 524.2.

Results

Sample ID	Date	Sampling Location	MDE Certified DW Sampler	Sampling Frequency	Result ug/L
#1 Whiteford	5/11/2011	Pressure Tank	Steve Saul ¹	Annual	chloroform 1.3
#2 Whitehall	8/23/2011	Pressure Tank	Steve Saul	Annual	MTBE 1.0
#68 Street	1/30/2011	Pressure Tank	Bob Triplett ²	Semiannual	ND
	7/6/2011	Pressure Tank	Steve Saul		ND
#81 Darlington	1/30/2011	Pressure Tank	Bob Triplett	Semiannual	ND
	7/26/2011	Pressure Tank	Steve Saul		ND
#86 Jarrettsville	1/31/2011	Pressure Tank	Bob Triplett	Quarterly	ND
	4/16/2011	Pressure Tank	Steve Saul		MTBE 0.6
	7/30/2011	Pressure Tank	Steve Saul		ND
#130 Madonna	1/31/2011	Pressure Tank	Bob Triplett	Semiannual	ND
	7/26/2011	Pressure Tank	Bob Triplett		ND

If you have any questions regarding this report, please do not hesitate to contact me at 410-557-7583 or nutshellart@zoominternet.net.

Sincerely,



Arthur A. Shellhouse
Certified Professional Environmental Auditor

Enclosures: Certificates of Analysis

cc: Kevin Green, High's

¹ Saul MDE DW Certification ID 1203-000-580, expires 3/12/2012

² Triplett MDE DW Certification ID 111-000-126, expires 11/13/2011



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 05/11/11 11:50
Date Received: 05/12/11 9:40
Date Issued: 05/19/11

Project: High's #1
Site Location: Whiteford, MD

SDG Number: 11051201

Field Sample ID: Potable Well Matrix: Drinking Water Lab ID: 11051201-01

	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatila Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Chloroform	1.3	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
2,2-Dichloroprpane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Methylene chloride	ND	ug/L	1	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	05/12/11	05/12/11 17:44	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 05/11/11 11:50
Date Received: 05/12/11 9:40
Date Issued: 05/19/11

Project: High's #1
Site Location: Whiteford, MD

SDG Number: 11051201

Field Sample ID:	Potable Well	Matrix:	Drinking Water	Lab ID:	11051201-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Naphthalene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	05/12/11	05/12/11 17:44	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	05/12/11	05/12/11 17:44	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	05/12/11	05/12/11 17:44	JKL

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 08/23/11 13:00
Date Received: 08/23/11 16:30
Date Issued: 08/30/11

Project: High's #2
Site Location: White Hall MD

SDG Number: 11082305

Field Sample ID:	Potable Well	Matrix:	Drinking Water	Lab ID:	11082305-04			
		Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds								
Benzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Bromobenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Bromoform	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Bromomethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Chloroethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Chloroform	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Chloromethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Dibromomethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Methylene chloride	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL	
Methyl t-butyl ether (MTBE)	1.0	ug/L	0.2	EPA 524.2	08/26/11	08/26/11 14:12	JKL	



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 08/23/11 13:00
Date Received: 08/23/11 16:30
Date Issued: 08/30/11

Project: High's #2
Site Location: White Hall MD

SDG Number: 11082305

Field Sample ID:	Potable Well	Matrix: Drinking Water				Lab ID: 11082305-04		
		Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds								
	Naphthalene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Styrene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Toluene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Trichloroethene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Vinyl chloride	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	m&p-Xylene	ND	ug/L	1	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	o-Xylene	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	08/26/11	08/26/11 14:12	JKL
	tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	08/26/11	08/26/11 14:12	JKL

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 01/30/11 12:30
Date Received: 02/02/11 15:30
Date Issued: 02/11/11

Project: High's # 68
Site Location: Street, MD

SDG Number: 11020206

Field Sample ID: Domestic Well Matrix: Drinking Water Lab ID: 11020206-01

	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Chloroform	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Methylene chloride	ND	ug/L	1.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	02/10/11	02/10/11 17:00	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 01/30/11 12:30
Date Received: 02/02/11 15:30
Date Issued: 02/11/11

Project: High's # 68
Site Location: Street, MD

SDG Number: 11020206

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11020206-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Naphthalene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	02/10/11	02/10/11 17:00	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	02/10/11	02/10/11 17:00	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:00	JKL

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/06/11 10:40
Date Received: 07/07/11 8:45
Date Issued: 07/14/11

Project: High's #68
Site Location: 4802 Rocks Road, Street, MD

SDG Number: 11070701

Field Sample ID:	Potable Well	Matrix:	Drinking Water	Lab ID:	11070701-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Coliforms							
E. Coli Coliforms	Absent			SM 9223	07/07/11	07/07/11 9:45	SS
Total Coliforms	Absent			SM 9223	07/07/11	07/07/11 9:45	SS
Volatile Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Chloroform	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/06/11 10:40
Date Received: 07/07/11 8:45
Date Issued: 07/14/11

Project: High's #68
Site Location: 4802 Rocks Road, Street, MD

SDG Number: 11070701

Field Sample ID:	Potable Well	Matrix:	Drinking Water	Lab ID:	11070701-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Methylene chloride	ND	ug/L	1	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Naphthalene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	07/08/11	07/08/11 15:20	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	07/08/11	07/08/11 15:20	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	07/08/11	07/08/11 15:20	JKL

Notes/Qualifiers

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/26/11 15:10
Date Received: 07/27/11 9:30
Date Issued: 08/03/11

Project: High's #81
Site Location: 1230 Main St. Darlington, MD
Project Number: 1230

SDG Number: 11072702

Field Sample ID:	Potable Well	Matrix: Drinking Water			Lab ID: 11072702-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Chloroform	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Methylene chloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	08/02/11	08/02/11 16:44	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/26/11 15:10
Date Received: 07/27/11 9:30
Date Issued: 08/03/11

Project: High's #81
Site Location: 1230 Main St. Darlington, MD
Project Number: 1230

SDG Number: 11072702

Field Sample ID:	Potable Well	Matrix:	Drinking Water	Lab ID:	11072702-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Naphthalene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	08/02/11	08/02/11 16:44	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	08/02/11	08/02/11 16:44	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 16:44	JKL

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 01/30/11 10:30

Date Received: 02/02/11 15:30

Date Issued: 02/11/11

Project: High's # 81
Site Location: Darlington, MD

SDG Number: 11020205

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11020205-01			
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.	
Volatile Organic Compounds								
Benzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Bromobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Bromoform	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Bromomethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Chloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Chloroform	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Chloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Dibromomethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Methylene chloride	ND	ug/L	1	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	02/10/11	02/10/11 16:20	JKL	



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 01/30/11 10:30
Date Received: 02/02/11 15:30
Date Issued: 02/11/11

Project: High's # 81
Site Location: Darlington, MD

SDG Number: 11020205

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11020205-01			
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.	
Volatile Organic Compounds								
Naphthalene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Styrene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Toluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Trichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
m&p-Xylene	ND	ug/L	1	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
o-Xylene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 16:20	JKL	

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 01/31/11 10:30
Date Received: 02/02/11 15:30
Date Issued: 02/11/11

Project: High's # 86
Site Location: Jarrettsville, MD

SDG Number: 11020207

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11020207-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Chloroform	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Methylene chloride	ND	ug/L	1	EPA 524.2	02/10/11	02/10/11 17:41	JKL
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	02/10/11	02/10/11 17:41	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 04/16/11 9:50
Date Received: 04/18/11 16:40
Date Issued: 04/26/11

Project: High's # 86
Site Location: Jarrettsville, MD
Project Number: HRGUA Quarterly Sampling

SDG Number: 11041811

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11041811-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Chloroform	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Methylene chloride	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Methyl t-butyl ether (MTBE)	0.6	ug/L	0.2	EPA 524.2	04/21/11	04/21/11 21:26	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 04/16/11 9:50
Date Received: 04/18/11 16:40
Date Issued: 04/26/11

Project: High's # 86
Site Location: Jarrettsville, MD
Project Number: HRGUA Quarterly Sampling

SDG Number: 11041811

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11041811-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Naphthalene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	04/21/11	04/21/11 21:26	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	04/21/11	04/21/11 21:26	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	04/21/11	04/21/11 21:26	JKL

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/30/11 7:30
Date Received: 08/01/11 8:50
Date Issued: 08/08/11

Project: High's
Site Location: 3711 Federal Hill Rd. Jarrettsville, MD
Project Number: 3711

SDG Number: 11080101

Field Sample ID:	Potable Well	Matrix:	Drinking Water	Lab ID:	11080101-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Chloroform	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Methylene chloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	08/02/11	08/02/11 22:34	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/30/11 7:30
Date Received: 08/01/11 8:50
Date Issued: 08/08/11

Project: High's
Site Location: 3711 Federal Hill Rd. Jarrettsville, MD
Project Number: 3711

SDG Number: 11080101

Field Sample ID:	Potable Well	Matrix:	Drinking Water	Lab ID:	11080101-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Naphthalene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	08/02/11	08/02/11 22:34	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	08/02/11	08/02/11 22:34	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 22:34	JKL

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 01/31/11 13:00
Date Received: 02/02/11 15:30
Date Issued: 02/11/11

Project: High's # 130
Site Location: Madonna, MD

SDG Number: 11020211

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11020211-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatila Organic Compounds							
Benzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Bromobenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Bromoform	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Bromomethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Chloroethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Chloroform	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Chloromethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Dibromomethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Methylene chloride	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	02/11/11	02/11/11 4:56	JKL



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 01/31/11 13:00
Date Received: 02/02/11 15:30
Date Issued: 02/11/11

Project: High's # 130
Site Location: Madonna, MD

SDG Number: 11020211

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11020211-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Naphthalene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	02/11/11	02/11/11 4:56	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	02/11/11	02/11/11 4:56	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	02/11/11	02/11/11 4:56	JKL

Notes/Qualifiers:

LLQ- Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/26/11 10:15
Date Received: 07/28/11 8:21
Date Issued: 08/04/11

Project: High's 130
Site Location: Madonna, MD
Project Number: Quaterly

SDG Number: 11072801

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11072801-01			
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.	
Volatile Organic Compounds								
Benzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Bromobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Bromochloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Bromodichloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Bromoform	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Bromomethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
n-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
sec-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
tert-Butylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Carbon tetrachloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Chlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Chloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Chloroform	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Chloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
2-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
4-Chlorotoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Dibromochloromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,2-Dibromo-3-chloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,2-Dibromoethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Dibromomethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,2-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,3-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,4-Dichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Dichlorodifluoromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,1-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,2-Dichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,1-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
cis-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
trans-1,2-Dichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,3-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
2,2-Dichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
1,1-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
cis-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
trans-1,3-Dichloropropene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Ethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Isopropylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
p-Isopropyltoluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Methylene chloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL	
Methyl t-butyl ether (MTBE)	ND	ug/L	0.2	EPA 524.2	08/02/11	08/02/11 17:19	JKL	



CALIBER ANALYTICAL SERVICES

Certificate of Analysis

Nutshell Enterprises
4059 Norrisville Road
Jarrettsville, MD 21084

Date Sampled: 07/26/11 10:15
Date Received: 07/28/11 8:21
Date Issued: 08/04/11

Project: High's 130
Site Location: Madonna, MD
Project Number: Quaterly

SDG Number: 11072801

Field Sample ID:	Domestic Well	Matrix:	Drinking Water	Lab ID:	11072801-01		
	Result	Unit	LLQ	Method	Prepared	Analyzed	Init.
Volatile Organic Compounds							
Naphthalene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
n-Propylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Styrene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,1,1,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,1,2,2-Tetrachloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Tetrachloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Toluene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,2,3-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,2,4-Trichlorobenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,1,1-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,1,2-Trichloroethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Trichloroethene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Trichlorofluoromethane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,2,3-Trichloropropane	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,2,4-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
1,3,5-Trimethylbenzene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Vinyl chloride	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
m&p-Xylene	ND	ug/L	1	EPA 524.2	08/02/11	08/02/11 17:19	JKL
o-Xylene	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
tert-Butanol (TBA)	ND	ug/L	5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Ethyl t-butyl ether (ETBE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
Diisopropyl ether (DIPE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
tert-Amyl methyl ether (TAME)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
tert-Amyl alcohol (TAA)	ND	ug/L	5	EPA 524.2	08/02/11	08/02/11 17:19	JKL
tert-Amyl ethyl ether (TAEE)	ND	ug/L	0.5	EPA 524.2	08/02/11	08/02/11 17:19	JKL

Notes/Qualifiers:

LLQ - Lowest Level of Quantitation

ND - Not Detected at a concentration greater than or equal to the LLQ.

Approved by:

QC Chemist