

**Maryland  
Department of the Environment**

**Sample UST Closure Report  
Guidance**



**November 16, 2007**

Updated Sample UST Closure can be viewed on MDE web at:

[http://mde.maryland.gov/programs/Land/OilControl/Pages/ustcertification\\_programs.aspx](http://mde.maryland.gov/programs/Land/OilControl/Pages/ustcertification_programs.aspx)

## Executive Summary

This document is intended to serve as guidance for contractors employed to close underground storage tank systems (UST) systems and to provide a sample UST System Closure Report in order to satisfy COMAR 26.10.10.03 *Assessing the Site at Closure or Change-in-Service*. Contractors performing the UST closure should, at a minimum, include the information and documents contained in this document applicable to each job site in all UST system Closure Reports submitted to the Department.

Prior notice of UST closure activities must be given to the Department (MDE) in accordance with COMAR 26.10.10.02A. All UST closure activities must be performed under the direct supervision of a Maryland certified technician or remover. Proper safety procedures must be followed and safety equipment used.

The report on the UST closure activity must be prepared to accurately describe the closure activities and findings for each UST location. The information contained in the report will assist the Department to evaluate if an UST site poses a threat to public health, safety and the environment and if further investigation or corrective action is required. Contractor conclusions and recommendations are a very important part of this evaluation process.

To ensure a timely review of each report submitted, the report must be sent to the attention of the inspector designated as the case manager and shall be identified by case number and facility ID number. The case manager can provide the case and facility numbers upon request.

**Please call the Oil Control Program at 410-537-3442 with any questions.**

**Visit our Web Site at <http://mde.maryland.gov/programs/Land/OilControl/Pages/index.aspx> to obtain additional information.**

This document is for informational and guidance purposes. This document is not intended nor should it be interpreted to be a regulation, as defined in Section 10-101, State Government Article. The MDE encourages you to read and understand the regulations that govern the operation and closure of underground storage systems found in Code of Maryland Regulations 26.10. "*Oil Pollution and Tank Management*"

# MDE Sample UST Closure Report

January 1, 2007

Maryland Department of the Environment  
Waste Management Administration  
Oil Control Program  
Attn: Inspector (Name)  
1800 Washington Boulevard, Suite 620  
Baltimore MD 21230-1719

**RE:    Underground Storage Tank System Closure Report**  
**Case No. 2007-7777HO**  
**Doe Property**  
**1234 Main Street**  
**Hampton, Maryland**  
**Facility I.D. No. 1111**

Dear Inspector (Name):

Blank Environmental, Inc. is pleased to submit the enclosed underground storage tank system closure report for the above-referenced property located in Howard County prepared on behalf of:

John Doe  
Property Owner  
4321 Niam Road  
Hampton MD 12345  
410-555-1212  
410-555-1213 (fax)

Should you have any questions or comments regarding this report, please contact the project manager, Joe Blank, at 410-555-5555 or via Email: [jblank@blankenvironmental.com](mailto:jblank@blankenvironmental.com).

Sincerely,

Joe Blank  
Senior Environmental Scientist

## **Table of Contents**

### **I. Underground Storage Tank System Closure Report**

- A. Narrative
- B. Soil and Groundwater Sampling
- C. Analytical Results
- D. Conclusions and Recommendations

### **II. Support Documents**

- A. Site Sketch
- B. Photographic Documentation (if applicable)
- C. Receipts (if applicable)
  - 1. Tanks Disposal Receipt(s)
  - 2. Slurry Receipt(s)
  - 3. Soil Disposal Receipt(s)
  - 4. Liquid Disposal Receipt(s)
- D. Sample Locations (diagram)
- E. Analytical Laboratory Information
- F. Amended Registration Forms

# I. Underground Storage Tank System Closure Report

## A. Narrative

On January 1, 2007, Blank Environmental, Inc. mobilized equipment to 1234 Main Street located in Howard County for the proper abandonment of three underground storage tank systems. Two underground storage tank systems, one 4,000-gallon gasoline bare steel and one 2,000-gallon diesel double wall fiberglass reinforced plastic, were removed and one underground storage tank system, a 500-gallon used oil StIP3, was abandoned in place, after receiving approval from MDE case manager Joe Regulator. These activities were completed under the direction of MDE certified technician, Joe Blank, MDIC 2007-0000 (expires 01-01-09). The gasoline system steel product supply pipe extended 20 feet with no change of direction from the underground storage tank to the single dispenser. The diesel system single wall fiberglass reinforced plastic diesel supply pipe extended 5 feet with no change of direction from the underground storage tank to the single dispenser. There was no product piping associated with the used oil tank. Tank diameters were 64", 48", and 48" respectively. Tank overburden was 18" for all tanks.

Using contract vacuum truck services provided by Vac USA, all petroleum was removed from the piping and the tanks prior to the removals and abandonment. Four gallons of water was utilized to flush the piping following the draining of product to the tank. The underground storage tanks were pumped free of petroleum and rinse waters. The used oil underground storage tank was cleaned internally in accordance with state and local regulations. An eductor-type air mover was utilized to purge any flammable vapor concentrations from the gasoline underground storage tank. Thirty pounds of dry ice were placed into the diesel underground storage tank to inert it. A MSA Combustible Gas Indicator, Model 1000, was utilized to scan the underground storage tanks for combustible vapors prior to, during, and after the removals and abandonment. The lower explosive limit did not exceed five percent after purging and inerting were complete.

The gasoline and diesel underground storage tank systems, including all associated piping, were removed from the ground. In addition, all vent risers were removed. Above ground portions of the used oil underground storage tank system were removed and the openings (fill and vent pipe risers) sealed at grade with concrete.

Five perforations were observed in the gasoline underground storage tank ranging from a pinhole to 1/2-inch in diameter. No perforations were observed in the gasoline underground storage tank system piping. No perforations were observed in the diesel underground storage tank. A single perforation measuring 1/8-inch diameter was observed in the diesel product piping approximately two feet from the dispenser. No perforations were observed in the used oil tank following cleaning.

The shared gasoline and diesel tank excavation measured 16 feet in length, 10 feet in width, and 14 feet in depth. Excavation limits were based on the extent of the equipment, visual signs of contamination, field screening of the soil utilizing a *Mini-Rae* photoionization detector, the existence of a natural gas line along the north wall of the excavation, and the existence of the building foundation along the south wall of the excavation. Subsurface soil was silty-clay. Oil-contaminated soil was encountered to excavation depth. There were no indications of

contamination along the gasoline or diesel piping trenches or below the dispensers. Approximately 120 tons of oil-contaminated soil were removed and transported to Disposal Facility X for proper disposal. Contaminated soil encountered along the north wall of the excavation could not be removed for proper disposal due to the presence of the natural gas line.

Groundwater entered the shared gasoline and diesel underground storage tank excavation at 14 feet below grade surface. Neither liquid phase hydrocarbon nor sheen was detected on the groundwater. No groundwater was removed for treatment.

Subsurface soil below the used oil underground storage tank system was sand. The soil did not exhibit signs of contamination. Groundwater was not encountered during abandonment of the used oil tank system. The UST was filled in-place with Flo-Ash.

Water supply to the site and vicinity is through a public water system with the exception of one drinking water well located on the adjacent residential property to the north. There are no wellhead protection areas within one-half mile radius of the site.

## **B. Soil and Groundwater Sampling**

A total of nine soil samples labeled S1 through S9 were collected from the site for analysis. Two soil samples, S1 and S2, were collected with a clean auger from two feet below the used oil underground storage tank from opposing ends after drilling access holes through the bottom. Five soil samples, S3 through S7, were collected from the shared gasoline and diesel underground storage tank excavation. S3 was collected at ten feet below grade surface along the center of the north wall of the excavation in the area exhibiting the most significant subsurface contamination remaining after removal of soil. Samples S4 through S7 were collected at the excavation depth of 14 feet. Two additional soil samples, S8 and S9, were collected to address subsurface conditions along the piping trenches. S8 was collected midway between the gasoline dispenser and the gasoline tank at three feet below grade surface. S9 was collected between the diesel dispenser and tank, two feet from the dispenser, at three feet below grade surface, the area where the perforation was observed in the piping. Soil samples were collected utilizing sterile gloves. All soil samples were placed in four-ounce wide mouth laboratory supplied jars and immediately placed on ice in a clean cooler. The cooler temperature was maintained at less than or equal to four degrees Celsius.

A groundwater sample labeled G1 was collected from the shared gasoline and diesel underground storage tank excavation at a depth of 14-feet below grade surface utilizing a disposal bailer and sterile gloves. The sample was transferred from the bailer into three 40-ml vials previously acidified with hydrochloric acid and one amber one liter glass bottle. The containers were immediately placed on ice in a clean cooler. The cooler temperature was maintained at less than or equal to four degrees Celsius.

Per directive of the Maryland Department of the Environment, a drinking water well sample labeled W1 was collected, by a certified supply well sampler, on January 8, 2007 from the adjacent property to the north. There was no type of treatment system or holding tank associated with the well water. Sterile gloves were worn when the sample was collected from the kitchen tap and placed into three 40-ml vials previously acidified with hydrochloric acid. The sink aerator was

removed and the water was allowed to run ten minutes prior to filling the vials. The full vials had no air bubbles or headspace. The samples were immediately placed on ice in a clean cooler. The cooler temperature was maintained at less than or equal to four degrees Celsius.

The groundwater sample from the tank excavation and all soil samples were delivered to Detection Laboratory Inc. on January 1, 2007. The drinking water well sample was delivered to Detection Laboratory Inc. on January 8, 2007.

### C. Analytical Results

#### Soil Analytical Results:

Sample Identification	Sample Date	Benzene (mg/kg)	Toluene (mg/kg)	Ethylbenzene (mg/kg)	Xylenes (mg/kg)
S1	1-1-07	ND	ND	ND	ND
S2	1-1-07	ND	ND	ND	ND
S3	1-1-07	600	20	1,000	1,200
S4	1-1-07	5	1,000	700	1,400
S5	1-1-07	ND	ND	ND	ND
S6	1-1-07	10	980	640	1,000
S7	1-1-07	ND	ND	ND	ND
S8	1-1-07	ND	ND	ND	ND
S9	1-1-07	ND	ND	ND	60
Analysis Date		1-5-07	1-5-07	1-5-07	1-5-07
MDE's residential soil cleanup standards		12	1,600	780	16,000
MDE's non-residential soil cleanup standards		100	57,000	20,000	410,000

Sample Identification	Sample Date	MTBE (mg/kg)	Naphthalene (mg/kg)	TPH-GRO (mg/kg)	TPH-DRO (mg/kg)
S1	1-1-07	ND	ND	11 U	11 U
S2	1-1-07	ND	ND	11 U	11 U
S3	1-1-07	800	420	2,400	750
S4	1-1-07	180	80	230	10
S5	1-1-07	ND	ND	10 U	10 U
S6	1-1-07	65	110	60	230
S7	1-1-07	ND	ND	11 U	11 U
S8	1-1-07	ND	ND	11 U	11 U
S9	1-1-07	ND	ND	11 U	11 U
Analysis Date		1-5-07	1-5-07	1-15-07	1-15-07
MDE's residential soil cleanup standards		650	160	230	230
MDE's non-residential soil cleanup standards		2,700	4,100	620	620

In addition to the above constituents, barium was detected in sample S2 at a concentration of 600 mg/kg above MDE's residential soil cleanup standard set at 550 mg/kg.

**Groundwater Analytical Results:**

Sample Identification	Sample Date	Benzene (ug/kg)	Toluene (ug/kg)	Ethylbenzene (ug/kg)	Xylenes (ug/kg)
G1	1-1-07	100	1,500	2,000	10,000
Analysis Date		1-10-07	1-10-07	1-10-07	1-10-07
MDE's groundwater cleanup standards		5	1,000	700	10,000

Sample Identification	Sample Date	MTBE (ug/kg)	Naphthalene (ug/kg)	TPH-GRO (ug/kg)	TPH-DRO (ug/kg)
G1	1-1-07	80	100	450	58
Analysis Date		1-10-07	1-10-07	1-11-07	1-11-07
MDE's groundwater cleanup standards		20	10	47	47

Sample Identification	Sample Date	Benzene (ug/kg)	Toluene (ug/kg)	Ethylbenzene (ug/kg)	Xylenes (ug/kg)
W1	1-8-07	ND	ND	ND	ND
Analysis Date		1-9-07	1-9-07	1-9-07	1-9-07
MDE's groundwater cleanup standards		5	1,000	700	10,000

Sample Identification	Sample Date	MTBE (ug/kg)	Naphthalene (ug/kg)	TPH-GRO (ug/kg)	TPH-DRO (ug/kg)
W1	1-8-07	ND	ND	ND	ND
Analysis Date		1-9-07	1-9-07	1-9-07	1-9-07
MDE's groundwater cleanup standards		20	10	47	47

**D. Conclusions and Recommendations**

The site is a commercial facility surrounded by residential homes to the north and east and commercial facilities to the south and west. The sample results from soil sample S3 revealed the presence of benzene, ethylbenzene, methyl tertiary butyl ether, naphthalene, and total petroleum hydrocarbons above MDE's residential soil cleanup standards. Groundwater sample results revealed the presence of benzene, toluene, ethylbenzene, methyl tertiary butyl ether, naphthalene, and total petroleum hydrocarbons above MDE's groundwater cleanup standards.

Based on the elevated soil and groundwater sample results and the presence of a drinking water well on the adjacent residential property, Blank Environmental, Inc. proposes to install two two-inch wells on the northern property boundary between the gasoline and diesel tank excavation and the adjacent property drinking water well. A third two-inch well will be installed off the southeast edge of the excavation to determine groundwater flow. A detailed corrective action work plan identifying the subsurface investigation techniques, sampling methodology and frequency, and site map of proposed well points will be forwarded to MDE.



## **II. Support Documents**

## **A. Site Sketch**




## B. Photographs

Photographs



Photograph of the used oil underground storage tank after cleaning.



Photograph of a hole in the gasoline underground storage tank.

## **C. Receipts**

1. Tank Disposal
2. Slurry Fill
3. Soil Disposal
4. Liquid Disposal

## Tank Disposal Receipt

ABC Salvage, Inc.  
1010 ABC Lane  
Metal MD 22222  
1-800-555-5555

### Certificate of Storage Tank Disposal

In accordance with current Federal, State, and Local regulations, ABC Salvage, Inc. of Metal Maryland accepts full responsibility for the disposal of the tank(s) listed below.			
The following tanks are no longer suitable for food, flammable liquid, combustible liquid, or hazardous liquid storage. The tanks have been rendered unfit for further use.			
Number of Tank	Size In Gallons	Material of Construction	Product Previously Stored

The above-reference tanks were removed from:

Site: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

Customer Signature: \_\_\_\_\_

Recycling Facility

Operator Signature: \_\_\_\_\_

Date: \_\_\_\_\_

**Slurry Receipt**

ABC Slurry, Inc.  
1012 ABC Lane  
Metal MD 22222  
1-800-555-5556

Date Delivered:  
Customer:

Ship to:

Order No.	Amount Ordered (yards)	Shipped (yards)	Product Identifier	Description
1514	1.00	1.00	1234	Flo-Ash



### Soil Disposal Receipt

ABC Disposal Facility, Inc.  
1014 ABC Lane  
Metal MD 22222  
1-800-555-5557

#### Non-Hazardous Materials Manifest

<b>Generator Information:</b> Name: Address: Phone:	<b>Customer Information:</b> Name: Address: Phone:
<b>Carrier Information:</b> Name: Address: Phone: Driver:	
<b>Description of Commodity:</b> Non-hazardous oil-contaminated soil  <b>Date Received:</b>	<b>Vehicle Weight Information:</b> Gross: _____ Tare: _____ Net: _____ Tons: _____

Customer Signature: \_\_\_\_\_

Driver Signature: \_\_\_\_\_

Disposal Facility Operator Signature: \_\_\_\_\_

## Liquid Disposal Receipt

ABC Disposal Facility, Inc.  
 1014 ABC Lane  
 Metal MD 22222  
 1-800-555-5557

Non-Hazardous Materials Manifest

<b>Generator Information:</b>  Name:  Address:  Phone:		<b>Customer Information:</b>  Name:  Address:  Phone:		
<b>Carrier Information:</b>  EPA ID#  Name:  Address:  Phone:  Driver:				
Description:	Number of Containers:	Type of Container:	Quantity:	Units:

Customer Signature: \_\_\_\_\_

Driver Signature: \_\_\_\_\_

Disposal Facility Operator Signature: \_\_\_\_\_

Date Received: \_\_\_\_\_

## **D. Sample Locations**

# Sample Location Diagram


Key:

⊗- Sample Location

S - Soil Sample (Depth of Sample Below Grade Surface)

G - Groundwater Sample (Depth of Sample Below Grade Surface)

North  
↑



## **E. Analytical Laboratory Information**

### Chain of Custody

Name:					Signature:		Site:					
Company:					Phone:		Analysis					
Address:					Fax:							
City, State, Zip:												
Sample ID	Date Sampled	Time Sampled	Preservative	Matrix	Number of Containers	Notes:						
Relinquished by:			Date:		Time:	Received By:		Date:		Time:		
Relinquished by:			Date:		Time:	Received By:		Date:		Time:		
Relinquished by:			Date:		Time:	Received By:		Date:		Time:		
Relinquished by:			Date:		Time:	Received By:		Date:		Time:		

Special Instructions:
-----------------------

# ABC Laboratory

1015 Analysis Way Anywhere MD Phone: 410-555-5555 Fax: 410-555-5556

## Certificate of Analysis

Sample Identification:	W-1 (potable well)
Matrix:	Water
Date Sampled:	1-1-07
Date Received:	1-2-07
Date Analyzed:	1-8-07
Analyst:	River

Volatile Organic Compound	Limit of Detection	EPA Method	Result	Units
Dichlorodifluoromethane	0.5	524.2	ND	ug/kg
Chloromethane	0.5	524.2	ND	ug/kg
Vinyl Chloride	0.5	524.2	ND	ug/kg
Bromomethane	0.5	524.2	ND	ug/kg
Chloroethane	0.5	524.2	ND	ug/kg
Trichlorofluoromethane	0.5	524.2	ND	ug/kg
1,1-Dichloroethene	0.5	524.2	ND	ug/kg
tert-Butyl Alcohol (TBA)	0.5	524.2	ND	ug/kg
Methylene Chloride	0.5	524.2	ND	ug/kg
trans-1,2-Dichloroethene	0.5	524.2	ND	ug/kg
Methyl tert-Butyl Ether (MtBE)	0.5	524.2	ND	ug/kg
1,1-Dichloroethane	0.5	524.2	ND	ug/kg
Diisopropyl Ether (DIPE)	0.5	524.2	ND	ug/kg
cis-1,2-Dichloroethene	0.5	524.2	ND	ug/kg
Bromochloromethane	0.5	524.2	ND	ug/kg
Chloroform	0.5	524.2	ND	ug/kg
2,2-Dichloropropane	0.5	524.2	ND	ug/kg

Ethyl tert-Butyl Ether (EtBE)	0.5	524.2	ND	ug/kg
1,2-Dichloroethane	0.5	524.2	ND	ug/kg
tert-Amyl Alcohol (TAA)	0.5	524.2	ND	ug/kg
1,1,1-Trichloroethane	0.5	524.2	ND	ug/kg
1,1-Dichloropropene	0.5	524.2	ND	ug/kg
Carbon tetrachloride	0.5	524.2	ND	ug/kg
Benzene	0.5	524.2	ND	ug/kg
tert-Amyl Methyl Ether (TAME)	0.5	524.2	ND	ug/kg
Dibromomethane	0.5	524.2	ND	ug/kg
1,2-Dichloropropane	0.5	524.2	ND	ug/kg
Trichloroethene	0.5	524.2	ND	ug/kg
Bromodichloromethane	0.5	524.2	ND	ug/kg
tert-Amyl Ethyl Ether (TAEE)	0.5	524.2	ND	ug/kg
cis-1,3-Dichloropropene	0.5	524.2	ND	ug/kg
trans-1,3-Dichloropropene	0.5	524.2	ND	ug/kg
1,1,2-Trichloroethane	0.5	524.2	ND	ug/kg
Toluene	0.5	524.2	ND	ug/kg
1,3-Dichloropropane	0.5	524.2	ND	ug/kg
Dibromochloromethane	0.5	524.2	ND	ug/kg
1,2-Dibromomethane	0.5	524.2	ND	ug/kg
Tetrachloroethene	0.5	524.2	ND	ug/kg
1,1,1,2-Tetrachloroethene	0.5	524.2	ND	ug/kg
Chlorobenzene	0.5	524.2	ND	ug/kg
Ethylbenzene	0.5	524.2	ND	ug/kg
m&p-Xylene	0.5	524.2	ND	ug/kg
Bromoform	0.5	524.2	ND	ug/kg
Styrene	0.5	524.2	ND	ug/kg
o-Xylene	0.5	524.2	ND	ug/kg
1,1,2,2-Tetrachloroethane	0.5	524.2	ND	ug/kg
1,2,3-Trichloropropane	0.5	524.2	ND	ug/kg
Isopropylbenzene	0.5	524.2	ND	ug/kg
Bromobenzene	0.5	524.2	ND	ug/kg



n-Propylbenzene	0.5	524.2	ND	ug/kg
2-Chlorotoluene	0.5	524.2	ND	ug/kg
4-Chlorotoluene	0.5	524.2	ND	ug/kg
1,3,5-Trimethylbenzene	0.5	524.2	ND	ug/kg
tert-Butylbenzene	0.5	524.2	ND	ug/kg
1,2,4-Trimethylbenzene	0.5	524.2	ND	ug/kg
sec-Butylbenzene	0.5	524.2	ND	ug/kg
1,3-Dichlorobenzene	0.5	524.2	ND	ug/kg
1,4-Dichlorobenzene	0.5	524.2	ND	ug/kg
1,2-Dichlorobenzene	0.5	524.2	ND	ug/kg
p-iso-Propyltoluene	0.5	524.2	ND	ug/kg
n-Butylbenzene	0.5	524.2	ND	ug/kg
1,2-Dibromo-3-chloropropane	0.5	524.2	ND	ug/kg
1,2,4-Trichlorobenzene	0.5	524.2	ND	ug/kg
Naphthalene	0.5	524.2	ND	ug/kg
Hexachlorobutadiene	0.5	524.2	ND	ug/kg
1,2,3-Trichlorobenzene	0.5	524.2	ND	ug/kg
<p>Note:  ND – Not Detected at a Concentration  Greater Than Detection Limit</p>				

# ABC Laboratory

1015 Analysis Way Anywhere MD Phone: 410-555-5555 Fax: 410-555-5556

## Certificate of Analysis

Sample Identification:	G-1 (non-potable well)			
Matrix:	Water			
Date Sampled:	1-1-07			
Date Received:	1-2-07			
Date Analyzed:	1-8-07			
Analyst:	River			
Compound	Limit of Detection	EPA Method	Result	Units
Dichlorodifluoromethane	50	8260	ND	ug/kg
Chloromethane	50	8260	ND	ug/kg
Vinyl Chloride	50	8260	ND	ug/kg
Bromomethane	50	8260	ND	ug/kg
Chloroethane	50	8260	ND	ug/kg
Trichlorofluoromethane	50	8260	ND	ug/kg
1,1-Dichloroethene	50	8260	ND	ug/kg
tert-Butyl Alcohol (TBA)	500	8260	ND	ug/kg
Methylene Chloride	50	8260	ND	ug/kg
trans-1,2-Dichloroethene	50	8260	ND	ug/kg
Methyl tert-Butyl Ether (MtBE)	50	8260	ND	ug/kg
1,1-Dichloroethane	50	8260	ND	ug/kg
Diisopropyl Ether (DIPE)	50	8260	ND	ug/kg
cis-1,2-Dichloroethene	50	8260	ND	ug/kg
Bromochloromethane	50	8260	ND	ug/kg
Chloroform	50	8260	ND	ug/kg

2,2-Dichloropropane	50	8260	ND	ug/kg
Ethyl tert-Butyl Ether (EtBE)	50	8260	ND	ug/kg
1,2-Dichloroethane	50	8260	ND	ug/kg
tert-Amyl Alcohol (TAA)	500	8260	ND	ug/kg
1,1,1-Trichloroethane	50	8260	ND	ug/kg
1,1-Dichloropropene	50	8260	ND	ug/kg
Carbon tetrachloride	50	8260	ND	ug/kg
Benzene	50	8260	ND	ug/kg
tert-Amyl Methyl Ether (TAME)	50	8260	ND	ug/kg
Dibromomethane	50	8260	ND	ug/kg
1,2-Dichloropropane	50	8260	ND	ug/kg
Trichloroethene	50	8260	ND	ug/kg
Bromodichloromethane	50	8260	ND	ug/kg
tert-Amyl Ethyl Ether (TAEE)	50	8260	ND	ug/kg
cis-1,3-Dichloropropene	50	8260	ND	ug/kg
trans-1,3-Dichloropropene	50	8260	ND	ug/kg
1,1,2-Trichloroethane	50	8260	ND	ug/kg
Toluene	50	8260	ND	ug/kg
1,3-Dichloropropane	50	8260	ND	ug/kg
Dibromochloromethane	50	8260	ND	ug/kg
1,2-Dibromomethane	50	8260	ND	ug/kg
Tetrachloroethene	50	8260	ND	ug/kg
1,1,1,2-Tetrachloroethene	50	8260	ND	ug/kg
Chlorobenzene	50	8260	ND	ug/kg
Ethylbenzene	50	8260	ND	ug/kg
m&p-Xylene	50	8260	ND	ug/kg
Bromoform	50	8260	ND	ug/kg
Styrene	50	8260	ND	ug/kg
o-Xylene	50	8260	ND	ug/kg
1,1,2,2-Tetrachloroethane	50	8260	ND	ug/kg
1,2,3-Trichloropropane	50	8260	ND	ug/kg
Isopropylbenzene	50	8260	ND	ug/kg

Bromobenzene	50	8260	ND	ug/kg
n-Propylbenzene	50	8260	ND	ug/kg
2-Chlorotoluene	50	8260	ND	ug/kg
4-Chlorotoluene	50	8260	ND	ug/kg
1,3,5-Trimethylbenzene	50	8260	ND	ug/kg
tert-Butylbenzene	50	8260	ND	ug/kg
1,2,4-Trimethylbenzene	50	8260	ND	ug/kg
sec-Butylbenzene	50	8260	ND	ug/kg
1,3-Dichlorobenzene	50	8260	ND	ug/kg
1,4-Dichlorobenzene	50	8260	ND	ug/kg
1,2-Dichlorobenzene	50	8260	ND	ug/kg
p-iso-Propyltoluene	50	8260	ND	ug/kg
n-Butylbenzene	50	8260	ND	ug/kg
1,2-Dibromo-3-chloropropane	50	8260	ND	ug/kg
1,2,4-Trichlorobenzene	50	8260	ND	ug/kg
Naphthalene	50	8260	ND	ug/kg
Hexachlorobutadiene	50	8260	ND	ug/kg
1,2,3-Trichlorobenzene	50	8260	ND	ug/kg
TPH GRO	100	8015B	ND	mg/kg
TPH DRO	500	8015B	ND	mg/kg

## ABC Laboratory

1015 Analysis Way Anywhere MD Phone: 410-555-5555 Fax: 410-555-5556

### *Certificate of Analysis*

#### VOLATILE ORGANIC COMPOUND (VOC) By Method 8260

Sample Identification:	S-1	S-2	S-3	S-4	S-5	
	1234 Main Street					
Matrix:	Soil	Soil	Soil	Soil	Soil	
Date Sampled:	1/1/07	1/1/07	1/1/07	1/1/07	1/1/07	
Date Received:	1/2/07	1/2/07	1/2/07	1/2/07	1/2/07	
Date Analyzed:	1/8/07	1/8/07	1/8/07	1/8/07	1/8/07	
Analyst:	River					
Unit:	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg
						Detection Limit
Dichlorodifluoromethane	ND	ND	ND	ND	ND	5.0
Chloromethane	ND	ND	ND	ND	ND	5.0
Vinyl Chloride	ND	ND	ND	ND	ND	5.0
Bromomethane	ND	ND	ND	ND	ND	5.0
Chloroethane	ND	ND	ND	ND	ND	5.0
Trichlorofluoromethane	ND	ND	ND	ND	ND	5.0
1,1-Dichloroethene	ND	ND	ND	ND	ND	5.0
tert-Butyl Alcohol (TBA)	ND	ND	ND	ND	ND	5.0
Methylene Chloride	ND	ND	ND	ND	ND	5.0
trans-1,2-Dichloroethene	ND	ND	ND	ND	ND	5.0
Methyl tert-Butyl Ether (MtBE)	ND	ND	800	180	ND	5.0
1,1-Dichloroethane	ND	ND	ND	ND	ND	5.0
Diisopropyl Ether (DIPE)	ND	ND	ND	ND	ND	5.0
cis-1,2-Dichloroethene	ND	ND	ND	ND	ND	5.0
Bromochloromethane	ND	ND	ND	ND	ND	5.0
Chloroform	ND	ND	ND	ND	ND	5.0
2,2-Dichloropropane	ND	ND	ND	ND	ND	5.0
Ethyl tert-Butyl Ether (EtBE)	ND	ND	ND	ND	ND	5.0
1,2-Dichloroethane	ND	ND	ND	ND	ND	5.0
tert-Amyl Alcohol (TAA)	ND	ND	ND	ND	ND	5.0
1,1,1-Trichloroethane	ND	ND	ND	ND	ND	5.0
1,1-Dichloropropene	ND	ND	ND	ND	ND	5.0
Carbon tetrachloride	ND	ND	ND	ND	ND	5.0
Benzene	ND	ND	600	5		5.0

tert-Amyl Methyl Ether (TAME)	ND	ND	ND	ND	ND	5.0
Dibromomethane	ND	ND	ND	ND	ND	5.0
1,2-Dichloropropane	ND	ND	ND	ND	ND	5.0
Trichloroethene	ND	ND	ND	ND	ND	5.0
Bromodichloromethane	ND	ND	ND	ND	ND	5.0
tert-Amyl Ethyl Ether (TAAE)	ND	ND	ND	ND	ND	5.0
cis-1,3-Dichloropropene	ND	ND	ND	ND	ND	5.0
trans-1,3-Dichloropropene	ND	ND	ND	ND	ND	5.0
1,1,2-Trichloroethane	ND	ND	ND	ND	ND	5.0
Toluene	ND	ND	20	1,000	ND	5.0
1,3-Dichloropropane	ND	ND	ND	ND	ND	5.0
Dibromochloromethane	ND	ND	ND	ND	ND	5.0
1,2-Dibromomethane	ND	ND	ND	ND	ND	5.0
Tetrachloroethene	ND	ND	ND	ND	ND	5.0
1,1,1,2-Tetrachloroethene	ND	ND	ND	ND	ND	5.0
Chlorobenzene	ND	ND	ND	ND	ND	5.0
Ethylbenzene	ND	ND	1,000	700	ND	5.0
m&p-Xylene	ND	ND	ND	ND	ND	5.0
Bromoform	ND	ND	ND	ND	ND	5.0
Styrene	ND	ND	ND	ND	ND	5.0
o-Xylene	ND	ND	ND	ND	ND	5.0
1,1,2,2-Tetrachloroethane	ND	ND	ND	ND	ND	5.0
1,2,3-Trichloropropane	ND	ND	ND	ND	ND	5.0
Isopropylbenzene	ND	ND	ND	ND	ND	5.0
Bromobenzene	ND	ND	ND	ND	ND	5.0
n-Propylbenzene	ND	ND	ND	ND	ND	5.0
2-Chlorotoluene	ND	ND	ND	ND	ND	5.0
4-Chlorotoluene	ND	ND	ND	ND	ND	5.0
1,3,5-Trimethylbenzene	ND	ND	ND	ND	ND	5.0
tert-Butylbenzene	ND	ND	ND	ND	ND	5.0
1,2,4-Trimethylbenzene	ND	ND	ND	ND	ND	5.0
sec-Butylbenzene	ND	ND	ND	ND	ND	5.0
1,3-Dichlorobenzene	ND	ND	ND	ND	ND	5.0
1,4-Dichlorobenzene	ND	ND	ND	ND	ND	5.0
1,2-Dichlorobenzene	ND	ND	ND	ND	ND	5.0
p-iso-Propyltoluene	ND	ND	ND	ND	ND	5.0
n-Butylbenzene	ND	ND	ND	ND	ND	5.0
1,2-Dibromo-3-chloropropane	ND	ND	ND	ND	ND	5.0
1,2,4-Trichlorobenzene	ND	ND	ND	ND	ND	5.0
Naphthalene	ND	ND	420	80	ND	5.0
Hexachlorobutadiene	ND	ND	ND	ND	ND	5.0
1,2,3-Trichlorobenzene	ND	ND	ND	ND	ND	5.0

ug/kg – Parts Per Billion (PPB)  
mg/kg – Parts Per Million (PPM)

# ABC Laboratory

1015 Analysis Way Anywhere MD Phone: 410-555-5555 Fax: 410-555-5556

## *Certificate of Analysis*

### DIESEL-RANGE ORGANICS (DRO) By Method 8015

Sample Identification:	S-1	S-2	S-3	S-4	S-5
	1234 Main Street				
Matrix:	Soil	Soil	Soil	Soil	Soil
Date Sampled:	1/1/07	1/1/07	1/1/07	1/1/07	1/1/07
Date Received:	1/2/07	1/2/07	1/2/07	1/2/07	1/2/07
Date Analyzed:	1/8/07	1/8/07	1/8/07	1/8/07	1/8/07
Analyst:	River				
Unit:	mg/kg	mg/kg	mg/kg	mg/kg	mg/kg

---

Diesel-Range Organics	11 U	11 U	750	10	11 U
Gasoline Range Organics	11 U	11 U	2,400	230	11 U

ug/kg – Micrograms per kilogram (parts per billion)

mg/kg – Milligrams per kilogram (parts per million)

U- Less than laboratory reported quantitation limit

# ABC Laboratory

1015 Analysis Way Anywhere MD Phone: 410-555-5555 Fax: 410-555-5556

## *Certificate of Analysis*

### DIESEL-RANGE ORGANICS (DRO) By Method 8015

Sample Identification:	S-6	S-7	S-8	S-9
	1234 Main Street			
Matrix:	Soil	Soil	Soil	Soil
Date Sampled:	1/1/07	1/1/07	1/1/07	1/1/07
Date Received:	1/2/07	1/2/07	1/2/07	1/2/07
Date Analyzed:	1/8/07	1/8/07	1/8/07	1/8/07
Analyst:	River			
Unit:	mg/kg	mg/kg	mg/kg	mg/kg

---

Diesel-Range Organics	230	11 U	11 U	11 U
-----------------------	-----	------	------	------

Gasoline Range Organics	60	11 U	11 U	11 U
-------------------------	----	------	------	------

ug/kg – Micrograms per kilogram (parts per billion)

mg/kg – Milligrams per kilogram (parts per million)

U- Less than laboratory reported quantitation limit



## **F. Registration Information**

All UST system closures, including abandonment in-place, require one of the Department's notification/registration forms listed below to be completed and submitted to the Oil Control Program before a case is reviewed and closed. Both forms require a signature from the owner or owner's representative.

### **1. New Facility or previously unregistered UST Registration Notification Form for Underground Storage Tank Systems**

The registration notification forms and instructions may be found online at:

<http://mde.maryland.gov/programs/Land/Pages/landpermits.aspx>

### **2. Existing Facility or previously register UST Removal/Abandonment 30-Day Written Notification**

The 30-day written notification form may be found online at:

<http://mde.maryland.gov/programs/Land/Pages/landpermits.aspx>

Waste Management Administration • Oil Control Program

## NOTIFICATION FOR UNDERGROUND STORAGE TANKS

### Return completed form to:

Maryland Department of the Environment  
Oil Control Program  
1800 Washington Boulevard, Suite 620  
Baltimore MD 21230-1719

.....

### Type Of Notification: (check one)

New Facility    Amended    Closure

\_\_\_\_\_ Number of tanks at facility

\_\_\_\_\_ Number of continuation sheets attached

### State Use Only

Facility ID Number: \_\_\_\_\_

Alt ID Number: \_\_\_\_\_

Date Entered into Computer: \_\_\_\_\_

Data Clerk's Initials: \_\_\_\_\_

Owner Contacted to Clarify Response: \_\_\_\_\_

Comments: \_\_\_\_\_

### I. OWNERSHIP INFORMATION:

Owner Name: \_\_\_\_\_

Street Address: \_\_\_\_\_

City \_\_\_\_\_ State \_\_\_\_\_ Zip Code \_\_\_\_\_

County: \_\_\_\_\_

Mailing Address (if different from above): \_\_\_\_\_

Phone Number: \_\_\_\_\_

Contact Person: \_\_\_\_\_

Owner ID: \_\_\_\_\_

### Type Of Owner: (check one)

#### Government

\_\_\_\_\_ Federal

\_\_\_\_\_ State

\_\_\_\_\_ Local

#### Commercial

\_\_\_\_\_ Corporation

\_\_\_\_\_ Company

\_\_\_\_\_ Partnership

\_\_\_\_\_ Individual

#### Non-Commercial

\_\_\_\_\_ Residential

\_\_\_\_\_ Agricultural

\_\_\_\_\_ Non-Profit Agency

### II. LOCATION OF TANK(S):

Facility Name or  
Company Site Identifier (as applicable): \_\_\_\_\_

Street Address: \_\_\_\_\_

City \_\_\_\_\_ State \_\_\_\_\_ Zip Code \_\_\_\_\_ County \_\_\_\_\_

Mailing Address (if different from above): \_\_\_\_\_

Phone Number: \_\_\_\_\_

Facility Operator: \_\_\_\_\_

**III. TYPE OF FACILITY:** (check one)

- |  |  |   |
|--|--|---|
| <input type="checkbox"/> Federal Non-Military  | <input type="checkbox"/> Gas Station           | <input type="checkbox"/> Private Home   |
| <input type="checkbox"/> Federal Military      | <input type="checkbox"/> Petroleum Distributor | <input type="checkbox"/> Apt. / Condo   |
| <input type="checkbox"/> Educational           | <input type="checkbox"/> Trucking/Transport    | <input type="checkbox"/> Farm / Nursery |
| <input type="checkbox"/> Fire/Rescue/Ambulance | <input type="checkbox"/> Industrial            | <input type="checkbox"/> Marina         |
| <input type="checkbox"/> Public Service        | <input type="checkbox"/> Contractor            | <input type="checkbox"/> Store          |
| <input type="checkbox"/> Utilities             | <input type="checkbox"/> Airline               | <input type="checkbox"/> Office         |
| <input type="checkbox"/> Railroad              | <input type="checkbox"/> Auto Dealership       | <input type="checkbox"/> Other: _____   |

**IV. CONTACT PERSON IN CHARGE OF TANKS:**

Name: \_\_\_\_\_ Job Title: \_\_\_\_\_

Street Address: \_\_\_\_\_ Phone Number: \_\_\_\_\_

City \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_ County \_\_\_\_\_

**V. FINANCIAL RESPONSIBILITY:** (if applicable - see instruction sheet)

I have met the financial responsibility requirements in accordance with 40 CFR Part 280, Subpart H

Yes  No

Policy #: _____	<input type="checkbox"/> Commercial Insurance	<input type="checkbox"/> Letter of Credit
Insurer: _____	<input type="checkbox"/> Self Insurance	<input type="checkbox"/> Surety Bond
Agent/Broker: _____	<input type="checkbox"/> Insurance Pool	<input type="checkbox"/> Other method allowed
Phone No.: _____	<input type="checkbox"/> Risk Retention Group	(specify) _____
	<input type="checkbox"/> Guarantee	

**VI. CERTIFICATION:** (to be completed by owner or owner's representative)

I certify, under penalty of law, that I have personally examined, and am familiar with, the information submitted in this and all attached documents, and that the information provided is in compliance with COMAR 26.10.03, and is true, accurate, and complete.

Name (print/type): \_\_\_\_\_

Title (print/type): \_\_\_\_\_

Signature: \_\_\_\_\_

Date Signed: \_\_\_\_\_

**VII. DESCRIPTION OF UNDERGROUND STORAGE TANKS: (complete for each tank at this facility)**

Tank Identification Number	Tank No.	Tank No.	Tank No.	Tank No.	Tank No.
Alt. Tank ID Number	Tank No.	Tank No.	Tank No.	Tank No.	Tank No.
1. Status of Tank (mark only one) -Currently In Use -Temporarily Out of Use -Permanently Out of Use	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
2. Date of Installation (mo/yr)					
3. Total Capacity (gallons)					
4. Material of Tank Construction (mark all that apply) -Asphalt Coated or Bare Steel -Cathodically Protected Steel -Composite (Steel w/ Fiberglass) -Concrete -Fiberglass Reinforced Plastic -Polyethylene Tank Jacket -Unknown -Other (specify)	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
-Has tank been repaired?	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> YES <input type="checkbox"/> NO
-Double-walled -Excavation Liner -Lined Interior	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
5. Material of Piping Construction (mark all that apply) -Bare Steel -Galvanized Steel -Fiberglass Reinforced Plastic -Copper -Flexible Plastic -Unknown -Other (specify)	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
-Cathodically Protected -Double-walled -Secondary Containment (specify)	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/>
6. Type of Piping (mark all that apply) -Pressure -Gravity Feed -Suction: no valve at tank (Safe Suction) -Suction: valve at tank (U.S. Suction) -Has piping been repaired?	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> YES <input type="checkbox"/> NO	<input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> YES <input type="checkbox"/> NO
7. Substance Currently or Last Stored -Gasoline -Diesel	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>	<input type="checkbox"/> <input type="checkbox"/>

Tank Identification Number	Tank No.	Tank No.	Tank No.	Tank No.	Tank No.
Alt. Tank ID Number	Tank No.	Tank No.	Tank No.	Tank No.	Tank No.
-Gasohol -Kerosene -Heating Oil -Used Oil -Hazardous Substance CERCLA name and/or CAS # -Other (specify) -Mixture of Substances (specify)					
8. Closing of Tank -Estimated date last used (mo/dd/yr) -Date tank closed (mo/dd/yr) -Tank removed from ground? -Tank filled with inert material? -If yes, material used					
-Change in service to non-regulated substance?	YES NO	YES NO	YES NO	YES NO	YES NO
9. Site Assessment Completed?	YES NO	YES NO	YES NO	YES NO	YES NO
10. Release Detection (mark all that apply) -Manual Tank Gauging -Tank Tightness Testing -Inventory Controls -Automatic Tank Gauging -Vapor Monitoring -Groundwater Monitoring -Interstitial Monitoring -Double-walled Tank/Piping -Statistical Inventory Reconciliation (SIR) -Automatic Line Leak Detection -Line Tightness Testing -Other Method Allowed (specify)	TANK PIPING	TANK PIPING	TANK PIPING	TANK PIPING	TANK PIPING
11. Spill and Overflow Protection -Overflow device installed -Spill catch basin					
12. Stage I Vapor Recovery?	YES NO	YES NO	YES NO	YES NO	YES NO
13. Stage II Vapor Recovery?	YES NO	YES NO	YES NO	YES NO	YES NO

**VIII. CERTIFICATION OF COMPLIANCE:** (complete for all new and upgraded tanks at this location)

**Installer Certification**

I certify that the underground storage system installed, upgraded, or repaired at this facility is in compliance with all applicable regulations.

Installer: \_\_\_\_\_  
 Print Name Signature

MDIC- \_\_\_\_\_  
 State Identification Number Date Company