

KEEP PERMIT AT SITE

CONTROL NO. B- 05575

Larry Hogan
Governor

Boyd Rutherford
Lieutenant Governor



Ben Grumbles
Secretary

DEPARTMENT OF THE ENVIRONMENT

Air and Radiation Administration
1800 Washington Boulevard, Suite 720
Baltimore, MD 21230

Construction Permit

Part 70
 Operating Permit

PERMIT NO. 24-025-0024

DATE ISSUED November 1, 2018

PERMIT FEE To be paid in accordance with COMAR 26.11.02.19B

EXPIRATION DATE October 31, 2023

LEGAL OWNER & ADDRESS
Constellation Power Source Generation, LLC
Fort Smallwood Road Complex
1005 Brandon Shores Road
Baltimore, MD 21226
Attn: Mr. David Ciotti, Site Environmental Specialist

SITE
Perryman Generating Station
900 Chelsea Road
Aberdeen, MD 21001
Harford County
AI#3946

SOURCE DESCRIPTION

Renewal of Part 70 PTO for an Electric Generating Peaking Station.

This source is subject to the conditions described on the attached pages.

Page 1 of 95

Program Manager

Director, Air and Radiation Administration

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

SECTION I	SOURCE IDENTIFICATION	4
1.	DESCRIPTION OF FACILITY	4
2.	FACILITY INVENTORY LIST	4
SECTION II	GENERAL CONDITIONS	6
1.	DEFINITIONS	6
2.	ACRONYMS	6
3.	EFFECTIVE DATE	7
4.	PERMIT EXPIRATION	7
5.	PERMIT RENEWAL	7
6.	CONFIDENTIAL INFORMATION	8
7.	PERMIT ACTIONS	8
8.	PERMIT AVAILABILITY	9
9.	REOPENING THE PART 70 PERMIT FOR CAUSE BY THE EPA.....	9
10.	TRANSFER OF PERMIT	9
11.	REVISION OF PART 70 PERMITS – GENERAL CONDITIONS	9
12.	SIGNIFICANT PART 70 OPERATING PERMIT MODIFICATIONS	10
13.	MINOR PERMIT MODIFICATIONS.....	11
14.	ADMINISTRATIVE PART 70 OPERATING PERMIT AMENDMENTS.....	14
15.	OFF-PERMIT CHANGES TO THIS SOURCE.....	16
16.	ON-PERMIT CHANGES TO SOURCES	17
17.	FEE PAYMENT	19
18.	REQUIREMENTS FOR PERMITS-TO-CONSTRUCT AND APPROVALS	19
19.	CONSOLIDATION OF PROCEDURES FOR PUBLIC PARTICIPATION.....	20
20.	PROPERTY RIGHTS	21
21.	SEVERABILITY	21
22.	INSPECTION AND ENTRY	21
23.	DUTY TO PROVIDE INFORMATION.....	22
24.	COMPLIANCE REQUIREMENTS	22
25.	CREDIBLE EVIDENCE	23
26.	NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE	23
27.	CIRCUMVENTION	23
28.	PERMIT SHIELD	23
29.	ALTERNATE OPERATING SCENARIOS	24
SECTION III	PLANT WIDE CONDITIONS.....	25
1.	PARTICULATE MATTER FROM CONSTRUCTION AND DEMOLITION.....	25
2.	OPEN BURNING	25
3.	AIR POLLUTION EPISODE	25
4.	REPORT OF EXCESS EMISSIONS AND DEVIATIONS	25
5.	ACCIDENTAL RELEASE PROVISIONS	26
6.	GENERAL TESTING REQUIREMENTS	27
7.	EMISSIONS TEST METHODS.....	27
8.	EMISSIONS CERTIFICATION REPORT	28
9.	COMPLIANCE CERTIFICATION REPORT.....	29
10.	CERTIFICATION BY RESPONSIBLE OFFICIAL.....	30
11.	SAMPLING AND EMISSIONS TESTING RECORD KEEPING.....	30

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

12.	GENERAL RECORDKEEPING	31
13.	GENERAL CONFORMITY	31
14.	ASBESTOS PROVISIONS	31
15.	OZONE DEPLETING REGULATIONS	32
16.	ACID RAIN PERMIT	32
SECTION V INSIGNIFICANT ACTIVITIES		93
SECTION VI STATE-ONLY ENFORCEABLE CONDITIONS.....		95

Appendix A - Acid Rain Permit

Appendix B - CO₂ Budget Permit

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

SECTION I SOURCE IDENTIFICATION

1. DESCRIPTION OF FACILITY

The Perryman Generating Station (Perryman Station) is an electric generating station located in eastern Harford County. The facility generates electricity for peak loads. The SIC code for this facility is 4911.

The Perryman Station consists of the following: four (4) identical Westinghouse model 501 simple cycle combustion turbines capable of burning only distillate oil; one (1) GE Frame 7FA simple cycle combustion turbine with dual fuel firing capability and a 120-MW gas turbine electric generator package, comprised of two identical simple cycle combustion turbines, and associated facilities (Perryman 6 Project).

2. FACILITY INVENTORY LIST

Emissions Unit Number	MDE Registration Number	Emissions Unit Name and Description	Date of Installation
PY-Unit1	12-4-0081	One (1) Westinghouse model 501 simple cycle combustion turbine with a design heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	Jan 1972
PY-Unit2	12-4-0082	One (1) Westinghouse model 501 simple cycle combustion turbine with a design heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	Apr 1972
PY-Unit3	12-4-0083	One (1) Westinghouse model 501 simple cycle combustion turbine with a design heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	Apr 1972
PY-Unit4	12-4-0084	One (1) Westinghouse model 501 simple cycle combustion turbine with a design heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	Apr 1972
PY-Unit51	12-5-0088	One (1) General Electric Frame 7FA stationary, single-shaft combustion turbine with a design heat input of 1900 MMBtu/hr, operating in the simple cycle mode rate at	Jun 1995

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Emissions Unit Number	MDE Registration Number	Emissions Unit Name and Description	Date of Installation
		a nominal 150 megawatts output. This turbine has dual fuel (natural gas and No. 2 oil) firing capability.	
CT6A & CT6B	025-0024-5-0353 & 025-0024-5-0354	One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted.	Apr 2015
EG6	025-0024-9-0492	One (1) diesel-fired emergency generator rated at 268 hp. This generator is fired with ultra-low sulfur diesel (ULSD)	Apr 2015
FWP6	025-00249-0502	One (1) diesel-fired emergency firewater pump engine rated at 181 hp. This generator is fired with ultra-low sulfur diesel (ULSD)	Apr 2015
FUG6	NA	Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.	Apr 2015
CB6	NA	Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF ₆).	Apr 2015
PR6	NA	Paved road emissions associated with the Perryman 6 Project. Emissions from this emission unit are assumed to be entirely PM _{2.5} and PM ₁₀ .	Apr 2015

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

SECTION II GENERAL CONDITIONS

1. DEFINITIONS

[COMAR 26.11.01.01] and [COMAR 26.11.02.01]

The words or terms in this Part 70 permit shall have the meanings established under COMAR 26.11.01 and .02 unless otherwise stated in this permit.

2. ACRONYMS

ARA	Air and Radiation Administration
BACT	Best Available Control Technology
Btu	British thermal unit
CAA	Clean Air Act
CAM	Compliance Assurance Monitoring
CEM	Continuous Emissions Monitor
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COMAR	Code of Maryland Regulations
EPA	United States Environmental Protection Agency
FR	Federal Register
gr	grains
HAP	Hazardous Air Pollutant
MACT	Maximum Achievable Control Technology
MDE	Maryland Department of the Environment
MVAC	Motor Vehicle Air Conditioner
NESHAPS	National Emission Standards for Hazardous Air Pollutants
NO _x	Nitrogen Oxides
NSPS	New Source Performance Standards
NSR	New Source Review
OTR	Ozone Transport Region
PM	Particulate Matter
PM10	Particulate Matter with Nominal Aerodynamic Diameter of 10 micrometers or less
ppm	parts per million
ppb	parts per billion
PSD	Prevention of Significant Deterioration
PTC	Permit to construct
PTO	Permit to operate (State)
SIC	Standard Industrial Classification
SO ₂	Sulfur Dioxide

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

TAP	Toxic Air Pollutant
tpy	tons per year
VE	Visible Emissions
VOC	Volatile Organic Compounds

3. EFFECTIVE DATE

The effective date of the conditions in this Part 70 permit is the date of permit issuance, unless otherwise stated in the permit.

4. PERMIT EXPIRATION

[COMAR 26.11.03.13B(2)]

Upon expiration of this permit, the terms of the permit will automatically continue to remain in effect until a new Part 70 permit is issued for this facility provided that the Permittee has submitted a timely and complete application and has paid applicable fees under COMAR 26.11.02.16.

Otherwise, upon expiration of this permit the right of the Permittee to operate this facility is terminated.

5. PERMIT RENEWAL

[COMAR 26.11.03.02B(3)] and [COMAR 26.11.03.02E]

The Permittee shall submit to the Department a completed application for renewal of this Part 70 permit at least 12 months before the expiration of the permit. Upon submitting a completed application, the Permittee may continue to operate this facility pending final action by the Department on the renewal.

The Permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall submit such supplementary facts or corrected information no later than 10 days after becoming aware that this occurred. The Permittee shall also provide additional information as necessary to address any requirements that become applicable to the facility after the date a completed application was submitted, but prior to the release of a draft permit. This information shall be submitted to the Department no later than 20 days after a new requirement has been adopted.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

6. CONFIDENTIAL INFORMATION

[COMAR 26.11.02.02G]

In accordance with the provisions of the State Government Article, Sec. 10-611 et seq., Annotated Code of Maryland, all information submitted in an application shall be considered part of the public record and available for inspection and copying, unless the Permittee claims that the information is confidential when it is submitted to the Department. At the time of the request for inspection or copying, the Department will make a determination with regard to the confidentiality of the information. The Permittee, when requesting confidentiality, shall identify the information in a manner specified by the Department and, when requested by the Department, promptly provide specific reasons supporting the claim of confidentiality. Information submitted to the Department without a request that the information be deemed confidential may be made available to the public. Subject to approval of the Department, the Permittee may provide a summary of confidential information that is suitable for public review. The content of this Part 70 permit is not subject to confidential treatment.

7. PERMIT ACTIONS

[COMAR 26.11.03.06E(3)] and [COMAR 26.11.03.20(A)]

This Part 70 permit may be revoked or reopened and revised for cause. The filing of an application by the Permittee for a permit revision or renewal; or a notification of termination, planned changes or anticipated noncompliance by the facility, does not stay a term or condition of this permit.

The Department shall reopen and revise, or revoke the Permittee's Part 70 permit under the following circumstances:

- a. Additional requirements of the Clean Air Act become applicable to this facility and the remaining permit term is 3 years or more;
- b. The Department or the EPA determines that this Part 70 permit contains a material mistake, or is based on false or inaccurate information supplied by or on behalf of the Permittee;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- c. The Department or the EPA determines that this Part 70 permit must be revised or revoked to assure compliance with applicable requirements of the Clean Air Act; or
- d. Additional requirements become applicable to an affected source under the Federal Acid Rain Program.

8. PERMIT AVAILABILITY

[COMAR 26.11.02.13G]

The Permittee shall maintain this Part 70 permit in the vicinity of the facility for which it was issued, unless it is not practical to do so, and make this permit immediately available to officials of the Department upon request.

9. REOPENING THE PART 70 PERMIT FOR CAUSE BY THE EPA

[COMAR 26.11.03.20B]

The EPA may terminate, modify, or revoke and reissue a permit for cause as prescribed in 40 CFR §70.7(g)

10. TRANSFER OF PERMIT

[COMAR 26.11.02.02E]

The Permittee shall not transfer this Part 70 permit except as provided in COMAR 26.11.03.15.

11. REVISION OF PART 70 PERMITS – GENERAL CONDITIONS

[COMAR 26.11.03.14] and [COMAR 26.11.03.06A(8)]

- a. The Permittee shall submit an application to the Department to revise this Part 70 permit when required under COMAR 26.11.03.15 -.17.
- b. When applying for a revision to a Part 70 permit, the Permittee shall comply with the requirements of COMAR 26.11.03.02 and .03 except that the application for a revision need include only information listed that is related to the proposed change to the source and revision to

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

the permit. This information shall be sufficient to evaluate the proposed change and to determine whether it will comply with all applicable requirements of the Clean Air Act.

- c. The Permittee may not change any provision of a compliance plan or schedule in a Part 70 permit as an administrative permit amendment or as a minor permit modification unless the change has been approved by the Department in writing.
- d. A permit revision is not required for a change that is provided for in this permit relating to approved economic incentives, marketable permits, emissions trading, and other similar programs.

12. SIGNIFICANT PART 70 OPERATING PERMIT MODIFICATIONS

[COMAR 26.11.03.17]

The Permittee may apply to the Department to make a significant modification to its Part 70 Permit as provided in COMAR 26.11.03.17 and in accordance with the following conditions:

- a. A significant modification is a revision to the federally enforceable provisions in the permit that does not qualify as an administrative permit amendment under COMAR 26.11.03.15 or a minor permit modification as defined under COMAR 26.11.03.16.
- b. This permit does not preclude the Permittee from making changes, consistent with the provisions of COMAR 26.11.03, that would make the permit or particular terms and conditions of the permit irrelevant, such as by shutting down or reducing the level of operation of a source or of an emissions unit within the source. Air pollution control equipment shall not be shut down or its level of operation reduced if doing so would violate any term of this permit.
- c. Significant permit modifications are subject to all requirements of COMAR 26.11.03 as they apply to permit issuance and renewal, including the requirements for applications, public participation, and review by affected states and EPA, except:
 - (1) An application need include only information pertaining to the proposed change to the source and modification of this permit, including a description of the change and modification, and any

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

new applicable requirements of the Clean Air Act that will apply if the change occurs;

- (2) Public participation, and review by affected states and EPA, is limited to only the application and those federally enforceable terms and conditions of the Part 70 permit that are affected by the significant permit modification.
- d. As provided in COMAR 26.11.03.15B(5), an administrative permit amendment may be used to make a change that would otherwise require a significant permit modification if procedures for enhanced preconstruction review of the change are followed that satisfy the requirements of 40 CFR 70.7(d)(1)(v).
- e. Before making a change that qualifies as a significant permit modification, the Permittee shall obtain all permits-to-construct and approvals required by COMAR 26.11.02.
- f. The Permittee shall not make a significant permit modification that results in a violation of any applicable requirement of the Clean Air Act.
- g. The permit shield in COMAR 26.11.03.23 applies to a final significant permit modification that has been issued by the Department, to the extent applicable under COMAR 26.11.03.23.

13. MINOR PERMIT MODIFICATIONS

[COMAR 26.11.03.16]

The Permittee may apply to the Department to make a minor modification to the federally enforceable provisions of this Part 70 permit as provided in COMAR 26.11.03.16 and in accordance with the following conditions:

- a. A minor permit modification is a Part 70 permit revision that:
 - (1) Does not result in a violation of any applicable requirement of the Clean Air Act;
 - (2) Does not significantly revise existing federally enforceable monitoring, including test methods, reporting, record keeping, or compliance certification requirements except by:

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- (a) Adding new requirements,
 - (b) Eliminating the requirements if they are rendered meaningless because the emissions to which the requirements apply will no longer occur, or
 - (c) Changing from one approved test method for a pollutant and source category to another;
- (3) Does not require or modify a:
- (a) Case-by-case determination of a federally enforceable emissions standard,
 - (b) Source specific determination for temporary sources of ambient impacts, or
 - (c) Visibility or increment analysis;
- (4) Does not seek to establish or modify a federally enforceable permit term or condition for which there is no corresponding underlying applicable requirement of the Clean Air Act, but that the Permittee has assumed to avoid an applicable requirement to which the source would otherwise be subject, including:
- (a) A federally enforceable emissions standard applied to the source pursuant to COMAR 26.11.02.03 to avoid classification as a Title I modification; and
 - (b) An alternative emissions standard applied to an emissions unit pursuant to regulations promulgated under Section 112(i)(5) of the Clean Air Act
- (5) Is not a Title I modification; and
- (6) Is not required under COMAR 26.11.03.17 to be processed as a significant modification to this Part 70 permit.
- b. Application for a Minor Permit Modification

The Permittee shall submit to the Department an application for a minor permit modification that satisfies the requirements of COMAR 26.11.03.03 which includes the following:

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- (1) A description of the proposed change, the emissions resulting from the change, and any new applicable requirements that will apply if the change is made;
- (2) The proposed minor permit modification;
- (3) Certification by a responsible official, in accordance with COMAR 26.11.02.02F, that:
 - (a) The proposed change meets the criteria for a minor permit modification, and
 - (b) The Permittee has obtained or applied for all required permits-to-construct required by COMAR 26.11.03.16 with respect to the proposed change;
- (4) Completed forms for the Department to use to notify the EPA and affected states, as required by COMAR 26.11.03.07-.12.

c. Permittee's Ability to Make Change

- (1) For changes proposed as minor permit modifications to this permit that will require the applicant to obtain a permit to construct, the permit to construct must be issued prior to the new change.
- (2) During the period of time after the Permittee applies for a minor modification but before the Department acts in accordance with COMAR 26.11.03.16F(2):
 - (a) The Permittee shall comply with applicable requirements of the Clean Air Act related to the change and the permit terms and conditions described in the application for the minor modification.
 - (b) The Permittee is not required to comply with the terms and conditions in the permit it seeks to modify. If the Permittee fails to comply with the terms and conditions in the application during this time, the terms and conditions of both this permit and the application for modification may be enforced against it.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- d. The Permittee is subject to enforcement action if it is determined at any time that a change made under COMAR 26.11.03.16 is not within the scope of this regulation.
- e. Minor permit modification procedures may be used for Part 70 permit modifications involving the use of economic incentives, marketable permits, emissions trading, and other similar approaches, but only to the extent that the minor permit modification procedures are explicitly provided for in regulations approved by the EPA as part of the Maryland SIP or in other applicable requirements of the Clean Air Act.

14. ADMINISTRATIVE PART 70 OPERATING PERMIT AMENDMENTS

[COMAR 26.11.03.15]

The Permittee may apply to the department to make an administrative permit amendment as provided in COMAR 26.11.03.15 and in accordance with the following conditions:

- a. An application for an administrative permit amendment shall:
 - (1) Be in writing;
 - (2) Include a statement certified by a responsible official that the proposed amendment meets the criteria in COMAR 26.11.03.15 for an administrative permit amendment, and
 - (3) Identify those provisions of this part 70 permit for which the amendment is requested, including the basis for the request.
- b. An administrative permit amendment:
 - (1) Is a correction of a typographical error;
 - (2) Identifies a change in the name, address, or phone number of a person identified in this permit, or a similar administrative change involving the Permittee or other matters which are not directly related to the control of air pollution;
 - (3) requires more frequent monitoring or reporting by the Permittee;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- (4) Allows for a change in ownership or operational control of a source for which the Department determines that no other revision to the permit is necessary and is documented as per COMAR 26.11.03.15B(4);
 - (5) Incorporates into this permit the requirements from preconstruction review permits or approvals issued by the Department in accordance with COMAR 26.11.03.15B(5), but only if it satisfies 40 CFR 70.7(d)(1)(v);
 - (6) Incorporates any other type of change, as approved by the EPA, which is similar to those in COMAR 26.11.03.15B(1)—(4);
 - (7) Notwithstanding COMAR 26.11.03.15B(1)—(6), all modifications to acid rain control provisions included in this Part 70 permit are governed by applicable requirements promulgated under Title IV of the Clean Air Act; or
 - (8) Incorporates any change to a term or condition specified as State-only enforceable, if the Permittee has obtained all necessary permits-to-construct and approvals that apply to the change.
- c. The Permittee may make the change addressed in the application for an administrative amendment upon receipt by the Department of the application, if all permits-to-construct or approvals otherwise required by COMAR 26.11.02 prior to making the change have first been obtained from the Department.
 - d. The permit shield in COMAR 26.11.03.23 applies to administrative permit amendments made under Section B(5) of COMAR 26.11.03.15 , but only after the Department takes final action to revise the permit.
 - e. The Permittee is subject to enforcement action if it is determined at any time that a change made under COMAR 26.11.03.15 is not within the scope of this regulation.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

15. OFF-PERMIT CHANGES TO THIS SOURCE

[COMAR 26.11.03.19]

The Permittee may make off-permit changes to this facility as provided in COMAR 26.11.03.19 and in accordance with the following conditions:

- a. The Permittee may make a change to this permitted facility that is not addressed or prohibited by the federally enforceable conditions of this Part 70 permit without obtaining a Part 70 permit revision if:
 - (1) The Permittee has obtained all permits and approvals required by COMAR 26.11.02 and .03;
 - (2) The change is not subject to any requirements under Title IV of the Clean Air Act;
 - (3) The change is not a Title I modification; and
 - (4) The change does not violate an applicable requirement of the Clean Air Act or a federally enforceable term or condition of the permit.
- b. For a change that qualifies under COMAR 26.11.03.19, the Permittee shall provide contemporaneous written notice to the Department and the EPA, except for a change to an emissions unit or activity that is exempt from the Part 70 permit application, as provided in COMAR 26.11.03.04. This written notice shall describe the change, including the date it was made, any change in emissions, including the pollutants emitted, and any new applicable requirements of the Clean Air Act that apply as a result of the change.
- c. Upon satisfying the requirements of COMAR 26.11.03.19, the Permittee may make the proposed change.
- d. The Permittee shall keep a record describing:
 - (1) Changes made at the facility that result in emissions of a regulated air pollutant subject to an applicable requirement of the Clean Air Act , but not otherwise regulated under this permit; and
 - (2) The emissions resulting from those changes.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- e. Changes that qualify under COMAR 26.11.03.19 are not subject to the requirements for Part 70 revisions.
- f. The Permittee shall include each off-permit change under COMAR 26.11.03.19 in the application for renewal of the part 70 permit.
- g. The permit shield in COMAR 26.11.03.23 does not apply to off-permit changes made under COMAR 26.11.03.19.
- h. The Permittee is subject to enforcement action if it is determined that an off-permit change made under COMAR 26.11.03.19 is not within the scope of this regulation.

16. ON-PERMIT CHANGES TO SOURCES

[COMAR 26.11.03.18]

The Permittee may make on-permit changes that are allowed under Section 502(b)(10) of the Clean Air Act as provided in COMAR 26.11.03.18 and in accordance with the following conditions:

- a. The Permittee may make a change to this facility without obtaining a revision to this Part 70 permit if:
 - (1) The change is not a Title I modification;
 - (2) The change does not result in emissions in excess of those expressly allowed under the federally enforceable provisions of the Part 70 permit for the permitted facility or for an emissions unit within the facility, whether expressed as a rate of emissions or in terms of total emissions;
 - (3) The Permittee has obtained all permits and approvals required by COMAR 26.11.02 and .03;
 - (4) The change does not violate an applicable requirement of the Clean Air Act;
 - (5) The change does not violate a federally enforceable permit term or condition related to monitoring, including test methods, record keeping, reporting, or compliance certification requirements;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- (6) The change does not violate a federally enforceable permit term or condition limiting hours of operation, work practices, fuel usage, raw material usage, or production levels if the term or condition has been established to limit emissions allowable under this permit;
 - (7) If applicable, the change does not modify a federally enforceable provision of a compliance plan or schedule in this Part 70 permit unless the Department has approved the change in writing; and
 - (8) This permit does not expressly prohibit the change under COMAR 26.11.03.18.
- b. The Permittee shall notify the Department and the EPA in writing of a proposed on-permit change under COMAR 26.11.03.18 not later than 7 days before the change is made. The written information shall include the following information:
- (1) A description of the proposed change;
 - (2) The date on which the change is proposed to be made;
 - (3) Any change in emissions resulting from the change, including the pollutants emitted;
 - (4) Any new applicable requirement of the Clean Air Act; and
 - (5) Any permit term or condition that would no longer apply.
- c. The responsible official of this facility shall certify in accordance with COMAR 26.11.02.02F that the proposed change meets the criteria for the use of on-permit changes under COMAR 26.11.03.18.
- d. The Permittee shall attach a copy of each notice required by condition b. above to this Part 70 permit.
- e. On-permit changes that qualify under COMAR 26.11.03.18 are not subject to the requirements for part 70 permit revisions.
- f. Upon satisfying the requirements under COMAR 26.11.03.18, the Permittee may make the proposed change.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- g. The permit shield in COMAR 26.11.03.23 does not apply to on-permit changes under COMAR 26.11.03.18.
- h. The Permittee is subject to enforcement action if it is determined that an on-permit change made under COMAR 26.11.03.18 is not within the scope of the regulation or violates any requirement of the State air pollution control law.

17. FEE PAYMENT

[COMAR 26.11.02.16A(2) & (5)(b)]

- a. The fee for this Part 70 permit is as prescribed in Regulation .19 of COMAR 26.11.02.
- b. The fee is due on and shall be paid on or before each 12-month anniversary date of the permit.
- c. Failure to pay the annual permit fee constitutes cause for revocation of the permit by the Department.

18. REQUIREMENTS FOR PERMITS-TO-CONSTRUCT AND APPROVALS

[COMAR 26.11.02.09.]

The Permittee may not construct or modify or cause to be constructed or modified any of the following sources without first obtaining, and having in current effect, the specified permits-to-construct and approvals:

- a. New Source Review source, as defined in COMAR 26.11.01.01, approval required, except for generating stations constructed by electric companies;
- b. Prevention of Significant Deterioration source, as defined in COMAR 26.11.01.01, approval required, except for generating stations constructed by electric companies;
- c. New Source Performance Standard source, as defined in COMAR 26.11.01.01, permit to construct required, except for generating stations constructed by electric companies;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- d. National Emission Standards for Hazardous Air Pollutants source, as defined in COMAR 26.11.01.01, permit to construct required, except for generating stations constructed by electric companies;
- e. A stationary source of lead that discharges one ton per year or more of lead or lead compounds measured as elemental lead, permit to construct required, except for generating stations constructed by electric companies;
- f. All stationary sources of air pollution, including installations and air pollution control equipment, except as listed in COMAR 26.11.02.10, permit to construct required;
- g. In the event of a conflict between the applicability of (a.— e.) above and an exemption listed in COMAR 26.11.02.10, the provision that requires a permit applies.
- h. Approval of a PSD or NSR source by the Department does not relieve the Permittee obtaining an approval from also obtaining all permits-to-construct required b y (c.— g.) above.

19. CONSOLIDATION OF PROCEDURES FOR PUBLIC PARTICIPATION

[COMAR 26.11.02.11C] and [COMAR 26.11.03.01K]

The Permittee may request the Department to authorize special procedures for the Permittee to apply simultaneously, to the extent possible, for a permit to construct and a revision to this permit.

These procedures may provide for combined public notices, informational meetings, and public hearings for both permits but shall not adversely affect the rights of a person, including EPA and affected states, to obtain information about the application for a permit, to comment on an application, or to challenge a permit that is issued.

These procedures shall not alter any existing permit procedures or time frames.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

20. PROPERTY RIGHTS

[COMAR 26.11.03.06E(4)]

This Part 70 permit does not convey any property rights of any sort, or any exclusive privileges.

21. SEVERABILITY

[COMAR 26.11.03.06A(5)]

If any portion of this Part 70 permit is challenged, or any term or condition deemed unenforceable, the remainder of the requirements of the permit continues to be valid.

22. INSPECTION AND ENTRY

[COMAR 26.11.03.06G(3)]

The Permittee shall allow employees and authorized representatives of the Department, the EPA, and local environmental health agencies, upon presentation of credentials or other documents as may be required by law, to:

- a. Enter at a reasonable time without delay and without prior notification the Permittee's property where a Part 70 source is located, emissions-related activity is conducted, or records required by this permit are kept;
- b. Have access to and make copies of records required by the permit;
- c. Inspect all emissions units within the facility subject to the permit and all related monitoring systems, air pollution control equipment, and practices or operations regulated or required by the permit; and
- d. Sample or monitor any substances or parameters at or related to the emissions units at the facility for the purpose of determining compliance with the permit.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

23. DUTY TO PROVIDE INFORMATION

[COMAR 26.11.03.06E(5)]

The Permittee shall furnish to the Department, within a reasonable time specified by the Department, information requested in writing by the Department in order to determine whether the Permittee is in compliance with the federally enforceable conditions of this Part 70 permit, or whether cause exists for revising or revoking the permit. Upon request, the Permittee shall also furnish to the Department records required to be kept under the permit.

For information claimed by the Permittee to be confidential and therefore potentially not discloseable to the public, the Department may require the Permittee to provide a copy of the records directly to the EPA along with a claim of confidentiality.

The Permittee shall also furnish to the Department, within a reasonable time specified by the Department, information or records requested in writing by the Department in order to determine if the Permittee is in compliance with the State-only enforceable conditions of this permit.

24. COMPLIANCE REQUIREMENTS

[COMAR 26.11.03.06E(1)] and [COMAR 26.11.03.06A(11)] and [COMAR 26.11.02.05]

The Permittee shall comply with the conditions of this Part 70 permit. Noncompliance with the permit constitutes a violation of the Clean Air Act, and/or the Environment Article Title 2 of the Annotated Code of Maryland and may subject the Permittee to:

- a. Enforcement action,
- b. Permit revocation or revision,
- c. Denial of the renewal of a Part 70 permit, or
- d. Any combination of these actions.

The conditions in this Part 70 permit are enforceable by EPA and citizens under the Clean Air Act except for the State-only enforceable conditions.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Under Environment Article Section 2-609, Annotated Code of Maryland, the Department may seek immediate injunctive relief against a person who violates this permit in such a manner as to cause a threat to human health or the environment.

25. CREDIBLE EVIDENCE

Nothing in this permit shall be interpreted to preclude the use of credible evidence to demonstrate noncompliance with any term of this permit.

26. NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE

[COMAR 26.11.03.06E(2)]

The need to halt or reduce activity in order to comply with the conditions of this permit may not be used as a defense in an enforcement action.

27. CIRCUMVENTION

[COMAR 26.11.01.06]

The Permittee may not install or use any article, machine, equipment or other contrivance, the use of which, without resulting in a reduction in the total weight of emissions, conceals or dilutes emissions which would otherwise constitute a violation of any applicable air pollution control regulation.

28. PERMIT SHIELD

[COMAR 26.11.03.23]

A permit shield as described in COMAR 26.11.03.23 shall apply only to terms and conditions in this Part 70 permit that have been specifically identified as covered by the permit shield. Neither this permit nor COMAR 26.11.03.23 alters the following:

- a. The emergency order provisions in Section 303 of the Clean Air Act, including the authority of EPA under that section;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- b. The liability of the Permittee for a violation of an applicable requirement of the Clean Air Act before or when this permit is issued or for a violation that continues after issuance;
- c. The requirements of the Acid Rain Program, consistent with Section 408(a) of the Clean Air Act;
- d. The ability of the Department or EPA to obtain information from a source pursuant to Maryland law and Section 114 of the Clean Air Act; or
- e. The authority of the Department to enforce an applicable requirement of the State air pollution control law that is not an applicable requirement of the Clean Air Act.

29. ALTERNATE OPERATING SCENARIOS

[COMAR 26.11.03.06A(9)]

For all alternate operating scenarios approved by the Department and contained within this permit, the Permittee, while changing from one approved scenario to another, shall contemporaneously record in a log maintained at the facility each scenario under which the emissions unit is operating and the date and time the scenario started and ended.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

SECTION III PLANT WIDE CONDITIONS

1. PARTICULATE MATTER FROM CONSTRUCTION AND DEMOLITION

[COMAR 26.11.06.03D]

The Permittee shall not cause or permit any building, its appurtenances, or a road to be used, constructed, altered, repaired, or demolished without taking reasonable precautions to prevent particulate matter from becoming airborne.

2. OPEN BURNING

[COMAR 26.11.07]

Except as provided in COMAR 26.11.07.04, the Permittee shall not cause or permit an open fire from June 1 through August 31 of any calendar year. Prior to any open burning, the Permittee shall request and receive approval from the Department.

3. AIR POLLUTION EPISODE

[COMAR 26.11.05.04]

When requested by the Department, the Permittee shall prepare in writing standby emissions reduction plans, consistent with good industrial practice and safe operating procedures, for reducing emissions creating air pollution during periods of Alert, Warning, and Emergency of an air pollution episode.

4. REPORT OF EXCESS EMISSIONS AND DEVIATIONS

[COMAR 26.11.01.07] and [COMAR 26.11.03.06C(7)]

The Permittee shall comply with the following conditions for occurrences of excess emissions and deviations from requirements of this permit, including those in Section VI – State-only Enforceable Conditions:

- a. Report any deviation from permit requirements that could endanger human health or the environment, by orally notifying the Department immediately upon discovery of the deviation;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- b. Promptly report all occurrences of excess emissions that are expected to last for one hour or longer by orally notifying the Department of the onset and termination of the occurrence;
- c. When requested by the Department the Permittee shall report all deviations from permit conditions, including those attributed to malfunctions as defined in COMAR 26.11.01.07A, within 5 days of the request by submitting a written description of the deviation to the Department. The written report shall include the cause, dates and times of the onset and termination of the deviation, and an account of all actions planned or taken to reduce, eliminate, and prevent recurrence of the deviation;
- d. The Permittee shall submit to the Department semi-annual monitoring reports that confirm that all required monitoring was performed, and that provide accounts of all deviations from permit requirements that occurred during the reporting periods. Reporting periods shall be January 1 through June 30 and July 1 through December 31, and reports shall be submitted within 30 days of the end of each reporting period. Each account of deviation shall include a description of the deviation, the dates and times of onset and termination, identification of the person who observed or discovered the deviation, causes and corrective actions taken, and actions taken to prevent recurrence. If no deviations from permit conditions occurred during a reporting period, the Permittee shall submit a written report that so states.
- e. When requested by the Department, the Permittee shall submit a written report to the Department within 10 days of receiving the request concerning an occurrence of excess emissions. The report shall contain the information required in COMAR 26.11.01.07D(2).

5. ACCIDENTAL RELEASE PROVISIONS

[COMAR 26.11.03.03B(23)] and [40 CFR 68]

Should the Permittee become subject to 40 CFR 68 during the term of this permit, the Permittee shall submit risk management plans by the date specified in 40 CFR 68.150 and shall certify compliance with the requirements of 40 CFR 68 as part of the annual compliance certification as required by 40 CFR 70.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

The Permittee shall initiate a permit revision or reopening according to the procedures of 40 CFR 70.7 to incorporate appropriate permit conditions into the Permittee's Part 70 permit.

6. GENERAL TESTING REQUIREMENTS

[COMAR 26.11.01.04]

The Department may require the Permittee to conduct, or have conducted, testing to determine compliance with this Part 70 permit. The Department, at its option, may witness or conduct these tests. This testing shall be done at a reasonable time, and all information gathered during a testing operation shall be provided to the Department.

7. EMISSIONS TEST METHODS

[COMAR 26.11.01.04]

Compliance with the emissions standards and limitations in this Part 70 permit shall be determined by the test methods designated and described below or other test methods submitted to and approved by the Department.

Reference documents of the test methods approved by the Department include the following:

- a. 40 CFR 60, appendix A
- b. 40 CFR 51, appendix M
- c. The Department's Technical Memorandum 91-01 "Test Methods and Equipment Specifications for Stationary Sources", (January 1991), as amended through Supplement 3, (October 1, 1997)

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

8. EMISSIONS CERTIFICATION REPORT

**[COMAR 26.11.01.05-1] and [COMAR 26.11.02.19C] and
[COMAR 26.11.02.19D]**

The Permittee shall certify actual annual emissions of regulated pollutants from the facility on a calendar year basis.

- a. The certification shall be on forms obtained from the Department and submitted to the Department not later than April 1 of the year following the year for which the certification is required;
- b. The individual making the certification shall certify that the information is accurate to the individual's best knowledge. The individual shall be:
 - (1) Familiar with each source for which the certifications forms are submitted, and
 - (2) Responsible for the accuracy of the emissions information;
- c. The Permittee shall maintain records necessary to support the emissions certification including the following information if applicable:
 - (1) The total amount of actual emissions of each regulated pollutant and the total of all regulated pollutants;
 - (2) An explanation of the methods used to quantify the emissions and the operating schedules and production data that were used to determine emissions, including significant assumptions made;
 - (3) Amounts, types and analyses of all fuels used;
 - (4) Emissions data from continuous emissions monitors that are required by this permit, including monitor calibration and malfunction information;
 - (5) Identification, description, and use records of all air pollution control equipment and compliance monitoring equipment including:
 - (a) Significant maintenance performed,

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- (b) Malfunctions and downtime, and
 - (c) Episodes of reduced efficiency of all equipment;
- (6) Limitations on source operation or any work practice standards that significantly affect emissions; and
- (7) Other relevant information as required by the Department.

9. COMPLIANCE CERTIFICATION REPORT

[COMAR 26.11.03.06G(6) and (7)]

The Permittee shall submit to the Department and EPA Region III a report certifying compliance with each term of this Part 70 permit including each applicable standard, emissions limitation, and work practice for the previous calendar year by April 1 of each year.

- a. The compliance certification shall include:
- (1) The identification of each term or condition of this permit which is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether the compliance was continuous or intermittent;
 - (4) The methods used for determining the compliance status of each source, currently and over the reporting period; and
 - (5) Any other information required to be reported to the Department that is necessary to determine the compliance status of the Permittee with this permit.
- b. The Permittee shall submit the compliance certification reports to the Department and EPA simultaneously.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

10. CERTIFICATION BY RESPONSIBLE OFFICIAL

[COMAR 26.11.02.02F]

All application forms, reports, and compliance certifications submitted pursuant to this permit shall be certified by a responsible official as to truth, accuracy, and completeness. The Permittee shall expeditiously notify the Department of an appointment of a new responsible official.

The certification shall be in the following form:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

11. SAMPLING AND EMISSIONS TESTING RECORD KEEPING

[COMAR 26.11.03.06C(5)]

The Permittee shall gather and retain the following information when sampling and testing for compliance demonstrations:

- a. The location as specified in this permit, and the date and time that samples and measurements are taken;
- b. All pertinent operating conditions existing at the time that samples and measurements are taken;
- c. The date that each analysis of a sample or emissions test is performed and the name of the person taking the sample or performing the emissions test;
- d. The identity of the Permittee, individual, or other entity that performed the analysis;
- e. The analytical techniques and methods used; and

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- f. The results of each analysis.

12. GENERAL RECORDKEEPING

[COMAR 26.11.03.06C(6)]

The Permittee shall retain records of all monitoring data and information that support the compliance certification for a period of five (5) years from the date that the monitoring, sample measurement, application, report or emissions test was completed or submitted to the Department.

These records and support information shall include:

- a. All calibration and maintenance records;
- b. All original data collected from continuous monitoring instrumentation;
- c. Records which support the annual emissions certification; and
- d. Copies of all reports required by this permit.

13. GENERAL CONFORMITY

[COMAR 26.11.26.09]

The Permittee shall comply with the general conformity requirements of 40 CFR 93, Subpart B and COMAR 26.11.26.09.

14. ASBESTOS PROVISIONS

[40 CFR 61, Subpart M]

The Permittee shall comply with 40 CFR 61, Subpart M when conducting any renovation or demolition activities at the facility.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

15. OZONE DEPLETING REGULATIONS

[40 CFR 82, Subpart F]

The Permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR 82, Subpart F, except as provided for MVACs in subpart B:

- a. Persons opening appliances for maintenance, service, repair, or disposal shall comply with the prohibitions and required practices pursuant to 40 CFR 82.154 and 82.156.
- b. Equipment used during the maintenance, service, repair or disposal of appliances shall comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- c. Persons performing maintenance, service, repairs or disposal of appliances shall be certified by an approved technician certification program pursuant to 40 CFR 82.161.
- d. Persons disposing of small appliances, MVACS, and MVAC-like appliances as defined in 40 CFR 82.152, shall comply with record keeping requirements pursuant to 40 CFR 82.155.
- e. Persons owning commercial or industrial process refrigeration equipment shall comply with the leak repair requirements pursuant to 40 CFR 82.156.
- f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant shall keep records of refrigerant purchased and added to such appliances pursuant to 40 CFR 82.166.

16. ACID RAIN PERMIT

The renewal Phase II Acid Rain Permit is attached as Appendix A. The Permittee shall comply with all applicable requirements contained in the Phase II Acid Rain Permit. The PY-Units 1, 2, 3 & 4 are not subject to the Acid Rain requirements.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

SECTION IV PLANT SPECIFIC CONDITIONS

This section provides tables that include the emissions standards, emissions limitations, and work practices applicable to each emissions unit located at this facility. The Permittee shall comply with all applicable emissions standards, emissions limitations and work practices included herein.

The tables also include testing, monitoring, record keeping and reporting requirements specific to each emissions unit. In addition to the requirements included here in **Section IV**, the Permittee is also subject to the general testing, monitoring, record keeping and reporting requirements included in **Section III – Plant Wide Conditions** of this permit.

Unless otherwise provided in the specific requirements for an emissions unit, the Permittee shall maintain at the facility for at least five (5) years, and shall make available to the Department upon request, all records that the Permittee is required under this section to establish. **[Reference: COMAR 26.11.03.06C(5)(g)]**

Table IV – 1	
1.0	<p><u>Emissions Unit Number(s): Combustion Turbines</u></p> <p>PY-Unit1, PY-Unit2, PY-Unit3, PY-Unit4 Four (4) Westinghouse model 501 simple cycle combustion turbines, each with a design heat input of 704 mm Btu/hr, rated at a nominal 51 megawatt output and capable of only burning No.2 distillate oil. [12-4-0081 thru 12-4-0084]</p>
1.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05 - Visible Emissions. “A. Fuel Burning Equipment. (2) Areas III and IV. In Areas III and IV, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is visible to human observers except that, for the purpose of demonstrating compliance using COM data, emissions that are visible to a human observer are those that are equal to or greater than 10 percent opacity. (3) Exceptions. Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, startup, or adjustments or occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40 percent opacity; and (b) The visible emissions do not occur for more than 6 consecutive minutes</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
 PERRYMAN GENERATING STATION
 900 CHELSEA ROAD, PERRYMAN, MD 21130
 PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 1

in any sixty minute period.”

B. Control of Sulfur Oxides

COMAR 26.11.09.07: Control of Sulfur Oxides From Fuel Burning Equipment.

“A. Sulfur Content Limitations for Fuel. A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations:

(2) In Areas III and IV:

(a) *Not Applicable*;

(b) **Distillate fuel oils, 0.3 percent**;

(c) *Not Applicable.*”

Cross-State Air Pollution Rule

See Table IV-7: CSAPR for requirements.

C. Control of Nitrogen Oxides:

COMAR 26.11.09.08G - Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.

“(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall:

(a) Provide certification of the capacity factor of the equipment to the Department in writing;

(b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually;

(c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request;

(d) *Not applicable*

(e) *Not applicable*

(2) A person who owns or operates a combustion turbine with a capacity factor greater than 15 percent shall meet an hourly average NO_x emission rate of not more than 42 ppm when burning gas or 65 ppm when burning fuel oil (dry volume at 15 percent oxygen) or meet applicable Prevention of Significant Deterioration limits, whichever is more restrictive. “

Cross-State Air Pollution Rule

See Table IV-7: CSAPR for requirements.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 1	
1.2	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Monitoring Requirement.</p> <p>B. <u>Control of Sulfur Oxides</u> See Monitoring Requirement.</p> <p>C. <u>Control of Nitrogen Oxides:</u> If the Permittee operates a turbine in excess of 15 percent capacity factor, the Permittee shall demonstrate compliance with the 65-ppm limit by performing an EPA Reference Method Test within 120 days after exceeding the 15 percent capacity factor. The Permittee shall submit a test protocol to the Department for approval at least 30 days prior to the proposed test date. [Reference: COMAR 26.11.03.06C]</p>
1.3	<p><u>Monitoring Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall:</p> <ul style="list-style-type: none"> (a) properly operate and maintain the combustion turbines in a manner to prevent visible emissions; (b) verify no visible emissions when burning #2 fuel oil. An observer shall perform an EPA Reference Method 9 observation of stack emissions for an 18-minute period once for each 168 hours a combustion turbine operates on No. 2 oil. <p>The Permittee shall perform the following if visible emissions are observed:</p> <ul style="list-style-type: none"> (a) inspect combustion turbine operations; (b) perform all necessary adjustments and/or repairs to the combustion turbine within 48 operating hours so that visible emissions are eliminated; (c) document in writing the results of the inspections, adjustments and/or repairs to the combustion turbine; and (d) if the required adjustments and/or repairs had not eliminated the visible emissions within the stipulated 48 operating hours, the Permittee shall perform a Method 9 observation once daily for 18 minutes until corrective action has eliminated the visible emissions. <p>[Reference: COMAR 26.11.03.06C]</p> <p>B. <u>Control of Sulfur Oxides</u> The Permittee shall obtain a certification from the fuel supplier indicating that the oil complies with the limitation on the sulfur content of the fuel oil or obtain sulfur in fuel analyses of oil that is representative of oil burned.</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 1	
	<p>[Reference: COMAR 26.11.03.06C]</p> <p><u>C. Control of Nitrogen Oxides:</u> The Permittee shall:</p> <ol style="list-style-type: none"> (1) Perform a combustion analysis and optimize combustion at least once annually when the turbines operate for more than 500 hours in a calendar year. [Reference: COMAR 26.11.09.08G(1)(b)]. (2) Calculate the capacity factor of each unit for each calendar year within 30 days after the end of each year. [Reference: COMAR 26.11.03.06C]
1.4	<p><u>Record Keeping Requirements:</u> Note: All records must be maintained for a period of at least 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p><u>A. Control of Visible Emissions</u> The Permittee shall maintain for at least five years the following:</p> <ol style="list-style-type: none"> (a) records of maintenance performed on the combustion turbines that relate to preventing visible emissions; and (b) log of visible emission observations performed. [Reference: COMAR 26.11.03.06C] <p><u>B. Control of Sulfur Oxides</u> The Permittee shall maintain for at least five years documents certifying the sulfur content of fuel oil received or copies of the sulfur in fuel analyses. [Reference: COMAR 26.11.03.06C]</p> <p><u>C. Control of Nitrogen Oxides:</u> The Permittee shall:</p> <ol style="list-style-type: none"> (1) Maintain the results of the combustion analysis and any stack tests for at least 5 years and make these results available to the Department and the EPA upon request. [Reference: COMAR 26.11.09.08G(1)(c) and COMAR 26.11.03.06C]. (2) Maintain a record of the calculated capacity factors. [Reference: COMAR 26.11.03.06C].
1.5	<p><u>Reporting Requirements:</u></p> <p><u>A. Control of Visible Emissions</u> The Permittee shall report incidents of excess emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations” [Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 1	
	<p>B. <u>Control of Sulfur Oxides</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations” [Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]</p> <p>C. <u>Control of Nitrogen Oxides:</u> The Permittee shall:</p> <ol style="list-style-type: none"> (1) Provide certification of the capacity factor of the equipment to the Department in writing as part of the annual Emissions Certification. [Reference: COMAR 26.11.09.08G(1)(a)] (2) Submit the results of any stack tests within 45 days after completion of the stack test. [Reference: COMAR 26.11.03.06C]

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV – 2	
2.0	<p><u>Emissions Unit Number(s): Combustion Turbine</u></p> <p>PY-Unit51 General Electric Frame 7FA stationary, single-shaft combustion turbine operating in the simple cycle mode, rated at a nominal 150-megawatt output. This turbine has dual fuel (natural gas and No. 2 fuel oil) firing capacity. [12-5-0088]</p>
2.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05 - Visible Emissions. “A. <u>Fuel Burning Equipment.</u> (2) Areas III and IV. In Areas III and IV, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is visible to human observers except that, for the purpose of demonstrating compliance using COM data, emissions that are visible to a human observer are those that are equal to or greater than 10 percent opacity. (3) <u>Exceptions.</u> Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, startup, or adjustments or occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40 percent opacity; and (b) The visible emissions do not occur for more than 6 consecutive minutes</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 2

in any sixty minute period.”

B. Control of Sulfur Oxides

COMAR 26.11.09.07: Control of Sulfur Oxides From Fuel Burning Equipment.

“A. Sulfur Content Limitations for Fuel. A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations:

(2) In Areas III and IV:

(a) *Not Applicable*;

(b) **Distillate fuel oils, 0.3 percent**;

(c) *Not Applicable.*”

Subpart GG—Standards of Performance for Stationary Gas Turbines
40 CFR §60.333, which limits the sulfur content in No. 2 distillate fuel oil to 0.8%.

CPCN #8241, which states “The fuel oil burned in PY-Unit51 shall contain no more than 0.05% by weight. If this type of fuel is not available or is not priced competitively, fuel oil with a maximum sulfur content of 0.2 percent may be used. Fuel oil with a maximum of 0.05 percent sulfur is considered to be “priced competitively” if it costs (on a \$/MMBtu basis) no more than 10 percent more than No. 2 oil containing 0.2 percent sulfur.”

CPCN #8241 which limits sulfur oxides (as SO₂) emissions to 28 lb/hr when burning natural gas and 87 lb/hr when burning No. 2 oil.

CPCN #8241, which limits Sulfuric Acid Mist to 7.8 lb/hr when burning No. 2 oil.

CPCN#8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.

Note: Compliance with these limitations will be by use of fuel supplier certifications or sulfur in fuel analyses

Acid Rain Permit

The Permittee shall comply with the requirements of the Phase II Acid Rain Permit issued for this generating station. **Note:** A renewal Phase II Acid Rain Permit will be issued in conjunction with this Part 70 permit and is attached to the Part 70 permit as Appendix A.

Cross-State Air Pollution Rule

See Table IV-XX: CSAPR for requirements.

**CONSTELLATION POWER SOURCE GENERATION, LLC
 PERRYMAN GENERATING STATION
 900 CHELSEA ROAD, PERRYMAN, MD 21130
 PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 2

C. Control of Particulate Matter

CPCN #8241 which limits particulate emissions (TSP and PM₁₀ emissions each) to 10 lb/hr when burning natural gas and 11 lb/hr when burning No. 2 oil.

CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.

D. Control of Nitrogen Oxides

COMAR 26.11.09.08G - Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.

“(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall:

- (a) Provide certification of the capacity factor of the equipment to the Department in writing;
- (b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually;
- (c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request;
- (d) *Not applicable.*
- (e) *Not applicable.*

(2) A person who owns or operates a combustion turbine with a capacity factor greater than 15 percent shall meet an hourly average NO_x emission rate of not more than 42 ppm when burning gas or 65 ppm when burning fuel oil (dry volume at 15 percent oxygen) or meet applicable Prevention of Significant Deterioration limits, whichever is more restrictive. “

Note: Compliance with the CPCN will be used to demonstrate compliance with NSPS (40 CFR part 60) and NO_x RACT requirements.

Subpart GG—Standards of Performance for Stationary Gas Turbines

40 CFR §60.332, which limits NO_x emissions in accordance with the equation contained in 40 CFR §60.332 (a) (1).

CPCN #8241 which limits NO_x emissions to 170 lb/hr when burning natural gas and 490 lb/hr when burning No. 2 oil.

CPCN #8241 which limits NO_x emissions to 25 parts per million by volume on a dry basis (ppmvd) at 15% excess oxygen on an hourly basis when burning natural gas and 65 ppmvd at 15% oxygen on an hourly basis when burning No. 2 oil.

CPCN #8241, which limits NO_x emissions to 1,363 tons in any consecutive

**CONSTELLATION POWER SOURCE GENERATION, LLC
 PERRYMAN GENERATING STATION
 900 CHELSEA ROAD, PERRYMAN, MD 21130
 PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 2	
	<p>12-month period. CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.</p> <p>Cross-State Air Pollution Rule See Table IV-7: CSAPR for requirements.</p> <p>E. <u>Control of VOC</u> CPCN #8241 which limits VOC emissions to 2.9 lb/hr when burning natural gas and 7 lb/hr when burning No. 2 oil. CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.</p> <p>F. <u>Control of Carbon Monoxide</u> CPCN # 8241 which limits CO emissions to 52 lb/hr when burning natural gas and 70 lb/hr when burning No. 2 oil. CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.</p>
2.2	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Monitoring Requirement.</p> <p>B. <u>Control of Sulfur Oxides</u> See Monitoring Requirement.</p> <p>C. <u>Control of Particulate Matter</u> See Monitoring Requirements</p> <p>D. <u>Control of Nitrogen Oxides</u> See Monitoring Requirements</p> <p>E. <u>Control of VOC</u> See Monitoring Requirements</p> <p>F. <u>Control of Carbon Monoxide</u> See Monitoring Requirements</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 2

2.3 Monitoring Requirements:

A. Control of Visible Emissions

The Permittee shall:

- (a) properly operate and maintain the combustion turbine;
- (b) verify no visible emissions when burning No.2 fuel oil. An observer shall perform an EPA Reference Method 9 observation of stack emissions for an 18-minute period once for each 168 hours the combustion turbine burns No. 2 fuel oil, or perform such an observation no less than once a calendar year if No 2 fuel oil is burned during the year.

The Permittee shall perform the following if visible emissions are observed:

- (a) inspect combustion turbine operations;
- (b) perform all necessary adjustments and/or repairs to the combustion turbine within 48 operating hours so that visible emissions are eliminated;
- (c) document in writing the results of the inspections, adjustments and/or repairs to the combustion turbine; and
- (d) if the required adjustments and/or repairs had not eliminated the visible emissions within the stipulated 48 operating hours, the Permittee shall perform a Method 9 observation once daily for 18 minutes until corrective action has eliminated the visible emissions.

[Reference: COMAR 26.11.03.06C]

B. Control of Sulfur Oxides

The Permittee shall obtain a certification from the fuel supplier indicating that the oil complies with the limitation on the sulfur content of the fuel oil or obtain sulfur in fuel analyses of oil that is representative of oil burned.

[Reference: COMAR 26.11.03.06C].

Acid Rain Permit:

The Permittee shall comply with the monitoring requirements in 40 CFR Part 75 including the QC/QA procedures in Part 75 Appendix B. See Acid Rain Permit in Appendix A of this permit.

C. Control of Particulate Matter

The Permittee shall perform preventative maintenance to maintain the turbine as designed. **[Reference: COMAR 26.11.03.06C]**

D. Control of Nitrogen Oxides

The Permittee shall:

- (1) Operate, calibrate, and maintain a certified NO_x CEM system

[Reference: CPCN 8241 and COMAR 26.11.29.08A].

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 2	
	<p>(2) Certify the NO_x CEM system in accordance with Part 75, Appendix A. [Reference: 40 CFR §75.70, COMAR 26.11.09.08B(2)(b), and COMAR 26.11.29.08B].</p> <p>E. <u>Control of VOC</u> The Permittee shall perform preventative maintenance to maintain the turbine as designed. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of Carbon Monoxide</u> The Permittee shall perform preventative maintenance to maintain the turbine as designed. [Reference: COMAR 26.11.03.06C]</p>
2.4	<p><u>Record Keeping Requirements:</u> Note: All records must be maintained for a period of at least 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall: (1) Maintain for at least five years records of maintenance performed on the combustion turbine that relate to preventing visible emissions. (2) Maintain for at least five years a log of visible emission observations performed. [Reference: COMAR 26.11.03.06C]</p> <p>B. <u>Control of Sulfur Oxides</u> The Permittee shall (1) Maintain for at least five years documents certifying the sulfur content of fuel oil received or copies of the sulfur in fuel analyses. (2) Maintain for at least five years records of the number of hours, in any consecutive 12-month period, that fuel oil is used. [Reference: COMAR 26.11.03.06C]</p> <p><u>Acid Rain Permit:</u> The Acid Rain Permit contains specific recordkeeping requirements. See Acid Rain Permit in Appendix A of this permit. [Reference: 40 CFR Part 75, Subpart F]</p> <p>C. <u>Control of Particulate Matter</u> The Permittee shall maintain records of the preventive maintenance that relates to combustion performance for 5 years. [Reference: COMAR 26.11.03.06C]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 2	
	<p>D. <u>Control of Nitrogen Oxides</u> The Permittee shall maintain records necessary to prepare a quarterly emission reports that contain the requirements of COMAR 26.11.01.11E(2). [Reference: COMAR 26.11.03.06C]</p> <p>E. <u>Control of VOC</u> The Permittee shall maintain records of the preventive maintenance that relates to combustion performance for 5 years. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of Carbon Monoxide</u> The Permittee shall maintain records of the preventive maintenance that relates to combustion performance for 5 years. [Reference: COMAR 26.11.03.06C]</p>
2.5	<p><u>Reporting Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations” [Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]</p> <p>B. <u>Control of Sulfur Oxides</u> The Permittee shall report fuel supplier certifications or fuel analyses to the Department upon request. [Reference: COMAR 26.11.09.07C]</p> <p><u>Acid Rain Permit:</u> The Acid Rain Permit contains specific reporting requirements. See Acid Rain Permit in Appendix A of this permit. [Reference: 40 CFR Part 75, Subpart G]</p> <p>C. <u>Control of Particulate Matter</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p> <p>D. <u>Control of Nitrogen Oxides</u> The Permittee shall submit a quarterly summary report to the Department not later than 30 days following each calendar quarter. The report shall be in a format approved by the Department, and shall include the following: (1) The cause, time periods, and magnitude of all emissions which exceed the applicable emission standards; (2) The source downtime including the time and date of the beginning and end of each downtime period and whether the source downtime was</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 2	
	<p>planned or unplanned; (3) The time periods and cause of all CEM downtime including records of any repairs, adjustments, or maintenance that may affect the validity of emission data; (4) Quarterly totals of excess emissions, installation downtime, and CEM downtime during the calendar quarter; (5) Quarterly quality assurance activities; and (6) Daily calibration activities that include reference values, actual values, absolute or percent of span differences, and drift status; and (7) Other information required by the Department that is determined to be necessary to evaluate the data, to ensure that compliance is achieved, or to determine the applicability of this regulation. [Reference: COMAR 26.11.09.08K(1) and COMAR 26.11.01.11E(2)]</p> <p><u>E. Control of VOC</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p> <p><u>F. Control of Carbon Monoxide</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p>

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV – 3	
3.0	<p><u>Emissions Unit Number(s): Combustion Turbines (Project 6)</u></p> <p>CT6A & CT6B One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted. [025-0024-5-0353 & 5-0354]</p>
3.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05 - Visible Emissions.</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

A. Fuel Burning Equipment.

(2) Areas III and IV. In Areas III and IV, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is visible to human observers except that, for the purpose of demonstrating compliance using COM data, emissions that are visible to a human observer are those that are equal to or greater than 10 percent opacity.

(3) Exceptions. Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, startup, or adjustments or occasional cleaning of control equipment if:

- (a) The visible emissions are not greater than 40 percent opacity; and
- (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period.”

B. Control of Sulfur Oxides

COMAR 26.11.09.07: Control of Sulfur Oxides From Fuel Burning Equipment.

“A. Sulfur Content Limitations for Fuel. A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: (2) In Areas III and IV:
(b) Distillate fuel oils, 0.3 percent;

Subpart KKKK—Standards of Performance for Stationary Combustion Turbines

§60.4330 - What emission limits must I meet for sulfur dioxide (SO₂)?

“(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO₂ in excess of **110 nanograms per Joule (ng/J) (0.90 pounds per megawatt-hour (lb/MWh))** gross output;

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of **26 ng SO₂/J (0.060 lb SO₂/MMBtu)** heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement;”

CPCN#9136, which states, “Fuel type Limit: The only permissible fuels for the combustion turbines are pipeline quality natural gas and ultra-low sulfur diesel (ULSD). ULSD may only be used during periods of interruption of the natural gas supply. **[Reference: CPCN Case No. 9136, Condition B-IV-1]**

Acid Rain Permit

The Permittee shall comply with the requirements of the Phase II Acid Rain Permit issued for this generating station. Note: A renewal Phase II Acid Rain Permit will be issued in conjunction with this Part 70 permit and is

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

attached to the Part 70 permit as Appendix A.

Cross-State Air Pollution Rule

See Table IV-7: CSAPR for requirements.

C. Control of Particulate Matter

COMAR 26.11.06.03B(2)(a) - Particulate Matter from Confined Sources.

“A person may not cause or permit to be discharged into the outdoor atmosphere from any other installation, particulate matter in excess of 0.03 gr/SCFD (68.7 mg/dscm).”

CPCN#9136 states PM₁₀ and PM_{2.5} (filterable and condensable), when burning NG emissions from the two (2) combustion turbines shall not exceed the following emission limits: 5.0 lb/hr (0.0079 lb/MMBtu High heat value (HHV) at all times, averaged over 3 stack test runs.

[Reference: CPCN Case No. 9136, Condition B-IV-4: BACT/LAER]

CPCN#9136 states PM₁₀ and PM_{2.5} (filterable and condensable), when burning ULSD emissions from the two (2) combustion turbines shall not exceed the following emission limits: 15.0 lb/hr (0.0248 lb/MMBtu High heat value (HHV) at all times, averaged over 3 stack test runs.

[Reference: CPCN Case No. 9136, Condition B-IV-4: BACT/LAER]

D. Control of Nitrogen Oxides

COMAR 26.11.09.08G - Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.

“(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall:

(a) Provide certification of the capacity factor of the equipment to the Department in writing;

(b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually;

(c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request;

(d) *Not Applicable.*

(e) *Not Applicable.*

(2) A person who owns or operates a combustion turbine with a capacity factor greater than 15 percent shall meet an hourly average NO_x emission rate of not more than **42 ppm when burning gas or 65 ppm when burning fuel oil (dry volume at 15 percent oxygen)** or meet applicable

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

Prevention of Significant Deterioration limits, whichever is more restrictive. “

Subpart KKKK—Standards of Performance for Stationary Combustion Turbines

40 CFR §60.4320, which states that NO_x emissions standard (**when burning NG**) shall not exceed 25 ppm at 15% O₂ or 150 ng/J (1.2 lb/MWh) of useful output at all times greater than or equal to 75 percent of peak load or greater than or equal to 0°F, average 4-hr rolling.

40 CFR §60.4320, which states that NO_x emissions standard (**when burning ULSD**) shall not exceed 74 ppm at 15% O₂ or 460 ng/J (3.6 lb/MWh) of useful output, average 4-hr rolling.

CPCN#9136 which states the NO_x (when burning NG) shall not exceed 2.5 ppm at 15% O₂ (5.8 lb/hr) at all times, excluding during startup events and shutdown events, averaged over 3-hr block. **[LAER]**

CPCN#9136 which states the NO_x (when burning NG or ULSD) shall not exceed 36.4 lb/startup event (1 CT or 2 CTs) and 9.27 lb/shutdown event (1 CT or 2 CTs). **[LAER]**

CPCN#9136 which states the NO_x (when burning ULSD) shall not exceed 5 ppm at 15% O₂ (11.7 lb/hr) at all times, excluding during startup events and shutdown events, averaged over 3-hr block. **[LAER]**

CPCN#9136 which states the NO_x (when burning either NG or ULSD) shall not exceed 96 ppm at 15% O₂ or 150 ng/J (1.2 lb/MWh) of useful output at all times greater than or equal to 75 percent of peak load or greater than or equal to 0°F, averaged over 4-hr rolling average [NSPS KKKK 40 CFR §60.4320, §60.4325]. **[LAER]**

CPCN#9136 states A “*Startup Event*” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a startup event is defined as the period of time during which one CTs output is increased with the intent to startup, beginning with initiation of fuel combustion in one CT and ending when the SCR system catalyst reaches 600 degrees Fahrenheit. In the case of 2 CTs, the startup event begins at the point at which 1 CT initiates combustion and ends when the SCR system catalyst reaches 600F.

[Reference: CPCN Case No. 9136, Condition B-II-5]

CPCN#9136 states A “*Shutdown Event*” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a shutdown event is defined as the period of time during which one CTs output is lowered with the intent to shutdown, beginning at the point at which the load drops below 50% and ending when fuel combustion ceases. In the case a shutdown event of 2 CTs occurs, a shutdown event begins at the point at which the first CT drops below 50% and ends when fuel combustion for both CTs ceases. Notwithstanding the foregoing, if 2 CTs are in operation and 1 CT’s load is lowered below 50% with the intent to shutdown while the other CT

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

continues in normal operation during and beyond the point fuel combustion ceases from the first Ct that shall not constitute a “Shutdown Event.”
[Reference: CPCN Case No. 9136, Condition B-II-4]

Cross-State Air Pollution Rule
See Table IV-7: CSAPR for requirements.

E. Control of GHG Emissions

CPCN#9136 which states the emissions from the two (2) combustion turbines shall not exceed the following emission limits:
GHG (when burning NG) shall not exceed 1,394 lb CO_{2e}/MWh gross at all times excluding startup events and shutdown events, over a 12-month rolling averaging period.

GHG (when burning ULSD) shall not exceed 1,741 lb CO_{2e}/MWh gross at all times excluding startup events and shutdown events, over a 12-month rolling averaging period. **[Reference: CPCN Case No. 9136, Condition B-IV-4]**

NSPS Subpart TTTT - Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units

§60.5520 - What CO₂ emissions standard must I meet?

(a) For each affected EGU subject to this subpart, you must not discharge from the affected EGU any gases that contain CO₂ in excess of the applicable CO₂ emission standard specified in **table 1** or **2** of this subpart, consistent with paragraphs (b), (c), and (d) of this section, as applicable.

Table 2 of Subpart TTTT of Part 60—CO₂ Emission Standards for Affected Stationary Combustion Turbines That Commenced Construction After January 8, 2014 and Reconstruction After June 18, 2014 (Net Energy Output-Based Standards Applicable as Approved by the Administrator)

[Note: Numerical values of 1,000 or greater have a minimum of 3 significant figures and numerical values of less than 1,000 have a minimum of 2 significant figures]

Affected EGU	CO ₂ Emission standard
Newly constructed or reconstructed stationary combustion turbine that supplies its design efficiency or 50 percent, whichever is less, times its potential electric output or less as net-electric sales on either a 12-operating month or a 3-year rolling average basis and combusts more than 90% natural gas on a heat input basis on a 12-operating-month rolling average basis	50 kg CO ₂ per gigajoule (GJ) of heat input (120 lb CO ₂ /MMBtu).

(d) Stationary combustion turbines subject to a heat input-based standard in table 2 of this subpart that are only permitted to burn one or more uniform fuels, as described in paragraph (d)(1) of this section, are only subject to the

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

monitoring requirements in paragraph (d)(1). All other stationary combustion turbines subject to a heat input based standard in table 2 are subject to the requirements in paragraph (d)(2) of this section.

(1) Stationary combustion turbines that are only permitted to burn fuels with a consistent chemical composition (*i.e.*, uniform fuels) that result in a consistent emission rate of 160 lb CO₂/MMBtu or less are **not subject to any monitoring or reporting requirements under this subpart**. These fuels include, but are not limited to, natural gas, methane, butane, butylene, ethane, ethylene, propane, naphtha, propylene, jet fuel kerosene, No. 1 fuel oil, No. 2 fuel oil, and biodiesel. **Stationary combustion turbines qualifying under this paragraph are only required to maintain purchase records for permitted fuels.**

F. Control of Ammonia Emissions

CPCN#9136 which states the emissions from the two (2) combustion turbines shall not exceed the following emission limits:
Ammonia (when burning NG or ULSD) shall not exceed 5 ppmvd at 15% O₂ at all times, over an averaged period of 3 stack test runs. **[Reference: CPCN Case No. 9136, Condition B-IV-4]**

G. Operational Limit

CPCN#9136 which states the combustion turbines may not exceed the following operational restrictions:

- (a) The total number of hours of operation for the two (2) combustion turbines, inclusive of startup and shutdown, shall not exceed 10,512 hours in any consecutive rolling 12-month period.
- (b) The total number of hours burning fuel oil on the two (2) combustion turbines, exclusive of startup and shutdown, shall not exceed 2,628 hours in any consecutive rolling 12-month period.
- (c) The total number of startup events (one or two turbines) shall not exceed 1,040 events in any consecutive rolling 12-month period.
- (d) The total number of shutdown events (one or two turbines) shall not exceed 1,040 events in any consecutive rolling 12-month period.

[Reference: CPCN Case No. 9136, Condition B-IV-2]

CPCN#9136 states A “Startup Event” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a startup event is defined as the

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3	
	<p>period of time during which one CTs output is increased with the intent to startup, beginning with initiation of fuel combustion in one CT and ending when the SCR system catalyst reaches 600 degrees Fahrenheit. In the case of 2 CTs, the startup event begins at the point at which 1 CT initiates combustion and ends when the SCR system catalyst reaches 600F. [Reference: CPCN Case No. 9136, Condition B-II-5] CPCN#9136 states A “<i>Shutdown Event</i>” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a shutdown event is defined as the period of time during which one CTs output is lowered with the intent to shutdown, beginning at the point at which the load drops below 50% and ending when fuel combustion ceases. In the case a shutdown event of 2 CTs occurs, a shutdown event begins at the point at which the first CT drops below 50% and ends when fuel combustion for both CTs ceases. Notwithstanding the foregoing, if 2 CTs are in operation and 1 CT’s load is lowered below 50% with the intent to shutdown while the other CT continues in normal operation during and beyond the point fuel combustion ceases from the first Ct that shall not constitute a “Shutdown Event.” [Reference: CPCN Case No. 9136, Condition B-II-4]</p>
3.2	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Monitoring Requirement.</p> <p>B. <u>Control of Sulfur Oxides</u> The Permittee shall conduct the stack testing annually per the methods described in 40 CFR §60.8 (40 CFR §60.4415 and 40 CFR §60.4360] or monitor the sulfur content of each fuel combusted at a frequency prescribed in 40 CFR §60.4370 (see monitoring requirements) [Reference: CPCN Case No. 9136, Condition B-IV-11]</p> <p>C. <u>Control of Particulate Matter</u> The Permittee shall conduct stack test annually for PM₁₀, and PM_{2.5}. Unless otherwise approved by the Department, the stack testing shall be conducted in accordance with the following EPA approved test methods to determine compliance: (d) Reference Method 201A – Determination of PM₁₀ and PM_{2.5} Emissions From Stationary Sources and (e) Reference Method 202 – Dry Impinger Method for Determining Condensable Particulate Emissions from Stationary Sources. [Reference: CPCN Case No. 9136, Condition B-IV-11] The Permittee may submit to the Department a request to reduce the frequency of stack testing for any pollutant listed in this condition. [Reference: CPCN Case No. 9136, Condition B-IV-9]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

	<p><u>D. Control of Nitrogen Oxides</u> See Monitoring Requirement</p> <p><u>E. Control of GHG Emissions</u> The Permittee shall conduct the stack testing annually. Unless otherwise approved by the Department, for each fuel burned, the performance test shall be conducted in accordance with the following EPA approved test methods to determine compliance: (b) Reference Method 3A – Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure) or as an alternative to annual stack testing for CO₂, and upon approval by the Department, the Permittee may choose to demonstrate compliance with emission limitations by installing and operating a certified CEMS in accordance with the performance specifications of 40 CFR Part 75, Appendix A. [Reference: CPCN Case No. 9136, Condition B-IV-11] The Permittee may submit to the Department a request to reduce the frequency of stack testing for any pollutant listed in this condition. [Reference: CPCN Case No. 9136, Condition B-IV-9]</p> <p>NSPS Subpart TTTT See Monitoring Requirement.</p> <p><u>F. Control of Ammonia Emissions</u> The Permittee shall conduct the stack testing every five (5) years for ammonia. Unless otherwise approved by the Department, the stack test shall be conducted in accordance with the following EPA approved test methods to determine compliance: (a) Conditional Test Method 027 – Procedure for Collection and Analysis of Ammonia in Stationary Sources. [Reference: CPCN Case No. 9136, Condition B-IV-11] The Permittee may submit to the Department a request to reduce the frequency of stack testing for any pollutant listed in this condition. [Reference: CPCN Case No. 9136, Condition B-IV-9]</p> <p><u>G. Operational Limit</u> See Monitoring Requirement</p>
3.3	<p><u>Monitoring Requirements:</u></p> <p><u>A. Control of Visible Emissions</u> The Permittee shall operate and maintain the combustion turbines and associated air pollution control equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

including during startup, shutdown, and malfunction. **[Reference: CPCN Case No. 9136, Condition B-IV-14]**

The Permittee shall conduct quarterly visual observations during normal operation in accordance with EPA Reference Method 22 – Visual Determination of Fugitive Emissions from Material Sources and Smoke Emissions from Flares, to verify there are no visible emissions during operation. If visual emissions are observed, the Permittee shall inspect combustion control systems, perform necessary adjustments and/or repairs within 48 hours, and document in writing the results of inspection, adjustments, and/or repairs. After 48 hours, if the required adjustments and/or repairs have not eliminated visible emissions, the Permittee shall perform Reference Method 9 observations once daily for a period of 18 minutes burning the fuel where visual emissions are observed until corrective actions have reduced the visible emissions to less than 10 percent opacity. **[Reference: CPCN Case No. 9136, Condition B-IV-8]**

B. Control of Sulfur Oxides

The Permittee shall monitor the sulfur content of each fuel combusted in the turbines at a frequency prescribed in 40 CFR 60.4370. A representative fuel sample shall be collected following ASTM D5287 for pipeline natural gas of ASTM D4177 or ASTM D4057 Section 14 for ULSD. The fuel analyses may be performed either by the Permittee, a service contractor, the fuel vendor, or any qualified agency. Analyze the samples for the total sulfur content of the fuel using ASTM D129 (or alternatively D1266, D1552, D2622, D4294, or D5453) for ULSD and ASTM D1072 (or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377) for pipeline quality natural gas.

§60.4370 - How often must I determine the sulfur content of the fuel?

The frequency of determining the sulfur content of the fuel must be as follows:

*(a) Fuel oil. For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (i.e., flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or **sampling each delivery** prior to combining it with fuel oil already in the intended storage tank).*

*(b) Gaseous fuel. If you elect not to demonstrate sulfur content using options in §60.4365, and the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel must be determined and **recorded once per unit operating day**.*

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

Acid Rain Permit:

The Permittee shall comply with the monitoring requirements in 40 CFR Part 75 including the QC/QA procedures in Part 75 Appendix B. See Acid Rain Permit in Appendix A of this permit.

C. Control of Particulate Matter

The Permittee shall operate and maintain the combustion turbines and associated air pollution control equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction. **[Reference: CPCN Case No. 9136, Condition B-IV-14]**

D. Control of Nitrogen Oxides

The Permittee shall install ULSD and pipeline quality natural gas flow meters and continuously monitor each fuel flow into the two (2) combustion turbines. The fuel flow for each fuel shall be recorded monthly. **[Reference: CPCN Case No. 9136, Condition B-IV-7]**

The Permittee shall demonstrate compliance for NO_x emission standards by installing a certified NO_x CEMS in accordance with the performance specifications of 40 CFR Part 60, Appendix B or 40 CFR Part 75, Appendix A. The CEMS shall be operated and maintained to meet the quality assurance requirements of 40 CFR 60, Appendix F, and applicable requirement of 40 CFR Part 75. **[Reference: CPCN Case No. 9136, Condition B-IV-10]**

The Permittee shall install and maintain a temperature gauge to accurately indicate the temperature in degrees Fahrenheit of the SCR catalyst system. During startup events, the temperature of the SCR system catalyst should be continuously monitored. **[Reference: CPCN Case No. 9136, Condition B-IV-13]**

E. Control of GHG Emissions

The GHG emissions for the project shall be calculated as follows:
The total GHG emissions shall be presented on a CO₂e basis using the following global warming potential values:

Chemical Formula	Global Warming Potential
CO ₂	1
CH ₄	25
N ₂ O	298
SF ₆	23,900

For the combustion turbines, the CO₂ emissions shall be based on fuel flow and the measured carbon content of the fuel using procedures specified in Appendix G of 40 CFR Part 75, or other

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3	
	<p>emission factors approved by the Department. The CH₄ and N₂O emissions shall be calculated using the procedures specified in 40 CFR Part 98 Subpart C.</p> <p>The total generation of the combustion turbines shall be monitored to calculate the emission rate of lb CO₂e/MWh, determined each month by summing the CO₂e emission for all hours in which power is being generated by the turbines during the previous 12 months and dividing that value by the sum of electrical energy output over that same period. [Reference: CPCN Case No. 9136, Condition B-IV-12]</p> <p>NSPS Subpart TTTT §60.5535 - <u>How do I monitor and collect data to demonstrate compliance?</u> "(a) Combustion turbines qualifying under §60.5520(d)(1) <u>are not</u> subject to any requirements in this section other than the requirement to maintain fuel purchase records for permitted fuel(s)."</p> <p>F. <u>Control of Ammonia Emissions</u> The Permittee shall operate and maintain the combustion turbines and associated air pollution control equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction. [Reference: CPCN Case No. 9136, Condition B-IV-14]</p> <p>G. <u>Operational Limit</u> The Permittee shall install ULSD and pipeline quality natural gas flow meters and continuously monitor each fuel flow into the two (2) combustion turbines. The fuel flow for each fuel shall be recorded monthly. [Reference: CPCN Case No. 9136, Condition B-IV-7]</p>
3.4	<p><u>Record Keeping Requirements:</u> <u>Note:</u> All records must be maintained for a period of at least 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall document in writing the results of inspection, adjustments, and/or repairs, taken to address visible emissions observed during quarterly Method 22 and/or Method 9 observations and make available to the Department upon request. [Reference: CPCN Case No. 9136, Condition B-IV-8 & COMAR 26.11.03.06C]</p> <p>B. <u>Control of Sulfur Oxides</u> The Permittee shall maintain all annual fuel records for the project. [Reference: CPCN Case No. 9136, Condition B-IV-21]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

A certification from the fuel supplier indicating that the ULSD complies with the limitation of sulfur content in the fuel oil. The certification should include the name of the supplier, the date of delivery, the amount of fuel delivered, the method used to determine the sulfur content of the oil, and a statement from the fuel supplier that the ULSD complies with the specifications of 40 CFR 80.510. **[Reference: CPCN Case No. 9136, Condition B-V-8 and 15]**

Acid Rain Permit:

The Acid Rain Permit contains specific recordkeeping requirements. See Acid Rain Permit in Appendix A of this permit. **[Reference: 40 CFR Part 75, Subpart F]**

C. Control of Particulate Matter

The Permittee shall maintain all annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

D. Control of Nitrogen Oxides

The Permittee shall maintain the following:

- (1) All CEMS reports submitted to the Department. **[Reference: CPCN Case No. 9136, Condition B-IV-20]**
- (2) Records of the SCR system catalyst temperature during startup events. **[Reference: CPCN Case No. 9136, Condition B-IV-22]**

E. Control of GHG Emissions

The Permittee shall maintain all annual fuel records for the project.

[Reference: CPCN Case No. 9136, Condition B-IV-21]

Monthly and 12-month consecutive rolling GHG emission rate, expressed in lb/CO₂/MWh gross, for each combustion turbine for each fuel burned.

[Reference: CPCN Case No. 9136, Condition B-IV-23]

NSPS Subpart TTTT

The Permittee shall maintain fuel purchase records as required by 40 CFR §60.5520(d)(1).

F. Control of Ammonia Emissions

The Permittee shall maintain all annual fuel records for the project.

[Reference: CPCN Case No. 9136, Condition B-IV-21]

Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine. **[Reference: CPCN Case No. 9136, Condition B-IV-23]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
 PERRYMAN GENERATING STATION
 900 CHELSEA ROAD, PERRYMAN, MD 21130
 PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3	
	<p><u>G. Operational Limit</u> The Permittee shall maintain all annual fuel records for the project. [Reference: CPCN Case No. 9136, Condition B-IV-21]</p>
3.5	<p><u>Reporting Requirements:</u></p> <p><u>A. Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations” [Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]</p> <p><u>B. Control of Sulfur Oxides</u> The Permittee shall report fuel supplier certifications or fuel analyses to the Department upon request. [Reference: COMAR 26.11.09.07C] The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted to the Department within 60 days after completion of the test. [Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25] The Permittee shall submit reports of NSPS Subpart KKKK excess emissions and monitor downtime associated with the combustion turbines, in accordance with 40 CFR 60.79(c). Excess emissions as defined in 40 CFR 60.4385 (SO₂) must be reported for all periods of unit operation, including startup, shutdown, and malfunction. [Reference: CPCN Case No. 9136, Condition B-IV-27] All reports required must be postmarked by the 30th day following the end of each 6-month period. [Reference: §60.4395]</p> <p><u>Acid Rain Permit:</u> The Acid Rain Permit contains specific reporting requirements. See Acid Rain Permit in Appendix A of this permit. [Reference: 40 CFR Part 75, Subpart G]</p> <p><u>C. Control of Particulate Matter</u> The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted to the Department within 60 days after completion of the test. [Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25]</p> <p>The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

documentation:

Monthly and consecutive rolling 12-month emissions (in tons per month and tons per year) of GHGs (as CO₂e), PM₁₀, PM_{2.5}, and NO_x for the entire Perryman 6 Project.

Additional emissions source specific supporting documentation as defined within each emissions source section of conditions.

[Reference: CPCN Case No. 9136, Condition B-III-5]

Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine.

Monthly and 12-month consecutive rolling quantity of pipeline natural gas and ULSD for each combustion turbine, inclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, inclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, exclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling total number of startup events and shutdown events.

Total NO_x emission expressed in lb/event for each startup event and shutdown event

Monthly and 12-month consecutive rolling gross generation (MWh) for each combustion turbine for each fuel burned.

For any period where a combustion turbine burned ULSD, an explanation for why ULSD used was burned.

[Reference: CPCN Case No. 9136, Condition B-IV-23]

D. Control of Nitrogen Oxides

The Permittee shall submit:

- (1) A quarterly CEMS summary report in a format approved by the Department and include the information required under COMAR 26.11.01.11E(2)(c)(i)-(vii). **[Reference: CPCN Case No. 9136, Condition B-IV-19(b)]**
- (2) CEMS System Downtime Reports for any CEMS system downtime that lasts or is expected to last more than 24 hours by telephone before 10 a.m. of the first regular business day following the breakdown. **[Reference: CPCN Case No. 9136, Condition B-IV-19(a)]**
- (3) Reports of NSPS Subpart KKKK excess emissions and monitor downtime associated with the combustion turbines, in accordance with 40 CFR 60.79(c). Excess emissions as defined in 40 CFR 60.4380 (NO_x) must be reported for all periods of unit operation, including startup, shutdown, and malfunction. **[Reference: CPCN**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3

Case No. 9136, Condition B-IV-27]

All reports required must be postmarked by the 30th day following the end of each 6-month period. **[Reference: §60.4395]**

E. Control of GHG Emissions

The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted to the Department within 60 days after completion of the test.

[Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25]

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation:

Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine.

Monthly and 12-month consecutive rolling GHG emission rate, expressed in lb/CO₂/MWh gross, for each combustion turbine for each fuel burned.

Monthly and 12-month consecutive rolling gross generation (MWh) for each combustion turbine for each fuel burned.

[Reference: CPCN Case No. 9136, Condition B-IV-23]

NSPS Subpart TTTT

See Record Keeping Requirements.

F. Control of Ammonia Emissions

The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted to the Department within 60 days after completion of the test.

[Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25]

G. Operational Limit

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation:

Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[Reference: CPCN Case No. 9136, Condition B-III-5]**

Monthly and 12-month consecutive rolling quantity of pipeline natural gas and ULSD for each combustion turbine, inclusive of startup events and shutdown events.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 3	
	<p>Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, inclusive of startup events and shutdown events. Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, exclusive of startup events and shutdown events. Monthly and 12-month consecutive rolling total number of startup events and shutdown events. [Reference: CPCN Case No. 9136, Condition B-IV-23]</p>

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV – 4	
4.0	<p><u>Emissions Unit Number(s): EG6 & FWP6</u></p> <p>EG6: One (1) diesel-fired emergency generator rated at 268 hp (025-0024-9-0492). FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp (025-0024-9-0502) These generators will only be fired with ultra-low sulfur diesel (ULSD).</p>
4.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05E - Visible Emissions.</p> <p>(2) "Emissions during Idle Mode. A person may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.</p> <p>(3) Emissions during Operating Mode. A person may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.</p> <p>(4) Exceptions.</p> <p>(a) Section E(2) of this regulation does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system.</p> <p>(b) Section E(3) of this regulation does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods: (i) Engines that are idled continuously when not in service: 30 minutes; (ii) All other engines: 15 minutes.</p> <p>(c) Sections E(2) and (3) of this regulation do not apply while</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 4

	<p style="text-align: center;">maintenance, repair, or testing is being performed by qualified mechanics.”</p> <p>B. <u>Control of Sulfur Oxides</u> COMAR 26.11.09.07A - <u>Control of Sulfur Oxides From Fuel Burning Equipment.</u> “A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: (2) In Areas III and IV: (b) Distillate fuel oils, 0.3 percent;” The only permissible fuels for the emergency generator and the firewater pump engine is ULSD with a sulfur content not to exceed 15 parts per million by weight. [Reference: CPCN Case No. 9136, Condition B-V-1] The emergency generator and firewater pump engine must be fitted with a non-resettable hour meter prior to startup of each engine. [Reference: CPCN Case No. 9136, Condition B-V-9]</p> <p>C. <u>Control of Nitrogen Oxides</u> COMAR 26.11.09.08G - <u>Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.</u> “(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall: (a) Provide certification of the capacity factor of the equipment to the Department in writing; (b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually; (c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request; (d) Require each operator of an installation, except combustion turbines, to attend operator training programs at least once every 3 years, on combustion optimization that are sponsored by the Department, the EPA, or equipment vendors; and (e) Maintain a record of training program attendance for each operator at the site, and make these records available to the Department upon request.</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 4	
4.2	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Monitoring Requirement.</p> <p>B. <u>Control of Sulfur Oxides</u> See Monitoring Requirement.</p> <p>C. <u>Control of Nitrogen Oxides</u> See Monitoring Requirement</p>
4.3	<p><u>Monitoring Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The emergency generator and firewater pump engine shall be operated and maintained in accordance with the manufacturer’s emission-related written instructions, changing only those emission-related settings that are permitted by the manufacturer, and meet the requirements of 40 CFR Parts 89, 94, and/or 1068 as applicable. [Reference: CPCN Case No. 9136, Condition B-V-10]</p> <p>B. <u>Control of Sulfur Oxides</u> The Permittee shall obtain a certification from the fuel oil supplier indicating that the oil complies with the limitation on the sulfur content of the fuel oil or obtain sulfur in fuel analyses of oil that is representative of oil burned. [Reference: COMAR 26.11.09.07C]</p> <p>C. <u>Control of Nitrogen Oxides</u> The emergency generator and firewater pump engine must be fitted with a non-resettable hour meter prior to startup of each engine. [Reference: CPCN Case No. 9136, Condition B-V-9]</p>
4.4	<p><u>Record Keeping Requirements:</u></p> <p>Note: All records must be maintained for a period of at least 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirement.</p> <p>B. <u>Control of Sulfur Oxides</u> The Permittee shall maintain: All annual fuel records for the project. [Reference: CPCN Case No. 9136, Condition B-IV-21]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 4	
	<p>A certification from the fuel supplier indicating that the ULSD complies with the limitation of sulfur content in the fuel oil. The certification should include the name of the supplier, the date of delivery, the amount of fuel delivered, the method used to determine the sulfur content of the oil, and a statement from the fuel supplier that the ULSD complies with the specifications of 40 CFR 80.510. [Reference: CPCN Case No. 9136, Condition B-V-8 and 15]</p> <p><u>C. Control of Nitrogen Oxides</u> The Permittee shall maintain: Results of any combustion analyses on the emergency generator or firewater pump engine. [Reference: CPCN Case No. 9136, Condition B-V-12(a)] Records of training program attendance for each operator of the emergency generator and firewater pump engine. [Reference: CPCN Case No. 9136, Condition B-V-12(b)]</p>
4.5	<p><u>Reporting Requirements:</u></p> <p><u>A. Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations” [Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]</p> <p><u>B. Control of Sulfur Oxides</u> The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. [Reference: CPCN Case No. 9136, Condition B-III-5] For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling emissions; For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling hours of operation; For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling quantity of ULSD burned; The reason the engine was in operation for each time operated. [Reference: CPCN Case No. 9136, Condition B-V-17]</p> <p><u>C. Control of Nitrogen Oxides</u> The Permittee shall submit quarterly reports to the Department to be</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 4	
	<p>postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation:</p> <p>Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. [Reference: CPCN Case No. 9136, Condition B-III-5]</p> <p>For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling hours of operation.</p> <p>The reason the engine was in operation for each time operated.</p> <p>[Reference: CPCN Case No. 9136, Condition B-V-17]</p>

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV – 4a																
4a.0	<p><u>Emissions Unit Number(s) EG6 & FWP6 (Cont'd)</u></p> <p>EG6: One (1) diesel-fired emergency generator rated at 268 hp (025-0024-9-0492).</p> <p>FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp (025-0024-9-0502)</p> <p>These generators will only be fired with ultra-low sulfur diesel (ULSD).</p>															
4a.1	<p><u>Applicable Standards/Limits:</u></p> <p><u>NSPS</u> 40 CFR 60 Subpart IIII - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines</p> <p>The emergency generator and the firewater pump engine must meet the following emissions limits for the entire life of the engines:</p> <table border="1" style="width: 100%; border-collapse: collapse; margin: 10px 0;"> <thead> <tr> <th style="width: 30%;">Pollutant</th> <th style="width: 35%;">Emergency Generator</th> <th style="width: 35%;">Firewater Pump Engine</th> </tr> <tr> <td></td> <td style="text-align: center;">Emissions Limit g/kW-hr (g/hp-hr)</td> <td style="text-align: center;">Emissions Limit g/kW-hr (g/hp-hr)</td> </tr> </thead> <tbody> <tr> <td>NO_x + NMHC</td> <td style="text-align: center;">4.0 (3.0)</td> <td style="text-align: center;">4.0 (3.0)</td> </tr> <tr> <td>CO</td> <td style="text-align: center;">3.5 (2.5)</td> <td style="text-align: center;">n/a</td> </tr> <tr> <td>PM (filterable only)</td> <td style="text-align: center;">0.20 (0.15)</td> <td style="text-align: center;">0.20 (0.15)</td> </tr> </tbody> </table> <p>[Reference: CPCN Case No. 9136, Condition B-V-4.]</p> <p><i>Note the emergency generator actually installed on the project was 268 hp, not the 1300 hp engine specified in the application and CPCN. Thus,</i></p>	Pollutant	Emergency Generator	Firewater Pump Engine		Emissions Limit g/kW-hr (g/hp-hr)	Emissions Limit g/kW-hr (g/hp-hr)	NO _x + NMHC	4.0 (3.0)	4.0 (3.0)	CO	3.5 (2.5)	n/a	PM (filterable only)	0.20 (0.15)	0.20 (0.15)
Pollutant	Emergency Generator	Firewater Pump Engine														
	Emissions Limit g/kW-hr (g/hp-hr)	Emissions Limit g/kW-hr (g/hp-hr)														
NO _x + NMHC	4.0 (3.0)	4.0 (3.0)														
CO	3.5 (2.5)	n/a														
PM (filterable only)	0.20 (0.15)	0.20 (0.15)														

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 4a	
	<p><i>the emission limit for NO_x+NHMC was reduced from 6.4 to 4.0 g/kW-hr to reflect the requirements in 40 CFR 60, Subpart IIII.</i></p> <p>The emergency generator and firewater pump engine must be certified to meet the emission standards of 40 CFR 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer’s emission-related specifications, except as permitted in paragraph 40 CFR 60.4211(g). [Reference: CPCN Case No. 9136, Condition B-V-5(b)]</p> <p>The emergency generator may only be operated for emergencies, maintenance, and testing purposes; any other operation is prohibited. Operation of the emergency generator for maintenance and testing purposes is limited to a maximum of 100 hours per year. There is no limit on emergency usage. [Reference: CPCN Case No. 9136, Condition B-V-5(c)]</p> <p>The firewater pump engine may operate for emergencies, maintenance and testing purposes, and emergency demand response as defined in 40 CFR 60.4211(f)(1) and (2). Operation of the engine for maintenance, testing, and emergency demand response is limited to a maximum of 100 hours per year. There is no limit on emergency usage. [Reference: CPCN Case No. 9136, Condition B-V-5(d)]</p> <p>The emergency generator and firewater pump engine shall not have PM₁₀ and PM_{2.5} total emissions (filterable and condensable) exceed 0.17 g/hp-hr with PM condensable emissions alone not to exceed 0.02 g/hp-hr. [Reference: CPCN Case No. 9136, Condition B-V-7]</p> <p><u>NESHAP</u> To satisfy the requirements of 40 CFR Part 63, Subpart ZZZZ, the emergency generator and firewater pump engine shall comply with all the applicable requirements of NSPS Subpart IIII. [Reference: CPCN Case No. 9136, Condition B-V-6]</p>
4a.2	<p><u>Testing Requirements:</u></p> <p><u>NSPS</u> See Monitoring Requirement.</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 4a	
4a.3	<p><u>Monitoring Requirements:</u></p> <p><u>NSPS</u> The emergency generator and firewater pump engine shall be operated and maintained in accordance with the manufacturer’s emission-related written instructions, changing only those emission-related settings that are permitted by the manufacturer, and meet the requirements of 40 CFR Parts 89, 94, and/or 1068 as applicable. [Reference: CPCN Case No. 9136, Condition B-V-10]</p> <p>The emergency generator and firewater pump engine must be fitted with a non-resettable hour meter prior to startup of each engine. [Reference: CPCN Case No. 9136, Condition B-V-9]</p>
4a.4	<p><u>Record Keeping Requirements:</u></p> <p>Note: All records must be maintained for a period of at least 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p><u>NSPS</u> The Permittee shall maintain: All annual fuel records for the project. [Reference: CPCN Case No. 9136, Condition B-IV-21] Results of any combustion analyses on the emergency generator or firewater pump engine. [Reference: CPCN Case No. 9136, Condition B-V-12(a)]</p>
4a.5	<p><u>Reporting Requirements:</u></p> <p><u>NSPS</u> The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. [Reference: CPCN Case No. 9136, Condition B-III-5]</p> <p>For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling emissions For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling hours of operation. The reason the engine was in operation for each time operated. [Reference: CPCN Case No. 9136, Condition B-V-17]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV – 5									
5.0	<p><u>Emissions Unit Number(s): FUG6, CB6 & PR6</u></p> <p>FUG6: Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.</p> <p>CB6: Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF₆).</p> <p>PR6: Paved road emissions associated with the Perryman 6 Project. Emissions from this emission unit are assumed to be entirely PM_{2.5} and PM₁₀.</p>								
5.1	<p><u>Applicable Standards/Limits:</u></p> <p><u>Operational Limit</u> <u>For FUG6 only</u></p> <p>GHG BACT Emission Limit - The GHG Emissions from FUG6 shall be included as part of the Project-wide GHG Emissions limit listed in Condition B-III-3 of the CPCN#9136.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">Pollutant</th> <th>Project-Wide Emission Limit (tpy)</th> </tr> </thead> <tbody> <tr> <td>Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO₂e)</td> <td style="text-align: center;">430,210</td> </tr> </tbody> </table> <p>The Permittee shall implement an audio, visual, and olfactory (AVO) program to monitor fugitive GHG emissions. [Reference: CPCN Case No. 9136, Condition B-VI-3]</p> <p><u>For CB6 only</u></p> <p>GHG BACT Emission Limit - The GHG Emissions from CB6 shall be included as part of the Project-wide GHG Emissions limit listed in Condition B-III-3 of the CPCN#9136.</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 60%;">Pollutant</th> <th>Project-Wide Emission Limit (tpy)</th> </tr> </thead> <tbody> <tr> <td>Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO₂e)</td> <td style="text-align: center;">430,210</td> </tr> </tbody> </table> <p>A state-of-the-art circuit breaker shall be installed that is designed to meet ANSI C37.013 or equivalent to detect and minimize SF₆ leaks. [Reference: CPCN Case No. 9136, Condition B-VII-3]</p> <p><u>For CB6 only</u></p> <p>BACT/LAER Emission Limits - The PM₁₀ and PM_{2.5} emissions from PR6</p>	Pollutant	Project-Wide Emission Limit (tpy)	Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210	Pollutant	Project-Wide Emission Limit (tpy)	Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210
Pollutant	Project-Wide Emission Limit (tpy)								
Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210								
Pollutant	Project-Wide Emission Limit (tpy)								
Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210								

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 5							
	<p>shall be included as part of the Project-wide PM₁₀ and PM_{2.5} emissions limits listed in Condition B-III-3 of the CPCN#9136</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">Pollutant</th> <th style="width: 50%;">Project-Wide Emission Limit (tpy)</th> </tr> </thead> <tbody> <tr> <td>Particulate Matter less than 10 microns (PM₁₀) – Filterable and Condensable</td> <td style="text-align: center;">43.0</td> </tr> <tr> <td>Particulate Matter less than 2.5 microns (PM_{2.5}) – Filterable and Condensable</td> <td style="text-align: center;">43.0</td> </tr> </tbody> </table> <p>[Reference: CPCN Case No. 9136, Condition B-III-3]</p>	Pollutant	Project-Wide Emission Limit (tpy)	Particulate Matter less than 10 microns (PM ₁₀) – Filterable and Condensable	43.0	Particulate Matter less than 2.5 microns (PM _{2.5}) – Filterable and Condensable	43.0
Pollutant	Project-Wide Emission Limit (tpy)						
Particulate Matter less than 10 microns (PM ₁₀) – Filterable and Condensable	43.0						
Particulate Matter less than 2.5 microns (PM _{2.5}) – Filterable and Condensable	43.0						
5.2	<p><u>Testing Requirements:</u></p> <p><u>Operational Limit</u> For FUG6 only See Monitoring Requirement</p> <p><u>For CB6 only</u> See Monitoring Requirement</p> <p><u>For CB6 only</u> See Monitoring Requirement</p>						
5.3	<p><u>Monitoring Requirements:</u></p> <p><u>Operational Limit</u> For FUG6 only Monthly and 12-month consecutive rolling emissions for the FUG6 shall be calculated as follows: The fugitive GHG emissions shall be based on EPA AP-42 emission factors, methodology described in 40 CFR Part 98 Subpart W, or other emission factors approved by the Department. [Reference: CPCN Case No. 9136, Condition B-VI-2(a)] The total GHG emissions from FUG6 shall be presented on a CO₂e basis using the following global warming potential values:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">Chemical Formula</th> <th style="width: 50%;">Global Warming Potential</th> </tr> </thead> <tbody> <tr> <td>CO₂</td> <td style="text-align: center;">1</td> </tr> <tr> <td>CH₄</td> <td style="text-align: center;">25</td> </tr> </tbody> </table> <p>[Reference: CPCN Case No. 9136, Condition B-VI-2(b); 40 CFR 98] The Permittee shall implement an audio, visual, and olfactory (AVO) program to monitor fugitive GHG emissions. These emissions shall be evaluated on a weekly basis from the natural gas pipeline and associated components through the AVO program. The AVO inspections shall be documented. Leaks identified from the AVO assessment shall be repaired within 5 days of discovery; repairs shall be documented, and associated repair records shall be maintained. [Reference: CPCN Case No. 9136,</p>	Chemical Formula	Global Warming Potential	CO ₂	1	CH ₄	25
Chemical Formula	Global Warming Potential						
CO ₂	1						
CH ₄	25						

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 5

	<p>Condition B-VI-3]</p> <p><u>For CB6 only</u> Monthly and 12-month consecutive rolling emissions for the CB6 shall be calculated as follows: The GHG emissions from the circuit breaker shall be calculated using manufacturer provided leak rate, the methodology in 40 CFR 98, Subpart DD, and assuming 8,760 hours per year of operation. [Reference: CPCN Case No. 9136, Condition B-VII-2(a)] The total GHG emissions from CB6 shall be presented on a CO2e basis using a global warming potential value of 23,900 for SF6. [Reference: CPCN Case No. 9136, Condition B-VII-2(a)]; 40 CFR 98 Leaks detected shall be repaired within 5 days of discovery; repairs shall be documented, and associated repair records shall be maintained. [Reference: CPCN Case No. 9136, Condition B-VII-3]</p> <p><u>For PR6 only</u> See Record Keeping Requirement</p>
5.4	<p><u>Record Keeping Requirements:</u> Note: All records must be maintained for a period of at least 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p><u>Operational Limit</u> The Permittee shall maintain for at least five (5) years and make available to the Department upon request the following: <u>For FUG6 only:</u> Records of monitoring and repair associated with fugitive emissions. [Reference: CPCN Case No. 9136, Condition B-VI-4] Monthly and 12-month consecutive rolling GHG emissions for FUG6. The emissions and supporting calculations shall be included in the quarterly report. [Reference: CPCN Case No. 9136, Condition B-VI-5]</p> <p><u>For CB6 only:</u> Records of all monitoring and repair associated with the circuit breaker. [Reference: CPCN Case No. 9136, Condition B-VII-4] Monthly and 12-month consecutive rolling GHG emissions for CB6. The emissions and supporting calculations shall be included in the quarterly report. [Reference: CPCN Case No. 9136, Condition B-VII-5]</p> <p><u>For PR6 only:</u> Reasonable precautions shall be taken to prevent particulate matter from becoming airborne via paved roads. [Reference: CPCN Case No. 9136, Condition B-VIII-3]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 5	
5.5	<p><u>Reporting Requirements:</u></p> <p><u>Operational Limit</u> The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. [Reference: CPCN Case No. 9136, Condition B-III-5] <u>For FUG6 only:</u> Monthly and 12-month consecutive rolling GHG emissions from fugitive sources. [Reference: CPCN Case No. 9136, Condition B-VI-5] <u>For CB6 only:</u> Monthly and 12-month consecutive rolling GHG emissions from the circuit breaker. [Reference: CPCN Case No. 9136, Condition B-VII-5] <u>For PR6 only:</u> Monthly and 12-month consecutive rolling PM₁₀ and PM_{2.5} emissions from paved roads. [Reference: CPCN Case No. 9136, Condition B-VIII-4]</p>

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV – 6	
6.0	<p><u>Emissions Unit Number(s): CT6A, CT6B, EG6, FWP6, FUG6, CB6 & PR6 (Project-wide)</u></p> <p>CT6A & CT6B One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted. [025-0024-5-0353 & 5-0354]</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 6

	<p>EG6: One (1) diesel-fired emergency generator rated at 268 hp (025-0024-9-0492).</p> <p>FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp (025-0024-9-0502)</p> <p>FUG6: Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.</p> <p>CB6: Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF₆).</p> <p>PR6: Paved road emissions associated with the Perryman 6 Project. Emissions from this emission unit are assumed to be entirely PM_{2.5} and PM₁₀.</p>										
<p>6.1</p>	<p><u>Applicable Standards/Limits:</u></p> <p><u>Operational Limit</u> Emissions for all sources identified as part of the Perryman 6 Project, including emissions during periods of startup and shutdown, shall be limited to the following, in tons per year, in any consecutive 12-month rolling period:</p> <table border="1" data-bbox="358 1010 1333 1356"> <thead> <tr> <th>Pollutant</th> <th>Project-Wide Emission Limit (tpy)</th> </tr> </thead> <tbody> <tr> <td>Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO₂e)</td> <td style="text-align: center;">430,210</td> </tr> <tr> <td>Particulate Matter less than 10 microns (PM₁₀) – Filterable and Condensable</td> <td style="text-align: center;">43.0</td> </tr> <tr> <td>Particulate Matter less than 2.5 microns (PM_{2.5}) – Filterable and Condensable</td> <td style="text-align: center;">43.0</td> </tr> <tr> <td>Nitrogen Dioxides (NO_x)</td> <td style="text-align: center;">58.5</td> </tr> </tbody> </table> <p>[Reference: CPCN Case No. 9136, Condition B-III-3]</p>	Pollutant	Project-Wide Emission Limit (tpy)	Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210	Particulate Matter less than 10 microns (PM ₁₀) – Filterable and Condensable	43.0	Particulate Matter less than 2.5 microns (PM _{2.5}) – Filterable and Condensable	43.0	Nitrogen Dioxides (NO _x)	58.5
Pollutant	Project-Wide Emission Limit (tpy)										
Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210										
Particulate Matter less than 10 microns (PM ₁₀) – Filterable and Condensable	43.0										
Particulate Matter less than 2.5 microns (PM _{2.5}) – Filterable and Condensable	43.0										
Nitrogen Dioxides (NO _x)	58.5										
<p>6.2</p>	<p><u>Testing Requirements:</u></p> <p><u>Operational Limit</u> See Monitoring Requirement.</p>										
<p>6.3</p>	<p><u>Monitoring Requirements:</u></p> <p>The Permittee shall calculate monthly and consecutive rolling 12-month emissions (in tons per month and tons per year) of GHGs (as CO₂e), PM₁₀, PM_{2.5}, and NO_x for the entire Perryman 6 Project. [Reference: CPCN Case No. 9136, Condition B-III-4]</p>										

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 6

The GHG emissions for the project shall be calculated as follows:
(a) The total GHG emissions shall be presented on a CO₂e basis using the following global warming potential values:

Chemical Formula	Global Warming Potential
CO ₂	1
CH ₄	25
N ₂ O	298
SF ₆	23,900

(b) For the combustion turbines, the CO₂ emissions shall be based on fuel flow and the measured carbon content of the fuel using procedures specified in Appendix G of 40 CFR Part 75, or other emission factors approved by the Department. The CH₄ and N₂O emissions shall be calculated using the procedures specified in 40 CFR Part 98 Subpart C.

(c) The total generation of the combustion turbines shall be monitored to calculate the emission rate of lb CO₂e/MWh, determined each month by summing the CO₂e emission for all hours in which power is being generated by the turbines during the previous 12 months and dividing that value by the sum of electrical energy output over that same period.

(d) For the emergency generator and firewater pump engine, the GHG emissions shall be based on the methodology described in 40 CFR Part 98 Subpart C, or other emission factors approved by the Department.

(e) The fugitive GHG emissions shall be based on EPA AP-42 emission factors, methodology described in 40 CFR Part 98 Subpart W, or other emission factors approved by the Department.

(f) The GHG emissions from the circuit breaker shall be calculated using manufacturer provided leak rate, the methodology in 40 CFR 98, Subpart DD, and assuming 8,760 hours per year of operation.

The Permittee shall install ULSD and pipeline quality natural gas flow meters and continuously monitor each fuel flow into the two (2) combustion turbines. The fuel flow for each fuel shall be recorded monthly. **[Reference: CPCN Case No. 9136, Condition B-IV-7]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 6	
6.4	<p><u>Record Keeping Requirements:</u> Note: All records must be maintained for a period of at least 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p>The Permittee shall maintain the following: The fuel flow for each fuel shall be recorded monthly. [Reference: CPCN Case No. 9136, Condition B-IV-7] All CEMS reports submitted to the Department. [Reference: CPCN Case No. 9136, Condition B-IV-20]</p>
6.5	<p><u>Reporting Requirements:</u></p> <p>The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation:</p> <ul style="list-style-type: none"> (a) Monthly and consecutive rolling 12-month emissions (in tons per month and tons per year) of GHGs (as CO₂e), PM₁₀, PM_{2.5}, and NO_x for the entire Perryman 6 Project. [Reference: CPCN Case No. 9136, Condition B-III-5(a)] (b) Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. [COMAR 26.11.02.02H] [Reference: CPCN Case No. 9136, Condition B-III-5(b)] (c) Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine. [Reference: CPCN Case No. 9136, Condition B-IV-23(a)] (d) Monthly and 12-month consecutive rolling quantity of pipeline natural gas and ULSD for each combustion turbine, inclusive of startup events and shutdown events. [Reference: CPCN Case No. 9136, Condition B-IV-23(b)] (e) Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, inclusive of startup events and shutdown events. [Reference: CPCN Case No. 9136, Condition B-IV-23(c)] (f) Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, exclusive of startup events and shutdown events. [Reference: CPCN Case No. 9136,

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 6

Condition B-IV-23(d)]

- (g) Monthly and 12-month consecutive rolling total number of startup events and shutdown events. **[Reference: CPCN Case No. 9136, Condition B-IV-23(e)]**
- (h) Total NO_x emission expressed in lb/event for each startup event and shutdown event. **[Reference: CPCN Case No. 9136, Condition B-IV-23(f)]**
- (i) Monthly and 12-month consecutive rolling GHG emissions rate, expressed in lb/CO₂/MWh gross, for each combustion turbine for each fuel burned. **[Reference: CPCN Case No. 9136, Condition B-IV-23(g)]**
- (j) Monthly and 12-month consecutive rolling gross generation (MWh) for each combustion turbine for each fuel burned. **[Reference: CPCN Case No. 9136, Condition B-IV-23(h)]**
- (k) A quarterly CEMS summary report in a format approved by the Department and include the information required under COMAR 26.11.01.11E(2)(c)(i)-(vii). **[Reference: CPCN Case No. 9136, Condition B-IV-19(b)]**
- (l) For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling emissions. **[Reference: CPCN Case No. 9136, Condition B-V-17(a)]**
- (m) Monthly and 12-month consecutive rolling GHG emissions from fugitive sources. **[Reference: CPCN Case No. 9136, Condition B-VI-5]**
- (n) Monthly and 12-month consecutive rolling GHG emissions from the circuit breaker. **[Reference: CPCN Case No. 9136, Condition B-VII-5]**
- (o) Monthly and 12-month consecutive rolling PM₁₀ and PM_{2.5} emissions from paved roads. **[Reference: CPCN Case No. 9136, Condition B-VIII-4]**
- (p) For any period where a combustion turbine burned ULSD, an explanation for why ULSD was burned. **[Reference: CPCN**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV – 6	
	Case No. 9136, Condition B-IV-23(i)]

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV–7: Cross State Air Pollution Rule (CSAPR)	
7.0	<p><u>Emissions Unit Number(s): PY-Unit 1, PY-Unit 2, PY-Unit 3, PY-Unit 4, PY-Unit 51, CT6A, CT6B, EG6, FWP6, FUG6, CB6 & PR6</u></p> <p>PY-Unit 1, PY-Unit 2, PY-Unit 3, PY-Unit 4 Four (4) Westinghouse model 501 simple cycle combustion turbines, each with a design heat input of 704 mm Btu/hr, rated at a nominal 51 megawatt output and capable of only burning No.2 distillate oil. [12-4-0081 thru 12-4-0084]</p> <p>PY-Unit 51 General Electric Frame 7FA stationary, single-shaft combustion turbine operating in the simple cycle mode, rated at a nominal 150-megawatt output. This turbine has dual fuel (natural gas and No. 2 oil) firing capacity. [12-5-0088]</p> <p>CT6A & CT6B One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted. [025-0024-5-0353 & 5-0354]</p> <p>EG6: One (1) diesel-fired emergency generator rated at 268 hp (025-0024-9-0492).</p> <p>FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp (025-0024-9-0502)</p> <p>FUG6: Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.</p> <p>CB6: Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF₆).</p> <p>PR6: Paved road emissions associated with the Perryman 6 Project.</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)	
	Emissions from this emission unit are assumed to be entirely PM _{2.5} and PM ₁₀ .
7.1	<p><u>Applicable Standards/Limits:</u></p> <p><u>A. 40 CFR Part 97 Subpart AAAAA-TR NO_x Annual Trading Program TR NO_x Annual Trading Program requirements (40 CFR 97.406)</u></p> <p>(a) Designated representative requirements. The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.413 through 97.418.</p> <p>(b) Emissions monitoring, reporting, and recordkeeping requirements.</p> <p>(1) The owners and operators, and the designated representative, of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.430 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.431 (initial monitoring system certification and recertification procedures), 97.432 (monitoring system out-of-control periods), 97.433 (notifications concerning monitoring), 97.434 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.435 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).</p> <p>(2) The emissions data determined in accordance with 40 CFR 97.430 through 97.435 shall be used to calculate allocations of TR NO_x Annual allowances under 40 CFR 97.411(a)(2) and (b) and 97.412 and to determine compliance with the TR NO_x Annual emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.430 through 97.435 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.</p> <p>(c) NO_x emissions requirements.</p> <p>(1) TR NO_x Annual emissions limitation.</p> <p>(i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>Annual source and each TR NO_x Annual unit at the source shall hold, in the source's compliance account, TR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Annual units at the source.</p> <p>(ii). If total NO_x emissions during a control period in a given year from the TR NO_x Annual units at a TR NO_x Annual source are in excess of the TR NO_x Annual emissions limitation set forth in paragraph (c)(1)(i) above, then:</p> <p>(A). The owners and operators of the source and each TR NO_x Annual unit at the source shall hold the TR NO_x Annual allowances required for deduction under 40 CFR 97.424(d); and</p> <p>(B). The owners and operators of the source and each TR NO_x Annual unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.</p> <p>(2) TR NO_x Annual assurance provisions.</p> <p>(i). If total NO_x emissions during a control period in a given year from all TR NO_x Annual units at TR NO_x Annual sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.425(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.425(b), of multiplying— (A) The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common</p>
--	---

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and (B) The amount by which total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the state for such control period exceed the state assurance level.</p> <p>(ii). The owners and operators shall hold the TR NO_x Annual allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.</p> <p>(iii). Total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the State during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the state NO_x Annual trading budget under 40 CFR 97.410(a) and the state's variability limit under 40 CFR 97.410(b).</p> <p>(iv). It shall not be a violation of 40 CFR part 97, subpart AAAAA or of the Clean Air Act if total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the State during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the TR NO_x Annual units at TR NO_x Annual sources in the state during a control period exceeds the common designated representative's assurance level.</p> <p>(v). To the extent the owners and operators fail to hold TR NO_x Annual allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,</p> <p style="padding-left: 40px;">(A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and</p> <p style="padding-left: 40px;">(B). Each TR NO_x Annual allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.</p> <p>(3) Compliance periods.</p> <p style="padding-left: 40px;">(i). A TR NO_x Annual unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015, or the deadline for meeting</p>
--	---

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.</p> <p>(ii). A TR NO_x Annual unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.</p> <p>(4) Vintage of allowances held for compliance.</p> <p>(i). A TR NO_x Annual allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO_x Annual allowance that was allocated for such control period or a control period in a prior year.</p> <p>(ii). A TR NO_x Annual allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO_x Annual allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.</p> <p>(5) Allowance Management System requirements. Each TR NO_x Annual allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart AAAAA.</p> <p>(6) Limited authorization. A TR NO_x Annual allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:</p> <p>(i). Such authorization shall only be used in accordance with the TR NO_x Annual Trading Program; and</p> <p>(ii). Notwithstanding any other provision of 40 CFR part 97, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.</p> <p>(7) Property right. A TR NO_x Annual allowance does not constitute a property right.</p> <p>(d) Title V permit revision requirements.</p> <p>(1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO_x Annual allowances in accordance with 40 CFR part 97, subpart AAAAA.</p> <p>(2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR</p>
--	--

**CONSTELLATION POWER SOURCE GENERATION, LLC
 PERRYMAN GENERATING STATION
 900 CHELSEA ROAD, PERRYMAN, MD 21130
 PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

97.430 through 97.435, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.406(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (i). The certificate of representation under 40 CFR 97.416 for the designated representative for the source and each TR NO_x Annual unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.416 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart AAAAA.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO_x Annual Trading Program.

- (2) The designated representative of a TR NO_x Annual source and each TR NO_x Annual unit at the source shall make all submissions required under the TR NO_x Annual Trading Program, except as provided in 40 CFR 97.418. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

(f) Liability.

- (1) Any provision of the TR NO_x Annual Trading Program that applies to a TR NO_x Annual source or the designated representative of a TR NO_x Annual source shall also apply to the owners and operators of such source and of the TR NO_x Annual units at the source.
- (2) Any provision of the TR NO_x Annual Trading Program that applies to a TR NO_x Annual unit or the designated representative of a TR NO_x Annual unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the TR NO_x Annual Trading Program or exemption under 40 CFR 97.405 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO_x Annual source or TR NO_x Annual unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

B. 40 CFR Part 97 Subpart BBBB-TR NO_x Ozone Season Trading Program

TR NO_x Ozone Season Trading Program Requirements (40 CFR 97.506)

(a) Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.513 through 97.518.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

- (1) The owners and operators, and the designated representative, of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.530 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.531 (initial monitoring system certification and recertification procedures), 97.532 (monitoring system out-of-control periods), 97.533 (notifications concerning monitoring), 97.534 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.535 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).
- (2) The emissions data determined in accordance with 40 CFR 97.530 through 97.535 shall be used to calculate allocations of TR

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

NO_x Ozone Season allowances under 40 CFR 97.511(a)(2) and (b) and 97.512 and to determine compliance with the TR NO_x Ozone Season emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.530 through 97.535 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) NO_x emissions requirements.

(1) TR NO_x Ozone Season emissions limitation.

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, TR NO_x Ozone Season allowances available for deduction for such control period under 40 CFR 97.524(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Ozone Season units at the source.
- (ii). If total NO_x emissions during a control period in a given year from the TR NO_x Ozone Season units at a TR NO_x Ozone Season source are in excess of the TR NO_x Ozone Season emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - (A). The owners and operators of the source and each TR NO_x Ozone Season unit at the source shall hold the TR NO_x Ozone Season allowances required for deduction under 40 CFR 97.524(d); and
 - (B). The owners and operators of the source and each TR NO_x Ozone Season unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart BBBBB and the Clean Air Act.

(2) TR NO_x Ozone Season assurance provisions.

- (i). If total NO_x emissions during a control period in a given year from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO_x Ozone Season allowances available for deduction for such control period under 40 CFR 97.525(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.525(b), of multiplying—</p> <p>(A). The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and</p> <p>(B). The amount by which total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state for such control period exceed the state assurance level.</p> <p>(ii). The owners and operators shall hold the TR NO_x Ozone Season allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.</p> <p>(iii). Total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the State NO_x Ozone Season trading budget under 40 CFR 97.510(a) and the state's variability limit under 40 CFR 97.510(b).</p> <p>(iv). It shall not be a violation of 40 CFR part 97, subpart BBBBBB or of the Clean Air Act if total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the TR NO_x Ozone Season units at</p>
--	--

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>TR NO_x Ozone Season sources in the state during a control period exceeds the common designated representative's assurance level.</p> <p>(v). To the extent the owners and operators fail to hold TR NO_x Ozone Season allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,</p> <p>(A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and</p> <p>(B). Each TR NO_x Ozone Season allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart BBBBB and the Clean Air Act.</p> <p>(3) Compliance periods.</p> <p>(i). A TR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of May 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.530(b) and for each control period thereafter.</p> <p>(ii). A TR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.530(b) and for each control period thereafter.</p> <p>(4) Vintage of allowances held for compliance.</p> <p>(i). A TR NO_x Ozone Season allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO_x Ozone Season allowance that was allocated for such control period or a control period in a prior year.</p> <p>(ii). A TR NO_x Ozone Season allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO_x Ozone Season allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.</p> <p>(5) Allowance Management System requirements. Each TR NO_x Ozone Season allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart</p>
--	---

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>BBBBB.</p> <p>(6) Limited authorization. A TR NO_x Ozone Season allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:</p> <ul style="list-style-type: none"> (i). Such authorization shall only be used in accordance with the TR NO_x Ozone Season Trading Program; and (ii). Notwithstanding any other provision of 40 CFR part 97, subpart BBBBB, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act. <p>(7) Property right. A TR NO_x Ozone Season allowance does not constitute a property right.</p> <p>(d) Title V permit revision requirements.</p> <p>(1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO_x Ozone Season allowances in accordance with 40 CFR part 97, subpart BBBBB.</p> <p>(2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.530 through 97.535, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.506(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).</p> <p>(e) Additional recordkeeping and reporting requirements.</p> <p>(1) Unless otherwise provided, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.</p> <ul style="list-style-type: none"> (i). The certificate of representation under 40 CFR 97.516 for the designated representative for the source and each TR NO_x
--	--

**CONSTELLATION POWER SOURCE GENERATION, LLC
 PERRYMAN GENERATING STATION
 900 CHELSEA ROAD, PERRYMAN, MD 21130
 PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.516 changing the designated representative.</p> <p>(ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart BBBBB.</p> <p>(iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO_x Ozone Season Trading Program.</p> <p>(2) The designated representative of a TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall make all submissions required under the TR NO_x Ozone Season Trading Program, except as provided in 40 CFR 97.518. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.</p> <p>(f) Liability.</p> <p>(1) Any provision of the TR NO_x Ozone Season Trading Program that applies to a TR NO_x Ozone Season source or the designated representative of a TR NO_x Ozone Season source shall also apply to the owners and operators of such source and of the TR NO_x Ozone Season units at the source.</p> <p>(2) Any provision of the TR NO_x Ozone Season Trading Program that applies to a TR NO_x Ozone Season unit or the designated representative of a TR NO_x Ozone Season unit shall also apply to the owners and operators of such unit.</p> <p>(g) Effect on other authorities.</p> <p>No provision of the TR NO_x Ozone Season Trading Program or exemption under 40 CFR 97.505 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO_x Ozone Season source or TR NO_x Ozone Season unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.</p>
--	--

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)	
	<p>C. 40 CFR Part 97 Subpart CCCC-TR SO₂ Group 1 Trading Program TR SO₂ Group 1 Trading Program requirements (40 CFR 97.606)</p> <p>(a) Designated representative requirements. The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.613 through 97.618.</p> <p>(b) Emissions monitoring, reporting, and recordkeeping requirements.</p> <p>(1) The owners and operators, and the designated representative, of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.630 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.631 (initial monitoring system certification and recertification procedures), 97.632 (monitoring system out-of-control periods), 97.633 (notifications concerning monitoring), 97.634 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.635 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).</p> <p>(2) The emissions data determined in accordance with 40 CFR 97.630 through 97.635 shall be used to calculate allocations of TR SO₂ Group 1 allowances under 40 CFR 97.611(a)(2) and (b) and 97.612 and to determine compliance with the TR SO₂ Group 1 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.630 through 97.635 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.</p> <p>(c) SO₂ emissions requirements.</p> <p>(1) TR SO₂ Group 1 emissions limitation.</p> <p>(i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall hold, in the source's compliance account, TR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all TR SO₂ Group 1 units at the source.</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>(ii). If total SO₂ emissions during a control period in a given year from the TR SO₂ Group 1 units at a TR SO₂ Group 1 source are in excess of the TR SO₂ Group 1 emissions limitation set forth in paragraph (c)(1)(i) above, then:</p> <p>(A). The owners and operators of the source and each TR SO₂ Group 1 unit at the source shall hold the TR SO₂ Group 1 allowances required for deduction under 40 CFR 97.624(d); and</p> <p>(B). The owners and operators of the source and each TR SO₂ Group 1 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation 40 CFR part 97, subpart CCCCC and the Clean Air Act.</p> <p>(2) TR SO₂ Group 1 assurance provisions.</p> <p>(i). If total SO₂ emissions during a control period in a given year from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such SO₂ emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.625(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.625(b), of multiplying—</p> <p>(A). The quotient of the amount by which the common designated representative's share of such SO₂ emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such SO₂ emissions exceeds the respective common designated representative's assurance level; and</p>
--	---

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>(B). The amount by which total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state for such control period exceed the state assurance level.</p> <p>(ii). The owners and operators shall hold the TR SO₂ Group 1 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.</p> <p>(iii). Total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period in a given year exceed the state assurance level if such total SO₂ emissions exceed the sum, for such control period, of the state SO₂ Group 1 trading budget under 40 CFR 97.610(a) and the state's variability limit under 40 CFR 97.610(b).</p> <p>(iv). It shall not be a violation of 40 CFR part 97, subpart CCCCC or of the Clean Air Act if total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total SO₂ emissions from the TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period exceeds the common designated representative's assurance level.</p> <p>(v). To the extent the owners and operators fail to hold TR SO₂ Group 1 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,</p> <p style="padding-left: 20px;">(A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and</p> <p style="padding-left: 20px;">(B). Each TR SO₂ Group 1 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart CCCCC and the Clean Air Act.</p> <p>(3) Compliance periods.</p> <p style="padding-left: 20px;">(i). A TR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.</p> <p style="padding-left: 20px;">(ii). A TR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting</p>
--	--

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

	<p>on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.</p> <p>(4) Vintage of allowances held for compliance.</p> <p style="padding-left: 20px;">(i). A TR SO₂ Group 1 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR SO₂ Group 1 allowance that was allocated for such control period or a control period in a prior year.</p> <p style="padding-left: 20px;">(ii). A TR SO₂ Group 1 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR SO₂ Group 1 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.</p> <p>(5) Allowance Management System requirements. Each TR SO₂ Group 1 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart CCCCC.</p> <p>(6) Limited authorization. A TR SO₂ Group 1 allowance is a limited authorization to emit one ton of SO₂ during the control period in one year. Such authorization is limited in its use and duration as follows:</p> <p style="padding-left: 20px;">(i). Such authorization shall only be used in accordance with the TR SO₂ Group 1 Trading Program; and</p> <p style="padding-left: 20px;">(ii). Notwithstanding any other provision of 40 CFR part 97, subpart CCCCC, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.</p> <p>(7) Property right. A TR SO₂ Group 1 allowance does not constitute a property right.</p> <p>(d) Title V permit revision requirements.</p> <p>(1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR SO₂ Group 1 allowances in accordance with 40 CFR part 97, subpart CCCCC.</p> <p>(2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.630 through 97.635, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR part 75.19), and an</p>
--	---

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)

alternative monitoring system (pursuant to 40 CFR part 75, subpart E), Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.606(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (i). The certificate of representation under 40 CFR 97.616 for the designated representative for the source and each TR SO₂ Group 1 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.616 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart CCCCC.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR SO₂ Group 1 Trading Program.
- (2) The designated representative of a TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall make all submissions required under the TR SO₂ Group 1 Trading Program, except as provided in 40 CFR 97.618. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

(f) Liability.

- (1) Any provision of the TR SO₂ Group 1 Trading Program that applies to a TR SO₂ Group 1 source or the designated representative of a TR SO₂ Group 1 source shall also apply to the owners and operators of such source and of the TR SO₂ Group 1 units at the source.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)	
	<p>(2) Any provision of the TR SO₂ Group 1 Trading Program that applies to a TR SO₂ Group 1 unit or the designated representative of a TR SO₂ Group 1 unit shall also apply to the owners and operators of such unit.</p> <p>(g) Effect on other authorities. No provision of the TR SO₂ Group 1 Trading Program or exemption under 40 CFR 97.605 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR SO₂ Group 1 source or TR SO₂ Group 1 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.</p>
7.2	<p><u>Testing Requirements:</u></p> <p>A, B & C: See Monitoring Requirements.</p>
7.3	<p><u>Monitoring Requirements:</u></p> <p>A. 40 CFR Part 97 Subpart AAAAA-TR NO_x Annual Trading Program The Permittee shall comply with the monitoring requirements found in §97.406, §97.430, and §97.434 for the NO_x Annual Trading Program.</p> <p>B. 40 CFR Part 97 Subpart BBBB-TR NO_x Ozone Season Trading Program The Permittee shall comply with the monitoring requirements found in §97.506, §97.530, and §97.534 for the NO_x Ozone Season Trading Program.</p> <p>C. 40 CFR Part 97 Subpart CCCC-TR SO₂ Group 1 Trading Program The Permittee shall comply with the monitoring requirements found in §97.606, §97.630, §97.631, §97.632, and §97.633.</p> <p>The Permittee operates continuous emission monitoring system (CEMS) pursuant to 40 CFR Part 75, Subpart B (for SO₂ monitoring) and 40 CFR Part 75, Subpart H (for NO_x monitoring).</p>
7.4	<p><u>Record Keeping Requirements:</u></p> <p>A. 40 CFR Part 97 Subpart AAAAA-TR NO_x Annual Trading Program The Permittee shall comply with the recordkeeping requirements found in §97.406, §97.430, and §97.434 for the NO_x Annual Trading Program.</p>

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

Table IV-7: Cross State Air Pollution Rule (CSAPR)	
	<p>B. 40 CFR Part 97 Subpart BBBB-TR NO_x Ozone Season Trading Program The Permittee shall comply with the recordkeeping requirements found in §97.506, §97.530, and §97.534 for the NO_x Ozone Season Trading Program.</p> <p>C. 40 CFR Part 97 Subpart CCCC-TR SO₂ Group 1 Trading Program The Permittee shall comply with the recordkeeping requirements found in §97.606, §97.630, and §97.634.</p>
7.5	<p><u>Reporting Requirements:</u></p> <p>A. 40 CFR Part 97 Subpart AAAA-TR NO_x Annual Trading Program The Permittee shall comply with the reporting requirements found in §97.406, §97.430, §97.433 and §97.434 for the NO_x Annual Trading Program.</p> <p>B. 40 CFR Part 97 Subpart BBBB-TR NO_x Ozone Season Trading Program The Permittee shall comply with the reporting requirements found in §97.506, §97.530, §97.533, and §97.534 for the NO_x Ozone Season Trading Program.</p> <p>C. 40 CFR Part 97 Subpart CCCC-TR SO₂ Group 1 Trading Program The Permittee shall comply with the reporting requirements found in §97.606, §97.630, §97.633 and §97.634.</p>

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

SECTION V INSIGNIFICANT ACTIVITIES

This section provides a list of insignificant emissions units that were reported in the Title V permit application. The applicable Clean Air Act requirements, if any, are listed below the insignificant activity.

- (1) No. 2 Stationary internal combustion engines with an output less than 500 brake horsepower (373 kilowatts) and which are not used to generate electricity for sale or for peak or load shaving;

The *affected units* are subject to the following requirements:

- (A) COMAR 26.11.09.05E(2), Emissions During Idle Mode: The Permittee may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.
- (B) COMAR 26.11.09.05E(3), Emissions During Operating Mode: The Permittee may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.
- (C) Exceptions:
 - (i) COMAR 26.11.09.05E(2) does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system.
 - (ii) COMAR 26.11.09.05E(2) does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods:
 - (a) Engines that are idled continuously when not in service: 30 minutes
 - (b) all other engines: 15 minutes.
 - (iii) COMAR 26.11.09.05E(2) & (3) do not apply while maintenance, repair or testing is being performed by qualified mechanics.

- (2) ✓ Space heaters utilizing direct heat transfer and used solely for comfort heat;

- (3) ✓ Charbroilers and pit barbecues as defined in COMAR 26.11.18.01 with a total cooking area of 5 square feet (0.46 square meter) or less;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

- (4) ✓ Comfort air conditioning subject to requirements of Title VI of the Clean Air Act;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
900 CHELSEA ROAD, PERRYMAN, MD 21130
PART 70 OPERATING PERMIT NO. 24-025-0024**

SECTION VI STATE-ONLY ENFORCEABLE CONDITIONS

The Permittee is subject to the following State-only enforceable requirements:

1. Applicable Regulations:

COMAR 26.11.06.08 - Nuisance.

"An installation or premises may not be operated or maintained in such a manner that a nuisance or air pollution is created. Nothing in this regulation relating to the control of emissions may in any manner be construed as authorizing or permitting the creation of, or maintenance of, nuisance or air pollution."

COMAR 26.11.06.09 - Odors.

"A person may not cause or permit the discharge into the atmosphere of gases, vapors, or odors beyond the property line in such a manner that a nuisance or air pollution is created."

2. Operating Conditions:

Annotated Code of Maryland, Environment, Title 2, and Subtitle 5 – Temporary Fuel Variances. The Permittee may file a petition to the Department to request a temporary fuel variance in accordance with the procedures specified under this subtitle.

3. CO₂ Budget Permit

The Permittee shall comply with the requirements of the CO₂ Budget Permit issued for Perryman Generating Station. Note: A CO₂ Budget Permit will be issued in conjunction with this Part 70 permit and is attached to the Part 70 permit as Appendix C.

4. Record Keeping and Reporting:

The Permittee shall submit to the Department, by April 1 of each year during the term of this permit, a written certification of the results of an analysis of emissions of toxic air pollutants from the Permittee's facility during the previous calendar year. The analysis shall include either:

- (a) a statement that previously submitted compliance demonstrations for emissions of toxic air pollutants remain valid; or
- (b) a revised compliance demonstration, developed in accordance with requirements included under COMAR 26.11.15 & 16, that accounts for changes in operations, analytical methods, emissions determinations, or other factors that have invalidated previous demonstrations.

Maryland Department of the Environment
Air and Radiation Administration

CO₂ BUDGET TRADING PROGRAM PERMIT

Plant Name: Perryman Generating Station	
Affected Trading Units: CT1, CT2, CT3, CT4, 00XX51, CT6A & CT6B	
Owner: Constellation Power Source Generation, LLC	ORIS Code 1556
Effective Date From: November 1, 2018 To: October 31, 2023	

Contents:

1. Statement of Basis
2. Table of Affected Units
3. Standard Requirements.
4. The permit application forms submitted for this source.

1. Statement of Basis

Statutory and Regulatory Authorities: In accordance with Environmental Article §2-401, Annotated Code of Maryland, the Maryland Department of the Environment, Air and Radiation Administration issues this permit pursuant to COMAR 26.09.01 thru COMAR 26.09.04.

Initial Permit Approval



f George S. Aburn, Jr., Director
Air and Radiation Administration

NOV - 1 2018

Date of Issue

2. Affected Units

Unit ID #	ARA ID #	Unit Description
CT1	4-0081	51 MW (nominal) output; No. 2 fuel oil-fired simple cycle combustion turbine.
CT2	4-0082	51 MW (nominal) output; No. 2 fuel oil-fired simple cycle combustion turbine.
CT3	4-0083	51 MW (nominal) output; No. 2 fuel oil-fired simple cycle combustion turbine.
CT4	4-0084	51 MW (nominal) output; No. 2 fuel oil-fired simple cycle combustion turbine.
00XX51	5-0088	140 MW (nominal) output; Natural gas-fired with No. 2 fuel oil back-up simple cycle combustion turbine.
CT6A	5-0353	60 MW (nominal) output; Natural gas-fired with ultra-low sulfur diesel (ULSD) fuel oil during periods when natural gas has been interrupted simple cycle combustion turbine.
CT6B	5-0354	60 MW (nominal) output; Natural gas-fired with ultra-low sulfur diesel (ULSD) fuel oil during periods when natural gas has been interrupted simple cycle combustion turbine.

3. Standard Requirements:

A. Selection and Responsibilities of CO₂ Budget Source Compliance Account Authorized Account Representatives.

- (1) Each CO₂ budget source shall have a CO₂ authorized account representative and an alternate CO₂ authorized account representative. (COMAR 26.09.01.04B)
- (2) Upon receipt of a complete account certificate of representation:
 - (a) The CO₂ authorized account representative and alternate CO₂ authorized account representative shall represent and, by representations, actions, inactions, or submissions, legally bind each owner or operator of the CO₂ budget source represented and each CO₂ budget unit at the source in all matters pertaining to this subtitle, notwithstanding any agreement between the CO₂

authorized account representative, alternate CO₂ authorized account representative, and the owners or operators; and

- (b) The owners or operators shall be bound by any decision or order issued to the CO₂ authorized account representative or alternate CO₂ authorized account representative by the Department or a court regarding the CO₂ budget source or unit.
(COMAR 26.09.01.04E (1) & (2))
- (3) A CO₂ budget permit may not be issued or a compliance account established for a CO₂ budget source until the Department has received a complete account certificate of representation for a CO₂ authorized account representative and alternate CO₂ authorized account representative of the source and the CO₂ budget units at the source. (COMAR 26.09.01.04F)
- (4) Each submission shall be signed and certified by the CO₂ authorized account representative or alternate CO₂ authorized account representative on behalf of each CO₂ budget source and shall include the following statement by the CO₂ authorized account representative or alternate CO₂ authorized account representative: "I am authorized to make the submission on behalf of the owners or operators of the CO₂ budget sources or CO₂ budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in the document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."
(COMAR 26.09.01.04G)

B. Distribution Of CO₂ Allowances And Compliance

- (1) Unless otherwise specified in this chapter, a CO₂ budget source shall demonstrate compliance with its CO₂ budget emissions limitation by holding one CO₂ allowance in its compliance account for every ton of CO₂ that it emits in a control period, by the allowance transfer deadline for that control period. (COMAR 26.09.02.03I(1))
- (2) As of the CO₂ allowance transfer deadline for an interim control period, the owners and operators of each CO₂ budget source and each CO₂ budget unit at the source shall hold, in the source's compliance account for deduction under §I of this regulation, CO₂ allowances for no less than 50 percent of the total CO₂ emissions for the interim control period from all CO₂ budget units at the source. (COMAR 26.09.02.03I(2))
- (3) Allowances Available for Compliance Deduction. The following CO₂ allowances may be deducted from a compliance account for purposes of complying with a budget source's CO₂ budget emissions limitation for a control period or an interim control period:
 - (a) CO₂ allowances that are not CO₂ offset allowances and are identified as allowances falling within a prior control period, the same control period, or the same interim control period for which the allowances are deducted;
 - (b) CO₂ allowances that are held or transferred into the CO₂ budget source's compliance account as

- of the CO₂ allowance transfer deadline for that control period or for the interim control period contained within that control period;
- (c) CO₂ offset allowances that are available to be deducted for compliance during a control period or an interim control period where the quantity of allowances is limited to:
- (i) 3.3 percent of the CO₂ budget source's CO₂ emissions for that control period; or
 - (ii) 3.3 percent of the CO₂ budget source's CO₂ emissions for an interim control period multiplied by 0.50.
(COMAR 26.09.02.03I(3)(a)-(c))
- (4) Deduction of CO₂ allowances:
- (a) The Department shall deduct allowances from the CO₂ budget source's compliance account until:
 - (i) The number of CO₂ allowances deducted equals 50 percent of the total CO₂ emissions for an interim control period; or
 - (ii) The number of CO₂ allowances deducted equals the total CO₂ emissions for the control period.
 - (b) No deduction shall be made for CO₂ emissions attributable to the burning of eligible biomass.
(COMAR 26.09.02.03I(4)(a) & (b))
- (5) The identification of available CO₂ allowances for compliance deduction by serial number or by default is as follows:
- (a) The CO₂ authorized account representative for a source's compliance account may request that specific CO₂ allowances, identified by serial number for a control period or interim control period, be deducted; and
 - (b) In the absence of an identification or in the case of a partial identification of available CO₂ allowances by serial number, the Department shall deduct CO₂ allowances for a control period or interim control period in the following descending order:
 - (i) For the first control period, all CO₂ allowances purchased by direct sale from the Department during years 2009, 2010, and 2011 resulting from the occurrence of the \$7 auction clearing price;
 - (ii) All CO₂ allowances for a control period allocated to a CO₂ budget unit from the Long Term Contract Set-aside Account or the Clean Generation Set-aside Account;
 - (iii) Subject to the relevant compliance deduction limitations identified in §I(3)(c) of this regulation, any CO₂ offset allowances transferred and recorded in the compliance account, in chronological order; and
 - (iv) Any CO₂ allowances, other than those identified in §I(5)(b)(i)—(iii) of this regulation, that

are available for deduction in the order they were recorded.
(COMAR 26.09.02.031(5)(a)-(b))

(6) Deductions for Excess Emissions.

- (a) If a CO₂ budget source has excess emissions, the Department shall deduct, from the CO₂ budget source's compliance account, CO₂ allowances from allocation years that occur after the control period or interim control period in which the excess emissions or excess interim emissions occurred, equal to three times the excess emissions.
- (b) If a source's compliance account holds insufficient CO₂ allowances to cover the excess emissions, the source shall immediately transfer sufficient allowances into its compliance account.
- (c) CO₂ offset allowances may not be deducted to account for the source's excess emissions.
- (d) No CO₂ allowance deduction shall relieve the owners or operators of the CO₂ budget units at the source of liability for any fine, penalty, assessment or obligation to comply with any other remedy, for the same violation, as ordered under applicable State law.
(COMAR 26.09.02.031(6)(a)-(d))

(7) Guidelines.

- (a) The following guidelines apply in assessing fines, penalties, or other obligations:
 - (i) For purposes of determining the number of days of violation, if a CO₂ budget unit has excess emissions for a control period or interim control period, each day in the control period or interim control period, as applicable, constitutes a separate day of violation unless the owners or operators of the unit can demonstrate to the satisfaction of the Department that a lesser number of days should be considered; and
 - (ii) The Department shall consider the amount of excess emissions in determining the severity of the violation.
 - (b) Each ton of excess interim emissions is a separate violation.
(COMAR 26.09.02.031(7)(a)-(b))
- (8) If the CO₂ budget source's compliance account no longer exists, the CO₂ allowances shall be deposited in a general account selected by the owner or operator of the CO₂ budget source.
(COMAR 26.09.02.031(8))

(9) Adjustments and Errors.

- (a) The Department may review and conduct independent audits concerning any submission under this subtitle and make appropriate adjustments to the information, if necessary.
- (b) The Department may correct any error in any account and, within 10 business days of making any correction, notify the CO₂ authorized account representative for the account.

(COMAR 26.09.02.031(9)(a)-(b))

C. Applicability and Administration

- (1) The requirements of this permit apply to the owner or operator of a CO₂ budget unit. When this permit establishes a requirement such as the submittal of a permit application, a report, a request for allowances or transfer of allowances, or general information, these actions shall be achieved through the authorized account representative on behalf of the owner or operator of the affected CO₂ budget source or unit.
(COMAR 26.09.02.02A)
- (2) The requirements of this subtitle are effective on January 1, 2009 or, for new CO₂ budget units, on the day on which the unit commences operation.
(COMAR 26.09.02.02C).
- (3) The provisions of this permit do not exempt or otherwise relieve the owners or operators of a CO₂ budget source from achieving compliance with any other provision of applicable State and federal laws and regulations.
(COMAR 26.09.02.02D).
- (4) Unless otherwise stated under this subtitle, any time period scheduled to begin:
 - (a) On the occurrence of an act or event, begins on the day the act or event occurs; and
 - (b) Before the occurrence of an act or event, is computed so that the period ends the day before the act or event occurs.
(COMAR 26.09.02.02E)
- (5) Unless otherwise stated, if the final day of any time period for performing an act required by this subtitle falls on a weekend or on a State or federal holiday, the time period is extended until or to the next business day.
(COMAR 26.09.02.02F)

D. Permit Requirements

- (1) The account representative or designate alternate account representative) of each affected unit at a source, (every fossil fuel fired unit with a nameplate capacity of 25 MW or greater) for that source shall comply with the following:
 - (a) The CO₂ authorized account representative for the source shall submit an initial CO₂ budget permit application by October 1, 2008, or 12 months before the date on which the CO₂ budget source, or a new unit at the source, commences operation.
(COMAR 26.09.02.04A(2));
 - (b) The CO₂ budget permit application shall include the following in a format prescribed by the Department: 1) the identification of the CO₂ budget source; 2) plant name and the ORIS (Office of Regulatory Information Systems) or facility code assigned to the source by the Energy Information Administration of the U. S. Department of Energy, if applicable; 3) each CO₂ budget unit at the source; and 4) other information required by the Department.
(COMAR 26.09.02.04A(3))

- (c) A CO₂ authorized account representative for the source shall submit a complete application for the renewal of an existing CO₂ budget permit on forms provided by the Department not later than 90 days before the expiration of the current CO₂ budget permit and in accordance with this regulation.
(COMAR 26.09.02.04E)
- (2) Each CO₂ budget source shall apply for and have in effect a CO₂ budget permit that contains all applicable requirements.
(COMAR 26.09.02.04A(1)).
- (3) The CO₂ budget permit issued by the Department shall be separate but attached to the budget source's Part 70 permit.
(COMAR 26.09.02.04B)
- (4) A CO₂ budget permit expires 5 years from the date of issuance by the Department, unless an earlier expiration date is specified in the permit.
(COMAR 26.09.02.04D)

E. Monitoring, Initial Certification and Recertification Requirements

- (1) For each control period in which a CO₂ budget source is subject to the CO₂ budget emissions limitation, the CO₂ authorized account representative of the source shall submit a compliance certification report by the March 1 following the relevant control period. A compliance certification report is not required as part of the compliance obligation during an interim control period.
(COMAR 26.09.02.05A(1))
- (2) The CO₂ authorized account representative shall include in the compliance certification report the following:
- (a) Identification of the source and each CO₂ budget unit at the source;
 - (b) At the CO₂ authorized account representative's option, the serial numbers of the CO₂ allowances that are to be deducted from the source's compliance account for the control period, including the serial numbers of any CO₂ offset allowances that are to be deducted subject to applicable limitations; and
 - (c) The compliance certification required by §A(3) of COMAR 26.09.02.05.
(COMAR 26.09.02.05A(2))
- (3) In the compliance certification report, the CO₂ authorized account representative shall certify whether the source and each CO₂ budget unit at the source for which the compliance certification is submitted was operated during the control period in compliance with the requirements of this subtitle, including:
- (a) Whether each CO₂ budget unit at the source was operated in compliance with the CO₂ budget emissions limitation;

- (b) Whether the monitoring plan applicable to each unit at the source: (i) has been maintained to reflect the actual operation and monitoring of the unit; and (ii) contains all information necessary to track CO₂ emissions from the unit;
- (c) Whether all CO₂ emissions from each unit at the source were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including: (i) whether all conditional data was reported in the quarterly reports; or (ii) if conditional data were reported, whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;
- (d) Whether the basis for certification or for using an excepted monitoring method or approved alternative monitoring method has changed; and
- (e) If a change is required to be reported, include: (i) the nature and reasons for the change; (ii) when the change occurred; and (iii) how the unit's compliance status was determined after the change, including the method used to determine emissions when a change mandated the need for monitor recertification.
(COMAR 26.09.02.05A (3) (a)-(e))
- (4) The Department, at its discretion, may review and conduct independent audits of any compliance certification or other submission required by this permit.
(COMAR 26.09.02.05B(1))
- (5) The Department may deduct CO₂ allowances from, or transfer CO₂ allowances to, a compliance account to correct errors in the account or to accurately reflect CO₂ emissions, based on the information in the compliance certification or other submissions.
(COMAR 26.09.02.05B(2))
- (6) The owner or operator of a CO₂ budget unit shall:
- (a) Install monitoring systems to monitor CO₂ concentration, stack gas flow rate, oxygen concentration, heat input, and fuel flow rate;
- (b) Install all monitoring systems in accordance with 40 CFR Part 75, except for equation G-1 in Appendix G (see below); and

$$W_{CO_2} = \frac{(MW_C + MW_{O_2}) \times W_C}{2,000 MW_C} \text{ (Eq. G-1)}$$

Where:

W_{CO₂}=CO₂ emitted from combustion, tons/day.

MW_C=Molecular weight of carbon (12.0).

MW_{O₂}=Molecular weight of oxygen (32.0)

W_C= Carbon burned, lb/day, determined using fuel sampling and analysis and fuel feed rates.

- (c) Record, report, and verify the data from the monitoring systems.
(COMAR 26.09.02.10A(1)(a)-(c))
- (7) Install and certify the monitoring system on or before the following dates:

- (a) For a CO₂ budget unit that commences commercial operation before July 1, 2008, the owner or operator shall comply on or before January 1, 2009; and
 - (b) For a CO₂ budget unit that commences commercial operation or constructs a new stack or flue on or after July 1, 2008, the owner or operator shall comply by January 1, 2009, or 90 operating days after the date on which the unit commences commercial operation.
(COMAR 26.09.02.10A(1)(d))
- (8) The owner or operator of a CO₂ budget unit that does not meet the applicable compliance date shall, in accordance with the provisions in 40 CFR §75.31(b)(2) or (c)(3), or §2.4 of Appendix D, determine, record, and report maximum potential or, as appropriate, minimum potential for the following:
- (a) CO₂ concentration;
 - (b) CO₂ emissions rate;
 - (c) Stack gas moisture content;
 - (d) Fuel flow rate; and
 - (e) Any other parameter required to determine CO₂ mass emissions.
(COMAR 26.09.02.10A(2)(a)-(e))
- (9) The owner or operator of a CO₂ budget unit that does not meet the applicable compliance date for any monitoring system shall determine, record, and report substitute data using the applicable missing data procedures in 40 CFR Part 75 Subpart D, or Appendix D, instead of the maximum potential values or, as appropriate, minimum potential values for a parameter, if the owner or operator demonstrates that there is continuity between the data streams for that parameter before and after the construction or installation.
(COMAR 26.09.02.10A(3))
- (10) An owner or operator of a CO₂ budget unit or a non-CO₂ budget unit monitored under 40 CFR §75.72 (b) (2) (ii) may not:
- (a) Use any alternative monitoring system, alternative reference method, or any other alternative for the required continuous emissions monitoring system without having obtained prior written approval from the Department;
 - (b) Operate the unit so as to discharge, or allow to be discharged, CO₂ emissions to the atmosphere without accounting for all emissions in accordance with the applicable provisions of this chapter and 40 CFR Part 75;
 - (c) Disrupt the operation of the CEMS, any portion of the CEMS, or any other approved emissions monitoring method, and thereby avoid monitoring and recording CO₂ mass emissions discharged into the atmosphere, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed; or

- (d) Permanently discontinue use of the approved CEMS unless the owner or operator monitors emissions with a system approved in accordance with this chapter and 40 CFR Part 75.
(COMAR 26.09.02.10A(4)(a)-(d))
- (11) For purposes of this subtitle only, the owner or operator of a CO₂ budget unit is exempt from demonstrating compliance with the initial certification requirements of 40 CFR §75.20 for a monitoring system if the following conditions are met:
- (a) The monitoring system has been previously certified in accordance with 40 CFR §75.20; and
- (b) The applicable quality assurance and quality-control requirements of 40 CFR §75.21 and Appendix B and Appendix D of 40 CFR Part 75 are fully met for the certified monitoring system.
(COMAR 26.09.02.10B(1)(a)-(b))
- (12) The recertification provisions of this regulation apply to a monitoring system exempt from the initial certification requirements of this regulation.
(COMAR 26.09.02.10B(2))
- (13) If the Department has previously approved a petition under 40 CFR §75.72(b)(2)(ii) or 40 CFR §75.16(b)(2)(ii)(B) pursuant to 40 CFR §75.13 for apportioning the CO₂ emissions rate measured in a common stack or a petition under 40 CFR §75.66 for an alternative requirement in 40 CFR Part 75, the CO₂ authorized account representative shall resubmit the petition to the Department to determine whether the approval applies under this chapter.
(COMAR 26.09.02.10B(3))
- (14) The owner or operator of a CO₂ budget unit shall comply with the initial certification and recertification procedures for a CEMS and an excepted monitoring system under 40 CFR Part 75, Appendix D.
(COMAR 26.09.02.10B(4))
- (15) The owner or operator of a unit that qualifies to use the low mass emissions excepted monitoring methodology in 40 CFR §75.19 or that qualifies to use an alternative monitoring system under 40 CFR Part 75, Subpart E, shall comply with this regulation.
(COMAR 26.09.02.10 B(5))
- (16) When the owner or operator replaces, modifies, or changes a CEMS that the Department determines significantly affects the ability of the system to accurately measure or record CO₂ mass emissions or to meet the quality assurance and quality control requirements of 40 CFR §75.21 or Appendix B, the owner or operator shall recertify the monitoring system according to 40 CFR §75.20(b).
(COMAR 26.09.02.10C(1))
- (17) When the owner or operator replaces, modifies, or changes the flue gas handling system or the unit's operation in a manner that the Department determines has significantly changed the flow or concentration profile, the owner or operator shall recertify the CEMS according to 40 CFR §75.20(b).

(COMAR 26.09.02.10C(2))

(18) Approval Process for Initial Certifications and Recertification. The procedures in 40 CFR §75.20(b)(5) and (g)(7) apply for recertification. The CO₂ authorized account representative shall submit to the Department:

(a) A written notice of the dates of certification; and

(b) A recertification application for each monitoring system, including the information specified in 40 CFR §75.63.

(COMAR 26.09.02.10C(3)(a)-(b))

(19) Provisional certification data for a monitor shall be:

(a) Determined in accordance with 40 CFR §75.20(a)(3);

(b) A provisionally certified monitor may be used for a period not to exceed 120 days after receipt of the complete certification application for the monitoring system or component; and

(c) Data measured and recorded by the provisionally certified monitoring system or component is considered valid quality assured data, retroactive to the date and time of provisional certification, if the Department does not issue a notice of disapproval within 120 days of receipt of the complete certification application.

(COMAR 26.09.02.10C(4)(a)-(c))

(20) The Department shall issue a written notice of approval or disapproval of the certification application to the owner or operator within 120 days of receipt of the complete certification application.

(COMAR 26.09.02.10D(1))

(21) If the Department does not issue the notice within the 120-day period, each monitoring system that meets the applicable performance requirements of 40 CFR Part 75 and is included in the certification application shall be deemed certified for use.

(COMAR 26.09.02.10D(2))

(22) If the certification application is complete and shows that each monitoring system meets the applicable performance requirements of 40 CFR Part 75, the Department shall issue a written notice of approval of the certification application within 120 days of receipt.

(COMAR 26.09.02.10D(3))

(23) If the certification application is not complete, the Department shall issue a written notice of incompleteness that sets a reasonable date by which the CO₂ authorized account representative is to submit the additional information required to complete the certification application.

(COMAR 26.09.02.10D(4))

(24) If the CO₂ authorized account representative does not comply with the notice of incompleteness by the specified date, the Department may issue a notice of disapproval.

(COMAR 26.09.02.10D(5))

- (25) If the Department issues a notice of disapproval of a certification application or a notice of disapproval of certification status, the owner or operator shall substitute the following values for each disapproved monitoring system, for each hour of unit operation during the period of invalid data beginning with the date and hour of provisional certification and continuing until the time, date, and hour specified under 40 CFR §75.20(a)(5)(i) or 75.20(g)(7):
- (a) For units using or intending to monitor for CO₂ mass emissions using heat input or for units using the low mass emissions excepted methodology under 40 CFR §75.19, the maximum potential hourly heat input of the unit; or
 - (b) For units intending to monitor for CO₂ mass emissions using a CO₂ pollutant concentration monitor and a flow monitor, the maximum potential concentration of CO₂ and the maximum potential flow rate of the unit under 40 CFR Part 75, Appendix A, §2.1.
(COMAR 26.09.02.10 D(6)(a)-(b))
- (26) The CO₂ authorized account representative shall submit a notification of certification retest dates and a new certification application. The owner or operator shall repeat all certification tests or other requirements that were failed by the monitoring system, as indicated in the Department's notice of disapproval, not later than 30 operating days after the date of issuance of the notice of disapproval.
(COMAR 26.09.02.10D(7))
- (27) The owner or operator of a unit qualified to use the low mass emissions excepted methodology under 40 CFR §75.19 shall meet the applicable certification and recertification requirements of 40 CFR §§75.19(a) (2) and 75.20(h).
(COMAR 26.09.02.10E(1))
- (28) If the owner or operator of this unit elects to certify a fuel flow meter system for heat input determinations, the owner or operator shall also meet the certification and recertification requirements in 40 CFR §75.20(g).
(COMAR 26.09.02.10E(2))
- (29) Certification and Recertification Procedures for Alternative Monitoring Systems. For each unit for which the owner or operator intends to use an alternative monitoring system approved by the Department, 40 CFR Part 75, Subpart E, shall be used to comply with the applicable notification and application procedures of 40 CFR §75.20(f).
(COMAR 26.09.02.10F)
- (30) When any monitoring system fails to meet the quality assurance and quality control requirements or data validation requirements of 40 CFR Part 75, data shall be substituted using the applicable procedures in 40 CFR Part 75, Subpart D, Appendix D.
(COMAR 26.09.02.10G(1))
- (31) Audit Decertification.
- (a) Whenever both an audit of a monitoring system and a review of the initial certification or recertification application reveal that any monitoring system should not have been certified or recertified because it did not meet a particular performance specification or the applicable

provisions of 40 CFR Part 75, both at the time of the initial certification or recertification application submission and at the time of the audit, the Department shall issue a notice of disapproval of the certification status of the monitoring system.

- (b) By issuing the notice of disapproval, the certification status of the monitoring system is prospectively revoked.
(COMAR 26.09.02.10G(2))

- (32) The data measured and recorded by the monitoring system may not be considered valid quality-assured data from the date of issuance of the notification of the revoked certification status.
(COMAR 26.09.02.10G(3))

F. Record Keeping and Reporting Requirements

- (1) The CO₂ authorized account representative shall comply with all record-keeping and reporting requirements in COMAR 26.09.02.10 and the applicable record-keeping and reporting requirements under 40 CFR §75.73.
(COMAR 26.09.02.11A)
- (2) The CO₂ authorized account representative shall submit quarterly reports as described below in this section.
(COMAR 26.09.02.11B(1))
- (3) The report shall contain the CO₂ mass emissions data for the CO₂ budget unit in an electronic format, unless otherwise required by the Department, for each calendar quarter beginning with:
- (a) The calendar quarter covering January 1, 2009 — March 31, 2009, for a unit that commences commercial operation before July 1, 2008; or
- (b) For a unit commencing commercial operation on or after July 1, 2008, the calendar quarter corresponding to the earlier of the: (i) date of provisional certification; or (ii) applicable deadline for initial certification.
(COMAR 26.09.02.11B(2)(a)-(b))
- (c) If the quarter is the third or fourth quarter of 2008, reporting shall commence in the quarter covering January 1, 2009 through March 31, 2009.
(COMAR 26.09.02.11B(3))
- (4) The CO₂ authorized account representative shall submit each quarterly report within 30 days following the end of the calendar quarter covered by the report and in accordance with 40 CFR Part 75, Subpart H, §75.64 and 40 CFR Part 75, Subpart G except for the opacity, NO_x and SO₂ provisions.
(COMAR 26.09.02.11B(4))
- (5) The CO₂ authorized account representative shall submit a compliance certification in support of each quarterly report. The certification shall state that:
- (a) The monitoring data submitted were recorded in accordance with the applicable requirements of

- this chapter and 40 CFR Part 75, including the quality assurance procedures and specifications;
- (b) For a unit with add-on CO₂ emissions controls and for all hours where data are substituted in accordance with 40 CFR §75.34(a)(1), the add-on emissions controls were operating within the range of parameters listed in the quality assurance and quality control program under 40 CFR Part 75, Appendix B, and the substitute values do not systematically underestimate CO₂ emissions; and
 - (c) The CO₂ concentration values substituted for missing data under 40 CFR Part 75, Subpart D, do not systematically underestimate CO₂ emissions.
(COMAR 26.09.02.11B(5)(a)-(c))
- (6) The CO₂ authorized account representative of a CO₂ budget unit may submit a petition to the Department under 40 CFR §75.66 requesting approval to apply an alternative to any requirement of this chapter.
(COMAR 26.09.02.11C)
- (7) The CO₂ authorized account representative or alternate CO₂ authorized account representative of a CO₂ budget unit that burns eligible biomass as a compliance mechanism under this chapter shall report the following information for each calendar quarter:
- (a) For each shipment of solid eligible biomass fuel fired at the CO₂ budget unit:
 - (i) Total eligible biomass fuel input, on an as-fired basis, in pounds; and
 - (ii) The moisture content, on an as-fired basis, as a fraction of weight;
 - (b) For each distinct type of gaseous eligible biomass fuel fired at the CO₂ budget unit:
 - (i) The density of the biogas, on an as-fired basis, in pounds per standard cubic foot; and
 - (ii) The moisture content of the biogas, as a fraction by total weight;
 - (c) For each distinct type of eligible biomass fuel fired at the CO₂ budget unit:
 - (i) The dry basis carbon content of the fuel type, as a fraction by dry weight;
 - (ii) The dry basis higher heating value, in MMBtu per dry pound;
 - (iii) The total dry basis eligible biomass fuel input, in pounds;
 - (iv) The total eligible biomass fuel heat input; and
 - (v) Chemical analysis, including heat value and carbon content;
 - (d) The total amount of CO₂ emitted from the CO₂ budget unit due to firing eligible biomass fuel, in tons, calculated as in §D(2)(b) of this regulation;

- (e) The total heat input to the CO₂ budget unit due to firing eligible biomass fuel, in MMBtu, calculated below; and
- (f) Description and documentation of monitoring technology and fuel sampling methodology employed, including sampling frequency.
(COMAR 26.09.02.11 D(1)(a)-(f))
- (8) An owner or operator of a CO₂ budget unit shall calculate and submit on a quarterly basis the total dry weight for each distinct type of eligible biomass fired by the CO₂ budget unit during the reporting quarter:

- (a) For solid eligible biomass fuel, determined as follows:

$$F_j = \sum_{i=1}^m (1 - M_i) x F_i$$

where:

- (i) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j;
(ii) F_i = Eligible biomass as fired fuel input (pounds) for fired shipment i;
(iii) M_i = Moisture content (fraction) for fired shipment i;
(iv) i = fired fuel shipment;
(v) j = fuel type; and
(vi) m = number of shipments.

- (b) For gaseous eligible biomass fuel, as determined as follows:

$$F_j = D_j x V_j x (1 - M_j)$$

where:

- (i) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j;
(ii) D_j = Density of biogas (pounds/scf) for fuel type j;
(iii) V_j = Total volume (scf) for fuel type j;
(iv) M_j = Moisture content (fraction) for fuel type j; and
(v) j = fuel type
(COMAR 26.09.02.11D(2)(a)-(b))

- (9) The amount of CO₂ emissions that is produced from the firing of eligible biomass for any full calendar quarter, during which either no fuel other than eligible biomass is combusted or during which fuels other than eligible biomass are combusted, is determined as follows:

$$CO_2 \text{ tons} = \sum_{j=1}^n F_j x C_j x O_j \left(\frac{44 \left(\frac{g}{mol CO_2} \right)}{12 \left(\frac{g}{mol C} \right)} \right) (0.0005)$$

where:

- (a) CO₂ tons = CO₂ emissions due to firing of eligible biomass for the reporting quarter;

- (b) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j , as calculated in §D(2)(a) of this regulation;
- (c) C_j = Carbon fraction (dry basis) for fuel type j ;
- (d) O_j = Oxidation factor for eligible biomass fuel type j , derived for solid fuels based on the ash content of the eligible biomass fired and the carbon content of this ash or for gaseous eligible biomass fuels, a default oxidation factor of 0.995 may be used;

$$(e) \frac{44 \left(\frac{g}{molCO_2} \right)}{12 \left(\frac{g}{molC} \right)}$$

= The number of tons of carbon dioxide that are created when one ton of carbon is combusted;

- (f) 0.0005 = The number of short tons which is equal to one pound;
 - (g) j = Fuel type; and
 - (h) n = number of distinct fuel types.
- (COMAR 26.09.02.11D(3))

(10) Heat input due to firing of eligible biomass for each quarter shall be determined as follows:

- (a) For each distinct fuel type:

$$H_j = F_j \times HHV_j$$

where:

- (i) H_j = Heat input (MMBtu) for fuel type j ;
- (ii) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j ;
- (iii) HHV_j = Higher heating value (MMBtu/pound), dry basis, for fuel type j , as determined through chemical analysis;
- (iv) j = Fuel type.

- (b) For all fuel types:

$$HeatInputMMBtu = \sum_{j=1}^n H_j$$

where:

- (i) H_j = Heat input (MMBtu) for fuel type j ;
- (ii) j = fuel type; and
- (iii) n = number of distinct fuel types.

Fuel sampling methods and fuel sampling technology shall be consistent with the New York State Renewable Portfolio Standard Biomass Guidebook, September 2011.

(COMAR 26.09.02.11D(4)& D(5))

- (11) A CO₂ budget unit shall submit to the Department the megawatt-hour value and a statement

certifying that the megawatt-hour of electrical output reported reflects the total actual electrical output for all CO₂ budget units at the facility used by the independent system operator (ISO) to determine settlement resources of energy market participants.
(COMAR 26.09.02.11E(1))

(12) A CO₂ budget unit shall report gross hourly megawatts to the Department in the same electronic data report (EDR) for gross output as submitted to the EPA Administrator, for the operating time in the hour, added for all hours in a year.
(COMAR 26.09.02.11E(2))

(13) A CO₂ budget unit shall submit the net electrical output to the Department in accordance with this regulation. A CO₂ budget source whose electrical output is not used in the independent system operator (ISO) energy market settlement determinations shall propose a method for quantification of net electrical output.
(COMAR 26.09.02.11E(3))

(14) Report of net Steam Output.

(a) CO₂ budget sources selling steam shall use billing meters to determine net steam output or an alternative method to measure net steam output approved by the Department.

(b) If data for steam output is not available, the CO₂ budget source may report heat input, substituting useful steam output for steam output.
(COMAR 26.09.02.11E(4)(a)-(b))

(15) Each CO₂ budget source shall submit an output monitoring plan with a description and diagram that include the following:

(a) If the CO₂ budget unit monitors net electric output, the diagram shall contain all CO₂ budget units and all generators served by each CO₂ budget unit and the relationship between CO₂ budget units and generators;

(b) If a generator served by a CO₂ budget unit is also served by a nonaffected unit, the nonaffected unit and its relationship to each generator shall be indicated on the diagram;

(c) The diagram shall indicate where the net electric output is measured and include all electrical inputs and outputs to and from the plant;

(d) If net electric output is determined using a billing meter, the diagram shall show each billing meter used to determine net sales of electricity and show that all electricity measured at the point of sale is generated by the CO₂ budget units;

(e) If the CO₂ budget unit monitors net thermal output, the diagram shall indicate all steam or hot water coming into the net steam system, including steam from CO₂ budget units and nonaffected units, and all exit points of steam or hot water from the net steam system;

(f) Each input and output stream shall have an estimated temperature, pressure and phase indicator, and an enthalpy in Btu per pound;

- (g) The diagram of the net steam system shall identify all useful loads, house loads, parasitic loads, any other steam loads, and all boiler feedwater returns;
 - (h) The diagram shall represent all energy losses in the system as either usable or unusable losses;
 - (i) The diagram shall indicate all flow meters, temperature or pressure sensors, or other equipment used to calculate gross thermal output; and
 - (j) If a sales agreement is used to determine net thermal output, the diagram shall show the monitoring equipment used to determine the sales of steam.
(COMAR 26.09.02.11F(2)(a)-(j))
- (16) The description of the output monitoring system shall include:
- (a) A written description of the output system and the equations used to calculate output, and, for net thermal output systems, descriptions and justifications of each useful load;
 - (b) A detailed description of all quality assurance and quality control activities that will be performed to maintain the output system; and
 - (c) Documentation supporting any output value to be used as a missing data value if there are periods of invalid output data.
 - (d) The missing data output value shall be either zero or an output value that is likely to be lower than a measured value and approved as part of the required monitoring plan.
(COMAR 26.09.02.11F(3)(a)-(b))
- (17) A certification statement shall be submitted by the CO₂ authorized account representative stating that either:
- (a) The output monitoring system consists entirely of billing meters; or
 - (b) The output monitoring system meets one of the accuracy requirements for nonbilling meters.
(COMAR 26.09.02.11G(1)(a)-(b))
- (18) The billing meter shall record the electric or thermal output. Any electric or thermal output values reported shall be the same as the values used in billing for the output.
(COMAR 26.09.02.11G(2))
- (19) For nonbilling meters, either the output monitoring system shall meet an accuracy of within 10 percent of the reference value, or each component monitor for the output system shall meet an accuracy of within 3 percent of the full scale value, whichever is less stringent.
(COMAR 26.09.02.11G(3))
- (20) The system approach to accuracy shall include:
- (a) A determination of how the system accuracy of 10 percent is achieved using the individual

components in the system; and

- (b) Data loggers and any wattmeters used to calculate the final net electric output data or any flowmeters for steam or condensate, temperature measurement devices, absolute pressure measurement devices, and differential pressure devices used for measuring thermal energy.
(COMAR 26.09.02.11G(4) (a)-(b))
- (21) If, upon testing a piece of output measurement equipment, it is determined that the output readings are not accurate to within 3 percent of the full scale value, then the equipment shall be repaired or replaced to meet that requirement.
(COMAR 26.09.02.11G(5))
- (22) Data is invalid until the output measurement equipment passes an accuracy test or is replaced with another piece of equipment that passes the accuracy test.
(COMAR 26.09.02.11G(6))
- (23) Ongoing quality assurance and quality control activities shall be performed in order to maintain the output system.
(COMAR 26.09.02.11H(1))
- (24) If billing meters are used to determine output, quality assurance and quality control activities are not required beyond what are already performed.
(COMAR 26.09.02.11H(2))
- (25) Certain types of equipment such as potential transformers, current transformers, nozzle and venture type meters, and the primary element of an orifice plate only require an initial certification of calibration and do not require periodic recalibration unless the equipment is physically changed.
- (a) Pressure and temperature transmitters accompanying an orifice plate will require periodic retesting.
- (b) For other types of equipment, the meter accuracy shall be recalibrated or verified at least once every 2 years, unless a consensus standard allows for less frequent calibrations or accuracy tests.
- (c) For nonbilling meters, either the output monitoring system shall meet an accuracy of within 10 percent of the reference value, or each component monitor for the output system shall meet an accuracy of within 3 percent of the full scale value, whichever is less stringent.
- (d) If, upon testing a piece of output measurement equipment, it is determined that the output readings are not accurate to within 3 percent of the full scale value, then the equipment shall be repaired or replaced to meet that requirement.
(COMAR 26.09.02.11 H(3)(a)-(e))
- (26) Out-of-Control Periods.
- (a) If, upon testing a piece of output measurement equipment, it is determined that the output readings are not accurate to the certification value, data is invalid until the output measurement equipment passes an accuracy test or is replaced with another piece of equipment that passes the

accuracy test.

- (b) All invalid data shall be replaced by either zero or an output value that is likely to be lower than a measured value and that is approved as part of the required monitoring plan.
(COMAR 26.09.02.11 H(4)(a)-(b))

(27) The CO₂ authorized account representative shall submit annual output reports, as follows:

- (a) Data shall be sent both electronically and in hardcopy by March 1 for the immediately preceding calendar year; and
(COMAR 26.09.02.11 I 1))

(28) The annual report shall include unit level megawatt hours, all useful steam output, and a certification statement from the CO₂ authorized account representative stating the following, "I am authorized to make this submission on behalf of the owners and operators of the CO₂ budget sources or CO₂ budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."
(COMAR 26.09.02.11 I(2))

G. CO₂ Emission Offset Projects

- (1) In order to qualify for the award of CO₂ offset allowances, the following offset projects shall satisfy all applicable requirements identified in COMAR 26.09.03 and initially commence on or after December 20, 2005:
- (a) Landfill methane capture and destruction;
 - (b) Reduction in emissions of sulfur hexafluoride (SF₆);
 - (c) Sequestration of carbon due to afforestation;
 - (d) Reduction or avoidance of CO₂ emissions from natural gas, oil, or propane end-use combustion due to end-use energy efficiency; and
 - (e) Avoided methane emissions from agricultural manure management operations.
(COMAR 26.09.03.02A(1)-(5))

4. Permit Application (See Attachment)

Maryland Department of the Environment
Air and Radiation Administration

PHASE II ACID RAIN PERMIT

Plant Name: Perryman Generating Station	
Affected Units: 51 and CT6A & CT6B	
Owner: Constellation Power Source Generation, LLC.	ORIS Code 1556
Effective Date From: November 1, 2018 To: October 31, 2023	


Contents:

1. Statement of Basis
2. SO₂ and NO_x Permit Requirements for Each Affected Unit.
3. Comments, Notes, and Justifications Regarding Permit Decisions; Changes Made to Permit Application Forms During the Review Process; Any Additional Requirements or Conditions.
4. The permit application forms submitted for this source. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application


1. Statement of Basis

Statutory and Regulatory Authorities: In accordance with Environmental Article §2-401, Annotated Code of Maryland and Titles IV and V of the Clean Air Act, the Maryland Department of the Environment, Air and Radiation Administration issues this permit pursuant to COMAR 26.11.02 and COMAR 26.11.03.

Renewal Permit Approval



Date of Issuance: **NOV - 1 2018**

 George S. Aburn, Jr., Director
Air and Radiation Administration

Phase II Renewal Acid Rain Permit: Perryman Generating Station

2. SO₂ and NO_x Requirements for Each Affected Unit

Sulfur Dioxide Requirements

Units No. 51 and CT6A & CT6B

SO_x Requirements	
SO _x Allowances	Constellation Power Source Generation, LLC will hold allowances for Units 51 and CT6A & CT6B in accordance with 40 CFR 72.9(c)(1).

- (1) The owners and operators of each source and each affected unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements

Units No. 51 and CT6A & CT6B

NO_x Requirements	
NO _x Limit	None

Phase II Renewal Acid Rain Permit: Perryman Generating Station

3. Comments, notes, and justifications regarding decisions; and changes made to the permit application forms during the review process:


The allowances allocated by the United States Environmental Protection Agency (US EPA) to the unit are listed in Table 2 of 40 CFR Part 73. However, the number of allowances actually held by an affected source's account may differ from the number allocated by the US EPA.

Unit 51 burns natural gas or No. 2 fuel oil. Because this unit is not coal-fired, the oxides of nitrogen (NO_x) emissions reduction regulations of 40 CFR Part 76 is not applicable.

CT6A & CT6B burns natural gas as primary fuel and ultra low sulfur diesel (ULSD) fuel oil during periods when natural gas supply has been interrupted. Because these units are not coal-fired, the oxides of nitrogen (NO_x) emissions reduction regulations of 40 CFR Part 76 is not applicable.

Revision 1: On July 1, 2001, Constellation Power Source Generation, LLC became the new owner of Perryman Generating Station. The previous owner was Baltimore Gas and Electric Company.

Renewal Permit Approval



Date of Issuance: **NOV - 1 2018**

George S. Aburn, Jr., Director
Air and Radiation Administration

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

BACKGROUND

The Perryman Generating Station (Perryman Station) is an electric generating station located in eastern Harford County. The facility generates electricity for peak loads. The SIC code for this facility is 4911.

The Perryman Station consists of the following: four (4) identical Westinghouse model 501 simple cycle combustion turbines capable of burning only distillate oil; one (1) GE Frame 7FA simple cycle combustion turbine with dual fuel firing capability and a 120-MW gas turbine electric generator package, comprised of two identical simple cycle combustion turbines, and associated facilities (Perryman 6 Project).

The Public Service Commission (PSC) issued a Certificate of Public Convenience and Necessity (**CPCN Case No.8241**) for the Perryman PY-Unit51 on July 16, 1993. This CPCN was amended on December 22, 1999 (Order No. 75847) to include hourly emission limits for sulfur oxides when burning No. 2 oil with 0.2 percent sulfur content. PY-Unit51 consists of a General Electric stationary, single-shaft combustion turbine operating in the simple cycle mode. The combustion turbine drives a generator set rated at a nominal 140 MW output. This turbine has dual fuel (natural gas and No. 2 oil) firing capability. Fuel firing is dependent upon cost and availability of the fuel. When firing natural gas, the unit operates in the dry low NO_x or premix mode. Natural gas and air are premixed prior to the combustion zone for NO_x control. Water injection is used for NO_x control when firing No. 2 fuel oil. The CPCN conditions restrict NO_x emissions to 25 ppm when firing natural gas and 65 ppm when firing No. 2 fuel oil. The Perryman Unit51 is subject to 40 CFR 60 Subpart GG – Standards of Performance for Stationary Gas Turbines.

Note: CPCN #8241 was issued for two-combined cycle generating units (PY-Unit51 and PY-Unit52). PY-Unit52 was never constructed. In addition, the two units were to be constructed in two phases. The first phase was the construction of two 140 MW simple cycle combustion turbines. In the second phase, the two simple cycle units were to be converted to one 440 MW combined cycle unit through the addition of a heat recovery steam generator and a steam-turbine generator. The second phase was also never constructed. The CPCN contains emission limits that are applicable during “Power Augmentation”. Power augmentation would only occur during combined cycle operation. Since the combined cycle phase was never constructed, these emission limits have not been included in the Part 70 operating permit.

The Perryman PY-Unit51 is a Phase II unit under the Title IV Acid Rain Program. The renewal Phase II Acid Rain Permit is attached as Appendix A. In order to

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

comply with the requirements of the 1990 Clean Air Amendments, as prescribed in 40 CFR §75, Constellation has installed a Continuous Emissions Monitoring (CEM) system to continuously monitor the NO_x and CO₂ concentrations in the exhaust gases from this unit.

Each of the five combustion turbines is equipped with a single discharge stack.

The combustion turbines are also not subject to 40 CFR Part 63, Subpart YYYYY – NESHAP for Stationary Combustion Turbines, because the Perryman Generating Station is not a major HAP source.

CHANGES AND MODIFICATIONS TO THE PART 70 OPERATING PERMIT

The following changes and/or modifications have been incorporated into the renewal Title V – Part 70 Operating Permit for the Perryman Generating Station:

The Public Service Commission (PSC) issued a Certificate of Public Convenience and Necessity (**CPCN Case No.9136**) for the Perryman 6 Project on May 19, 2014. The Perryman 6 Project consists of construction and operation of a nominal 120-megawatt (MW) generator set consisting of two (2) identical simple cycle natural-gas fired combustion turbines (**CT6A & CT6B**) and associated facilities (**EG6, FWP6, FUG6, CB6 & PR6**).

New Source Performance Standards (NSPS) – 40 CFR Part 60

Several emission units at the Perryman Generating Station are subject to the following NSPS:

Subpart GG for Stationary Gas Turbines applies stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired which commences construction, modification, or reconstruction after October 3, 1977.

Subpart IIII for Stationary Compression Ignition Internal Combustion Engines applies to stationary compression ignition (CI) internal combustion engines (ICE) constructed after July 11, 2005 and either manufactured after April 1, 2006 or modified or reconstructed after July 11, 2005.

Subpart KKKK for Combustion Turbines: Standards of Performance for Stationary Combustion Turbines applies to stationary combustion turbine with a heat input at peak load equal to or greater than 10.7 gigajoules (10 MMBtu) per

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

hour, based on the higher heating value of the fuel, which commenced construction, modification, or reconstruction after February 18, 2005.

National Emission Standard for Hazardous Air Pollutants (NESHAP) – 40 CFR Part 63

Perryman Generating Station is not a major HAP Emissions Source. Instead it is an area HAP emission source and is subject to the following MACTs:

Subpart ZZZZ — Stationary Reciprocating Internal Combustion Engines. Requirements for Existing Stationary RICE Located at Area Sources of HAP Emissions: 268 hp and 350 hp diesel-fired engines are subject to this subpart.

The following table summarizes the actual emissions from Perryman Generating Station based on its Annual Emission Certification Reports:

Table 1: Actual Emissions

Year	NO _x (TPY)	SO _x (TPY)	PM ₁₀ /PM _{2.5} (TPY)	CO (TPY)	VOC (TPY)	Total HAP (TPY)
2016	150.85	3.60	11.79/8.38	19.23	4.29	23.62
2015	190.44	2.09	5.19/5.02	3.04	1.10	1.467
2014	214.65	4.65	2.45	7.71	0.12	0.971
2013	96.90	4.30	1.58	3.08	0.112	0.892
2012	61.80	2.30	1.36		0.017	1.11

The major source threshold for triggering Title V permitting requirements in Harford County is 25 tons per year for VOC, 25 tons for NO_x, and 100 tons per year for any other criteria pollutants and 10 tons for a single HAP or 25 tons per year for total HAPS. Since the actual NO_x emission from the facility are greater than the major source threshold, Perryman Generating Station is required to obtain a Title V – Part 70 Operating Permit under COMAR 26.11.03.01.

As a major source of NO_x, this facility is also subject to requirements of Reasonably Available Control Technology (RACT) for NO_x found in COMAR 26.11.09.08. Perryman is also subject to the Cross-State Air Pollution Rule (CSAPR) which replaced the Clean Air Interstate Rule (CAIR). The facility was subject to the NO_x Reduction and Trading Program which expired at the end of 2008. Perryman is subject to the requirements of the Regional Greenhouse Gas Initiative (RGGI), a Maryland state-only enforceable program. Under these regulations, Perryman Generating Station will be required to obtain a RGGI permit.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

The Department on October 19, 2017 received Perryman Generating Station's Part 70 renewal permit application. An administrative completeness review was conducted and the application was deemed to be administratively complete. A completeness determination letter was sent to Perryman Generating Station on December 12, 2017 granting Perryman Generating Station an application shield.

COMPLIANCE ASSURANCE MONITORING (CAM)

Perryman Generating Station conducted a Compliance Assurance Monitoring (CAM) analysis for the facility and determined that the facility is not subject to the (CAM) Rule 40 CFR Subpart 64. CAM is intended to provide a reasonable assurance of compliance with applicable requirements under the Clean Air Act for large emission units that rely on air pollution control (APC) equipment to achieve compliance. The CAM approach establishes monitoring for the purpose of: (1) documenting continued operation of the control measures within ranges of specified indicators of performance (such as emissions, control device parameters, and process parameters) that are designed to provide a reasonable assurance of compliance with applicable requirements; (2) indicating any excursions from these ranges; and (3) responding to the data so that the cause or causes of the excursions are corrected. In order for a unit for a unit to be subject to CAM, the unit must be located at a major source, be subject to an emission limitation or standard; use a control device to achieve compliance; have post-control emissions of at least 100% of the major source amount (for initial CAM submittals); and must not otherwise be exempt from CAM. Applicability determinations are made on a pollutant-by-pollutant basis for each emission unit.

The Perryman Generating Station is not subject to CAM requirements because none of the units (PY-Units 1, 2, 3, 4, CT6A, CT6B and 51) use control devices to achieve compliance with their emission limits

ACID RAIN PERMIT

Title IV of the Clean Air Act set a goal of reducing annual SO₂ emissions by 10 million tons below 1980 levels. To achieve these reductions, the law required a two-phase tightening of the restrictions placed on fossil fuel-fired power plants.

Phase I began in 1995 and affected 263 units at 110 mostly coal-burning electric utility plants located in 21 eastern and Midwestern states. An additional 182 units joined Phase I of the program as substitution or compensating units, bringing the total of Phase I affected units to 445. Emissions data indicate that 1995 SO₂ emissions at these units nationwide were reduced by almost 40 percent below their required level.

Phase II, which began in the year 2000, tightened the annual emissions limits imposed on these large, higher emitting plants and also set restrictions on smaller, cleaner plants fired by coal, oil, and gas, encompassing over 2,000 units

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

in all. The program affects existing utility units serving generators with an output capacity of greater than 25 megawatts and all new utility units.

CROSS-STATE AIR POLLUTION RULE (CSAPR)

The U.S. Environmental Protection Agency (EPA) issued the Cross-State Air Pollution Rule (CSAPR) in July 2011 to address Clean Air Act requirements concerning interstate transport of air pollution and to replace the previous Clean Air Interstate Rule (CAIR) which the D.C. Circuit remanded to the EPA for replacement. Following the original rulemaking, CSAPR was amended by three further rules known as the Supplemental Rule, the First Revisions Rule, and the Second Revisions Rule. As amended, CSAPR requires 28 states to limit their state-wide emissions of sulfur dioxide (SO₂) and/or nitrogen oxides (NO_x) in order to reduce or eliminate the states' contributions to fine particulate matter and/or ground-level ozone pollution in other states. The emissions limitations are defined in terms of maximum state-wide "budgets" for emissions of annual SO₂, annual NO_x, and/or ozone season NO_x by each state's large electricity generating units (EGUs). The emissions budgets are implemented in two phases of generally increasing stringency. As the mechanism for achieving compliance with the emissions limitations, CSAPR establishes federal implementation plans (FIPs) that require large EGUs in each affected state to participate in one or more new emission trading programs that supersede the existing CAIR emissions trading programs. On December 30, 2011, in response to petitions challenging CSAPR, the D.C. Circuit granted a stay of the rule, ordering the EPA to continue administering CAIR on an interim basis. In a subsequent decision, the Court vacated CSAPR but on April 29, 2014, the U.S. Supreme Court reversed that decision and remanded the case to the D.C. Circuit Court for further proceedings. In order to allow CSAPR to replace CAIR in an orderly manner, EPA filed a motion asking the D.C. Circuit to lift the stay and to toll, by three years, all CSAPR compliance deadlines that had not yet passed. On October 23, 2014, the Court granted the EPA's motion.

Consistent with the Court's order, compliance with CSAPR's Phase 1 emissions budgets is now required in 2015 and 2016 and compliance with the rule's Phase 2 emissions budgets and assurance provisions is now required in 2017 and beyond.

This renewal Part 70 permit identifies the applicable regulations of the CSAPR rule as found in 40 CFR Part 97 subparts AAAAA- NO_x Annual Trading Program, subparts BBBBB- NO_x Ozone Season Trading Program, and subpart CCCCC SO₂ Group 1 Trading Program.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

REGIONAL GREENHOUSE GAS INITIATIVE

The Regional Greenhouse Gas Initiative (RGGI) is a market-based carbon dioxide (CO₂) cap and trade program designed to reduce CO₂ emissions from fossil fuel-fired power plants. The Healthy Air Act required Maryland to join RGGI by July 2007. Maryland joined RGGI by signing RGGI's multi-state Memorandum of Understanding (MOU) on April 20, 2007. The MOU requires Maryland to adopt regulations by December 31, 2008, implementing the RGGI program. The Maryland CO₂ Budget Trading Program, Code of Maryland Regulations (COMAR) 26.09.01 to .03, became effective on July 17, 2008. COMAR 26.09.04 became effective as an emergency action on April 4, 2008 and as a permanent action on August 25, 2008.

The regulations require the following:

- 1) Implement a cap and trade program for CO₂ emissions from fossil fuel-fired electric generating units located in Maryland having a capacity of at least 25 megawatts;
- 2) Distribute CO₂ allowances to stakeholders through auction, sale and/or allocation;
- 3) Require each affected source to have a CO₂ budget account representative and a compliance account;
- 4) Require each budget unit to hold in its source's compliance account at the end of each 3-year control period one allowance for each ton of CO₂ emissions emitted in that period;
- 5) Require sources to monitor emissions and submit quarterly and annual emission reports;
- 6) Establish set-aside accounts for voluntary renewable purchase, limited industrial generator exemptions, and long-term contract generators;
- 7) Establish a consumer benefit or strategic energy purpose fund to support energy efficiency, directly mitigate electricity ratepayer impacts, promote renewable or non-carbon emitting energy technologies, stimulate or reward investment in the development of innovative carbon emissions abatement technologies with significant carbon reduction potential, and fund administration of the program; and
- 8) Establish procedures to evaluate and award allowances to persons who undertake offset projects that will reduce CO₂ emissions.
- 9) Require affected sources to submit an application for a CO₂ Budget Permit. A CO₂ Budget Permit is an attachment to the Part 70 permit. This permit is state-only enforceable.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

GREENHOUSE GAS (GHG) EMISSIONS

The Perryman Generating Station emits the following greenhouse gases (GHGs) related to Clean Air Act requirements: carbon dioxide, methane, and nitrous oxide. These GHGs originate from combustion turbine power generation. The facility has not triggered Prevention of Significant Deterioration (PSD) requirements for GHG emissions; therefore, there are no applicable GHG Clean Air Act requirements. While there may be no applicable requirements as a result of PSD, emission certifications reports for the years 2014, 2015, and 2016, showed that the Perryman Generating Station is not a major source (threshold: 100,000tpy CO_{2e}) for GHGs (see Table 2 shown below). The Permittee shall quantify facility-wide GHGs emissions and report them in accordance with Section 3 of the Part 70 permit.

The following table summarizes the actual emissions from the Perryman Generation Station based on its Annual Emission Certification Reports:

Table 2: Greenhouse Gases Emissions Summary

GHG	Conversion factor	2014 tpy CO_{2e}	2015 tpy CO_{2e}	2016 tpy CO_{2e}
Carbon dioxide CO ₂	1	100,340.92	272,975.67	375,103.92
Methane CH ₄	25	3.56	5.332	7.766
Nitrous Oxide N ₂ O	298	0.649	0.583	0.894
Total GHG CO_{2eq}		100,345.13	272,981.59	375,112.58

EMISSION UNIT IDENTIFICATION

Perryman Generating Station has identified the following emission units as being subject to Title V permitting requirements and having applicable requirements.

Table 3: Emission Unit Identification

Emissions Unit Number	MDE Registration Number	Emissions Unit Name and Description	Date of Installation
PY-Unit1	12-4-0081	One (1) Westinghouse model 501 simple cycle combustion turbine with a design	Jan 1972

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Emissions Unit Number	MDE Registration Number	Emissions Unit Name and Description	Date of Installation
		heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	
PY-Unit2	12-4-0082	One (1) Westinghouse model 501 simple cycle combustion turbine with a design heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	Apr 1972
PY-Unit3	12-4-0083	One (1) Westinghouse model 501 simple cycle combustion turbine with a design heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	Apr 1972
PY-Unit4	12-4-0084	One (1) Westinghouse model 501 simple cycle combustion turbine with a design heat input of 704 MMBtu/hr, rated at a nominal 51 megawatts output and capable of only burning No.2 distillate oil.	Apr 1972
PY-Unit51	12-5-0088	One (1) General Electric Frame 7FA stationary, single-shaft combustion turbine with a design heat input of 1900 MMBtu/hr, operating in the simple cycle mode rate at a nominal 150 megawatts output. This turbine has dual fuel (natural gas and No. 2 oil) firing capability.	Jun 1995
CT6A & CT6B	025-0024-5-0353 & 025-0024-5-0354	One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted.	Apr 2015

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Emissions Unit Number	MDE Registration Number	Emissions Unit Name and Description	Date of Installation
EG6	025-0024-9-0492	One (1) diesel-fired emergency generator rated at 268 hp. This generator is fired with ultra-low sulfur diesel (ULSD)	Apr 2015
FWP6	025-00249-0502	One (1) diesel-fired emergency firewater pump engine rated at 181 hp. This generator is fired with ultra-low sulfur diesel (ULSD)	Apr 2015
FUG6	NA	Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.	Apr 2015
CB6	NA	Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF ₆).	Apr 2015
PR6	NA	Paved road emissions associated with the Perryman 6 Project. Emissions from this emission unit are assumed to be entirely PM _{2.5} and PM ₁₀ .	Apr 2015

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

AN OVERVIEW OF THE PART 70 PERMIT

The Fact Sheet is an informational document. If there are any discrepancies between the Fact Sheet and the Part 70 permit, the Part 70 permit is the enforceable document.

Section I of the Part 70 Permit contains a brief description of the facility and an inventory list of the emissions units for which applicable requirements are identified in Section IV of the permit.

Section II of the Part 70 Permit contains the general requirements that relate to administrative permit actions. This section includes the procedures for renewing, amending, reopening, and transferring permits, the relationship to permits to construct and approvals, and the general duty to provide information and to comply with all applicable requirements.

Section III of the Part 70 Permit contains the general requirements for testing, record keeping and reporting; and requirements that affect the facility as a whole, such as open burning, air pollution episodes, particulate matter from construction and demolition activities, asbestos provisions, ozone depleting substance provisions, general conformity, and acid rain permit. This section includes the requirement to report excess emissions and deviations, to submit an annual emissions certification report and an annual compliance certification report, and results of sampling and testing.

Section IV of the Part 70 Permit identifies the emissions standards, emissions limitations, operational limitations, and work practices applicable to each emissions unit located at the facility. For each standard, limitation, and work practice, the permit identifies the basis upon which the Permittee will demonstrate compliance. The basis will include testing, monitoring, record keeping, and reporting requirements. The demonstration may include one or more of these methods.

Section V of the Part 70 Permit contains a list of insignificant activities. These activities emit very small quantities of regulated air pollutants and do not require a permit to construct or registration with the Department. For insignificant activities that are subject to a requirement under the Clean Air Act, the requirement is listed under the activity.

Section VI of the Part 70 Permit contains State-only enforceable requirements. Section VI identifies requirements that are not based on the Clean Air Act, but solely on Maryland air pollution regulations. These requirements generally relate

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

to the prevention of nuisances and implementation of Maryland's Air Toxics Program.

**REGULATORY REVIEW/TECHNICAL REVIEW/COMPLIANCE
METHODOLOGY**

Emission Unit – Combustion Turbines

PY-Unit1, PY-Unit2, PY-Unit3, PY-Unit4

Four (4) Westinghouse model 501 simple cycle combustion turbines, each with a design heat input of 704 mm Btu/hr, rated at a nominal 51 megawatt output and capable of only burning No.2 distillate oil. [12-4-0081 thru 12-4-0084]

The four Westinghouse units were all installed in January 1970, prior to the NSPS applicability date of October 3, 1977, and have not been modified or reconstructed after the NSPS applicability date. Therefore, the four units are not subject to the NSPS standards found in 40 CFR 60 Subpart GG. PY-Units 1, 2, 3 & 4 are also exempt from the Title IV Acid Rain requirements.

Compliance Status

During the July 20, 2017 inspection, these units were not operating. NO_x stack testing Part 75 Appendix E (8/11-8/13, 2015) was conducted on Units 1, 3 & 4. Three 1-hour NO_x tests were conducted at each of the four operating loads (low, mid-low, mid-high and high). The results of tests were used to develop a NO_x/Heat Input curve for Part 75 emissions reporting purposes. See table below.

Units	Low (11 MW)	Mid-low (24 MW)	Mid-high (38 MW)	High (47 MW)
PY-Unit1	0.478	0.53	0.618	0.655
PY-Unit3	0.491	0.565	0.685	0.807
PY-Unit4	0.52	0.629	0.763	0.835

Please Note: Unit2 has not operated since 2015.

Capacity Factor

Units	Year	Month	Capacity Factor
PY-Unit1	2017	Jan	0
		Feb	0
		Mar	0
		Apr	0
		May	1.34
PY-Unit3	2017	Jan	0
		Feb	0
		Mar	0
		Apr	0
		May	0.45
PY-Unit4	2017	Jan	0.14
		Feb	0

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Units	Year	Month	Capacity Factor
		Mar	0
		Apr	0.08
		May	0.84

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05 - Visible Emissions.

"A. Fuel Burning Equipment.

(2) Areas III and IV. In Areas III and IV, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is visible to human observers except that, for the purpose of demonstrating compliance using COM data, emissions that are visible to a human observer are those that are equal to or greater than 10 percent opacity.

(3) Exceptions. Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, startup, or adjustments or occasional cleaning of control equipment if:

- (a) The visible emissions are not greater than 40 percent opacity; and
- (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period."

Compliance Demonstration

The Permittee shall:

- (a) properly operate and maintain the combustion turbines in a manner to prevent visible emissions;
- (b) verify no visible emissions when burning #2 fuel oil. An observer shall perform an EPA Reference Method 9 observation of stack emissions for an 18-minute period once for each 168 hours a combustion turbine operates on No. 2 oil.

The Permittee shall perform the following if visible emissions are observed:

- (a) inspect combustion turbine operations;
- (b) perform all necessary adjustments and/or repairs to the combustion turbine within 48 operating hours so that visible emissions are eliminated;
- (c) document in writing the results of the inspections, adjustments and/or repairs to the combustion turbine; and
- (d) if the required adjustments and/or repairs had not eliminated the visible emissions within the stipulated 48 operating hours, the Permittee shall perform a Method 9 observation once daily for 18 minutes until corrective action has eliminated the visible emissions.

[Reference: COMAR 26.11.03.06C]

The Permittee shall maintain for at least five years the following:

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (a) records of maintenance performed on the combustion turbines that relate to preventing visible emissions; and
- (b) log of visible emission observations performed.

[Reference: COMAR 26.11.03.06C]

The Permittee shall report incidents of excess emissions in accordance with Section III Condition 4 "Report of Excess Emissions and Deviations" **[Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]**

B. Control of Sulfur Oxides

COMAR 26.11.09.07: Control of Sulfur Oxides From Fuel Burning Equipment.

"A. Sulfur Content Limitations for Fuel. A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations:

(2) In Areas III and IV:

(a) *Not Applicable*;

(b) **Distillate fuel oils, 0.3 percent**;

(c) *Not Applicable.*"

Cross-State Air Pollution Rule

See Table IV-7: CSAPR for requirements.

Compliance Demonstration

The Permittee shall obtain a certification from the fuel supplier indicating that the oil complies with the limitation on the sulfur content of the fuel oil or obtain sulfur in fuel analyses of oil that is representative of oil burned. The Permittee shall maintain for at least five years documents certifying the sulfur content of fuel oil received or copies of the sulfur in fuel analyses. **[Reference: COMAR 26.11.03.06C]**

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 "Report of Excess Emissions and Deviations" **[Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]**

C. Control of Nitrogen Oxides:

COMAR 26.11.09.08G - Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.

"(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall:

- (a) Provide certification of the capacity factor of the equipment to the Department in writing;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually;
 - (c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request;
 - (d) *Not applicable*
 - (e) *Not applicable*
- (2) A person who owns or operates a combustion turbine with a capacity factor greater than 15 percent shall meet an hourly average NO_x emission rate of not more than 42 ppm when burning gas or 65 ppm when burning fuel oil (dry volume at 15 percent oxygen) or meet applicable Prevention of Significant Deterioration limits, whichever is more restrictive. “

Cross-State Air Pollution Rule

See Table IV-7: CSAPR for requirements.

Compliance Demonstration

If the Permittee operates a turbine in excess of 15 percent capacity factor, the Permittee shall demonstrate compliance with the 65-ppm limit by performing an EPA Reference Method Test within 120 days after exceeding the 15 percent capacity factor. The Permittee shall submit a test protocol to the Department for approval at least 30 days prior to the proposed test date. **[Reference: COMAR 26.11.03.06C]**

The Permittee shall:

- (1) Perform a combustion analysis and optimize combustion at least once annually when the turbines operate for more than 500 hours in a calendar year. **[Reference: COMAR 26.11.09.08G(1)(b)]**.
- (2) Calculate the capacity factor of each unit for each calendar year within 30 days after the end of each year. **[Reference: COMAR 26.11.03.06C]**

The Permittee shall:

- (1) Maintain the results of the combustion analysis and any stack tests for at least 5 years and make these results available to the Department and the EPA upon request. **[Reference: COMAR 26.11.09.08G(1)(c) and COMAR 26.11.03.06C]**.
- (2) Maintain a record of the calculated capacity factors. **[Reference: COMAR 26.11.03.06C]**.

The Permittee shall:

- (1) Provide certification of the capacity factor of the equipment to the Department in writing as part of the annual Emissions Certification. **[Reference: COMAR 26.11.09.08G(1)(a)]**
- (2) Submit the results of any stack tests within 45 days after completion of the stack test. **[Reference: COMAR 26.11.03.06C]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Rationale: Capacity factors

The Units 1 thru 4 turbines typically operate with a capacity factor less than 15%. The hours of operation are managed by economic dispatch from the PJM interconnector grid. Constellation is not able to unilaterally decide to operate a turbine and the cost to generate electricity by these turbines also prohibits the units from running with any frequency except for times of peak demands or emergencies. These turbines will never operate with a capacity factor greater than 15% unless there is a PJM grid emergency with possibility of brown outs or worse. Units 51, CT6A & CT6B satisfy COMAR 26.11.09.08G by meeting the hourly average emission rates at 42 NO_x ppmvd @15%O₂ for gas and 65 NO_x ppmvd @15%O₂ for oil

Emission Unit – Combustion Turbine

PY-Unit 51

General Electric Frame 7FA stationary, single-shaft combustion turbine operating in the simple cycle mode, rated at a nominal 150-megawatt output. This turbine has dual fuel (natural gas and No. 2 fuel oil) firing capacity. [12-5-0088]

The type of fuel (oil or gas) utilized is dependent upon cost and availability of the fuel. During the winter PY-Unit51 typically burns fuel oil due to the limited availability of natural gas. When firing No. 2 fuel oil water injection is used for NO_x control. This unit is equipped with NO_x and CO₂ CEMs as required by Part 75.

The Public Service Commission (PSC) issued a Certificate of Public Convenience and Necessity (CPCN Case No.8241) for the PY-Unit51 on July 16, 1993. The PY-Unit51 is subject to 40 CFR §60 Subpart GG – Standards of Performance for Stationary Gas Turbines.

Compliance Status:

During the July 20, 2017 inspection, PY-Unit51 was not operating. Initial performance testing conducted in 1995 per CPCN. Results are as follows:

PM: 3.39lb/hr firing on natural gas and 4.39 lb/hr firing on oil. In compliance with the CPCN limit.

CO: 1.8 lb/hr firing on natural gas and 41.9 lb/hr firing on oil.

Capacity Factor

Unit	Year	Month	Capacity Factor
PY-Unit51	2017	Jan	3.01
		Feb	0
		Mar	0
		Apr	5.14
		May	4.13

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05 - Visible Emissions.

"A. Fuel Burning Equipment.

(2) Areas III and IV. In Areas III and IV, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is visible to human observers except that, for the purpose of demonstrating compliance using COM data, emissions that are visible to a human observer are those that are equal to or greater than 10 percent opacity.

(3) Exceptions. Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, startup, or adjustments or occasional cleaning of control equipment if:

- (a) The visible emissions are not greater than 40 percent opacity; and
- (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period."

Compliance Demonstration

The Permittee shall:

- (a) properly operate and maintain the combustion turbine;
- (b) verify no visible emissions when burning No.2 fuel oil. An observer shall perform an EPA Reference Method 9 observation of stack emissions for an 18-minute period once for each 168 hours the combustion turbine burns No. 2 fuel oil, or perform such an observation no less than once a calendar year if No 2 fuel oil is burned during the year.

The Permittee shall perform the following if visible emissions are observed:

- (a) inspect combustion turbine operations;
- (b) perform all necessary adjustments and/or repairs to the combustion turbine within 48 operating hours so that visible emissions are eliminated;
- (c) document in writing the results of the inspections, adjustments and/or repairs to the combustion turbine; and
- (d) if the required adjustments and/or repairs had not eliminated the visible emissions within the stipulated 48 operating hours, the Permittee shall perform a Method 9 observation once daily for 18 minutes until corrective action has eliminated the visible emissions.

The Permittee shall:

- (1) Maintain for at least five years records of maintenance performed on the combustion turbine that relate to preventing visible emissions.
- (2) Maintain for at least five years a log of visible emission observations performed.

[Reference: COMAR 26.11.03.06C]

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 "Report of Excess Emissions and Deviations" [**Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)**]

B. Control of Sulfur Oxides

COMAR 26.11.09.07: Control of Sulfur Oxides From Fuel Burning Equipment.

"A. Sulfur Content Limitations for Fuel. A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations:

(2) In Areas III and IV:

(a) *Not Applicable*;

(b) **Distillate fuel oils, 0.3 percent;**

(c) *Not Applicable.*"

Subpart GG—Standards of Performance for Stationary Gas Turbines

40 CFR §60.333, which limits the sulfur content in No. 2 distillate fuel oil to 0.8%.

CPCN #8241, which states "The fuel oil burned in PY-Unit51 shall contain no more than 0.05% by weight. If this type of fuel is not available or is not priced competitively, fuel oil with a maximum sulfur content of 0.2 percent may be used. Fuel oil with a maximum of 0.05 percent sulfur is considered to be "priced competitively" if it costs (on a \$/MMBtu basis) no more than 10 percent more than No. 2 oil containing 0.2 percent sulfur."

CPCN #8241 which limits sulfur oxides (as SO₂) emissions to 28 lb/hr when burning natural gas and 87 lb/hr when burning No. 2 oil.

CPCN #8241, which limits Sulfuric Acid Mist to 7.8 lb/hr when burning No. 2 oil.

CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.

Note: Compliance with these limitations will be by use of fuel supplier certifications or sulfur in fuel analyses

Compliance Demonstration

The Permittee shall obtain a certification from the fuel supplier indicating that the oil complies with the limitation on the sulfur content of the fuel oil or obtain sulfur in fuel analyses of oil that is representative of oil burned.

The Permittee shall

(1) Maintain for at least five years documents certifying the sulfur content of fuel oil received or copies of the sulfur in fuel analyses.

(2) Maintain for at least five years records of the number of hours, in any consecutive 12-month period, that fuel oil is used.

[**Reference: COMAR 26.11.03.06C**]

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

The Permittee shall report fuel supplier certifications or fuel analyses to the Department upon request. **[Reference: COMAR 26.11.09.07C]**

Acid Rain Permit

The Permittee shall comply with the requirements of the Phase II Acid Rain Permit issued for this generating station. Note: A renewal Phase II Acid Rain Permit will be issued in conjunction with this Part 70 permit and is attached to the Part 70 permit as Appendix A.

Cross-State Air Pollution Rule

See Table IV-7: CSAPR for requirements.

C. Control of Particulate Matter

CPCN #8241 which limits particulate emissions (TSP and PM₁₀ emissions each) to 10 lb/hr when burning natural gas and 11 lb/hr when burning No. 2 oil. **CPCN #8241 condition 26**, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.

Compliance Demonstration

The Permittee shall perform preventative maintenance to maintain the turbine as designed. The Permittee shall maintain records of the preventive maintenance that relates to combustion performance for 5 years. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

D. Control of Nitrogen Oxides

COMAR 26.11.09.08G - Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.

- “(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall:
- (a) Provide certification of the capacity factor of the equipment to the Department in writing;
 - (b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually;
 - (c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request;
 - (d) *Not applicable.*
 - (e) *Not applicable.*
- (2) A person who owns or operates a combustion turbine with a capacity factor greater than 15 percent shall meet an hourly average NO_x emission rate of not

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

more than 42 ppm when burning gas or 65 ppm when burning fuel oil (dry volume at 15 percent oxygen) or meet applicable Prevention of Significant Deterioration limits, whichever is more restrictive. “

Note: Compliance with the CPCN will be used to demonstrate compliance with NSPS (40 CFR Part 60) and NO_x RACT requirements.

Subpart GG—Standards of Performance for Stationary Gas Turbines
40 CFR §60.332, which limits NO_x emissions in accordance with the equation contained in 40 CFR §60.332 (a) (1).

CPCN #8241 which limits NO_x emissions to 170 lb/hr when burning natural gas and 490 lb/hr when burning No. 2 oil.

CPCN #8241 which limits NO_x emissions to 25 parts per million by volume on a dry basis (ppmvd) at 15% excess oxygen on an hourly basis when burning natural gas and 65 ppmvd at 15% oxygen on an hourly basis when burning No. 2 oil.

CPCN #8241, which limits NO_x emissions to 1,363 tons in any consecutive 12-month period.

CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.

Cross-State Air Pollution Rule
See Table IV-7: CSAPR for requirements.

Compliance Demonstration

The Permittee shall:

- (1) Operate, calibrate, and maintain a certified NO_x CEM system [**Reference: CPCN 8241 and COMAR 26.11.29.08A**].
- (2) Certify the NO_x CEM system in accordance with Part 75, Appendix A. [**Reference: 40 CFR §75.70, COMAR 26.11.09.08B(2)(b), and COMAR 26.11.29.08B**].

The Permittee shall maintain records necessary to prepare a quarterly emission reports that contain the requirements of COMAR 26.11.01.11E(2). [**Reference: COMAR 26.11.03.06C**]

The Permittee shall submit a quarterly summary report to the Department not later than 30 days following each calendar quarter. The report shall be in a format approved by the Department, and shall include the following:

- (1) The cause, time periods, and magnitude of all emissions which exceed the applicable emission standards;
- (2) The source downtime including the time and date of the beginning and end of each downtime period and whether the source downtime was planned or unplanned;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (3) The time periods and cause of all CEM downtime including records of any repairs, adjustments, or maintenance that may affect the validity of emission data;
- (4) Quarterly totals of excess emissions, installation downtime, and CEM downtime during the calendar quarter;
- (5) Quarterly quality assurance activities; and
- (6) Daily calibration activities that include reference values, actual values, absolute or percent of span differences, and drift status; and
- (7) Other information required by the Department that is determined to be necessary to evaluate the data, to ensure that compliance is achieved, or to determine the applicability of this regulation.

[Reference: COMAR 26.11.09.08K(1) and COMAR 26.11.01.11E(2)]

Rationale: Capacity factors

The PY-Unit51 turbine satisfy COMAR 26.11.09.08G by meeting the hourly average emission rates at 42 NO_x ppmvd @15%O₂ for gas and 65 NO_x ppmvd @15%O₂ for oil.

E. Control of VOC

CPCN #8241 which limits VOC emissions to 2.9 lb/hr when burning natural gas and 7 lb/hr when burning No. 2 oil.

CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.

Compliance Demonstration

The Permittee shall perform preventative maintenance to maintain the turbine as designed. The Permittee shall maintain records of the preventive maintenance that relates to combustion performance for 5 years. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

F. Control of Carbon Monoxide

CPCN # 8241 which limits CO emissions to 52 lb/hr when burning natural gas and 70 lb/hr when burning No. 2 oil.

CPCN #8241 condition 26, which states that the emissions limitations in the CPCN conditions do not apply during periods of start-up, shutdown, malfunction.

Compliance Demonstration

The Permittee shall perform preventative maintenance to maintain the turbine as designed. The Permittee shall maintain records of the preventive maintenance

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

that relates to combustion performance for 5 years. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

Emission Unit – Combustion Turbines (Project 6)

CT6A & CT6B

One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted. **[025-0024-5-0353 & 5-0354]**

CT6A & CT6B were installed in 2015 and is subject to NSPS KKKK as well as BACT and LAER limits per the CPCN #9136 issued in 2014.

The CT6A & CT6B are equipped with SCR for NO_x control and Oxidation Catalyst for CO control as well as CEMs to monitor emissions.

Note: The turbine part of Project 6 was replaced with a prototype unit while the original was sent for repairs. MDE was notified of this issue and approved the temporary installation of the prototype.

Compliance Status:

Initial startup for CT6A occurred on April 25, 2015; Initial Commercial Operation for CT6A commenced on May 9, 2015. Initial startup for CT6B occurred on May 29, 2015; Initial Commercial Operation for CT6B commenced on May 29, 2015.

During the July 20, 2017 inspection, this unit was operating at full load (99 MW of a possible 120 MW) for stack testing for PM and GHG emissions.

Stack Test Results

Initial performance testing was conducted October 21-22, 2015. Results are as follows:

Pollutant	Result per Fuel type		Limit per fuel type	
	Natural gas	Fuel oil	Natural gas	Fuel oil
NO _x	2.4ppm	4.7 ppm	42 ppm @ 15% O ₂ - COMAR 25 ppm @ 15% O ₂ - NSPS	65 ppm @ 15% O ₂ - COMAR 74 ppm @ 15% O ₂ - COMAR

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Pollutant	Result per Fuel type		Limit per fuel type	
	Natural gas	Fuel oil	Natural gas	Fuel oil
			2.5 ppmvd @ 15% O ₂ - LAER	5.0 ppmvd @ 15% O ₂ - LAER
CO ₂	1148 lb/MWh	1644 lb/MWh	1394 lb/MWh	1741 lb/MWh
PM ₁₀	See Feb 2, 2016 stack test	See Feb 2, 2016 stack test	5.0 lb/hr; 0.0079 lb/MMBtu - BACT	15.0 lb/hr; 0.0248 lb/MMBtu - BACT
PM _{2.5}	See Feb 2, 2016 stack test	See Feb 2, 2016 stack test	5.0 lb/hr; 0.0079 lb/MMBtu - LAER	15.0 lb/hr; 0.0248 lb/MMBtu - LAER
Ammonia	4.4 ppmvd @ 15% O ₂ 2.3 15% O ₂	2.6 ppmvd @ 15% O ₂	5 ppmvd @ 15% O ₂ - COMAR	5 ppmvd @ 15% O ₂ - COMAR
SO ₂	<0.1 lb/MWh <0.005 lb/MMBtu	<0.1 lb/MWh <0.005 lb/MMBtu	0.90 lb/MWh; 0.060 lb/MMBtu - NSPS	.90 lb/MWh; 0.060 lb/MMBtu - NSPS
H ₂ SO ₄	<0.13 ppm <1.31 lb/hr	≤0.11 ppm ≤1.12 lb/hr	NA	NA

On February 2, 2016, two PM₁₀ (filterable & condensable) and PM_{2.5} (filterable & condensable) stack test runs were conducted on Project 6 (combined stack for CT6A & CT6B) while firing on oil. These test runs were performed following the Department's rejection of the October 21-22, 2015 PM₁₀ & PM_{2.5} test results for a lack of sufficient number of valid runs. As approved by the Department the two additional PM₁₀ and PM_{2.5} runs performed on Feb 2, 2016 were averaged with the two valid runs conducted in October 2015. The results are as follows:

PM₁₀ - 8.28 lb/hr (0.0045 lb/mmBtu) - Limit: 15 lb/hr (0.0248 lb/mmBtu)
PM_{2.5} - 6.78 lb/hr (0.0065 lb/mmBtu) - Limit: 15 lb/hr (0.0248 lb/mmBtu)

Stack testing conducted July 13-15, 2017 for PM₁₀, PM_{2.5} & CO₂. The results indicated compliance with the BACT and LAER limited listed in the CPCN.

Pollutant	Limit nat gas firing (each unit)	CT6A (natural gas)	CT6B (natural gas)	Limit oil firing	CT6A (oil firing)	CT6B (oil firing)
CO ₂	1394 (lbs/MWh)	663	665	1741 (lb/MWH)	855	824
PM ₁₀	5.0 lb/hr	3.3	3.2	15	3.5	3.5
PM _{2.5}	5.0 lb/hr	3.0	2.9	15	3.2	3.2

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Capacity Factor

Unit	Year	Month	Capacity Factor
CT6A & CT6B	2017	Jan	1.82
		Feb	2.83
		Mar	18.19
		Apr	0
		May	7.87

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05 - Visible Emissions.

"A. Fuel Burning Equipment.

(2) Areas III and IV. In Areas III and IV, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is visible to human observers except that, for the purpose of demonstrating compliance using COM data, emissions that are visible to a human observer are those that are equal to or greater than 10 percent opacity.

(3) Exceptions. Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, startup, or adjustments or occasional cleaning of control equipment if:

- (a) The visible emissions are not greater than 40 percent opacity; and
- (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period."

Compliance Demonstration

The Permittee shall operate and maintain the combustion turbines and associated air pollution control equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction. **[Reference: CPCN Case No. 9136, Condition B-IV-14]**

The Permittee shall conduct quarterly visual observations during normal operation in accordance with EPA Reference Method 22 – Visual Determination of Fugitive Emissions from Material Sources and Smoke Emissions from Flares, to verify there are no visible emissions during operation. If visible emissions are observed, the Permittee shall inspect combustion control systems, perform necessary adjustments and/or repairs within 48 hours, and document in writing the results of inspection, adjustments, and/or repairs. After 48 hours, if the required adjustments and/or repairs have not eliminated visible emissions, the Permittee shall perform Reference Method 9 observations once daily for a period of 18 minutes burning the fuel where visual emissions are observed until

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

corrective actions have reduced the visible emissions to less than 10 percent opacity. [Reference: CPCN Case No. 9136, Condition B-IV-8]

The Permittee shall document in writing the results of inspection, adjustments, and/or repairs, taken to address visible emissions observed during quarterly Method 22 and/or Method 9 observations and make available to the Department upon request. [Reference: CPCN Case No. 9136, Condition B-IV-8 & COMAR 26.11.03.06C]

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 "Report of Excess Emissions and Deviations" [Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]

B. Control of Sulfur Oxides

COMAR 26.11.09.07: Control of Sulfur Oxides From Fuel Burning Equipment.

"A. Sulfur Content Limitations for Fuel. A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: (2) In Areas III and IV: (b) **Distillate fuel oils, 0.3 percent;**

Subpart KKKK—Standards of Performance for Stationary Combustion Turbines

§60.4330 - What emission limits must I meet for sulfur dioxide (SO₂)?

"(1) You must not cause to be discharged into the atmosphere from the subject stationary combustion turbine any gases which contain SO₂ in excess of **110 nanograms per Joule (ng/J) (0.90 pounds per megawatt-hour (lb/MWh))** gross output;

(2) You must not burn in the subject stationary combustion turbine any fuel which contains total potential sulfur emissions in excess of **26 ng SO₂/J (0.060 lb SO₂/MMBtu)** heat input. If your turbine simultaneously fires multiple fuels, each fuel must meet this requirement;"

CPCN#9136, which states, "Fuel type Limit: The only permissible fuels for the combustion turbines are pipeline quality natural gas and ultra-low sulfur diesel (ULSD). ULSD may only be used during periods of interruption of the natural gas supply. [Reference: CPCN Case No. 9136, Condition B-IV-1]

Acid Rain Permit

The Permittee shall comply with the requirements of the Phase II Acid Rain Permit issued for this generating station. Note: A renewal Phase II Acid Rain Permit will be issued in conjunction with this Part 70 permit and is attached to the Part 70 permit as Appendix A.

Cross-State Air Pollution Rule

See Table IV-7: CSAPR for requirements.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Compliance Demonstration

The Permittee shall conduct the stack testing annually per the methods described in 40 CFR §60.8 (40 CFR §60.4415 and 40 CFR §60.4360) or monitor the sulfur content of each fuel combusted at a frequency prescribed in 40 CFR §60.4370 (see monitoring requirements). **[Reference: CPCN Case No. 9136, Condition B-IV-11]**

The Permittee shall monitor the sulfur content of each fuel combusted in the turbines at a frequency prescribed in 40 CFR 60.4370. A representative fuel sample shall be collected following ASTM D5287 for pipeline natural gas of ASTM D4177 or ASTM D4057 Section 14 for ULSD. The fuel analyses may be performed either by the Permittee, a service contractor, the fuel vendor, or any qualified agency. Analyze the samples for the total sulfur content of the fuel using ASTM D129 (or alternatively D1266, D1552, D2622, D4294, or D5453) for ULSD and ASTM D1072 (or alternatively D3246, D4084, D4468, D4810, D6228, D6667, or Gas Processors Association Standard 2377) for pipeline quality natural gas.

§60.4370 - How often must I determine the sulfur content of the fuel?

The frequency of determining the sulfur content of the fuel must be as follows:

*(a) Fuel oil. For fuel oil, use one of the total sulfur sampling options and the associated sampling frequency described in sections 2.2.3, 2.2.4.1, 2.2.4.2, and 2.2.4.3 of appendix D to part 75 of this chapter (i.e., flow proportional sampling, daily sampling, sampling from the unit's storage tank after each addition of fuel to the tank, or **sampling each delivery** prior to combining it with fuel oil already in the intended storage tank).*

*(b) Gaseous fuel. If you elect not to demonstrate sulfur content using options in §60.4365, and the fuel is supplied without intermediate bulk storage, the sulfur content value of the gaseous fuel must be determined and **recorded once per unit operating day**.*

The Permittee shall maintain all annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

A certification from the fuel supplier indicating that the ULSD complies with the limitation of sulfur content in the fuel oil. The certification should include the name of the supplier, the date of delivery, the amount of fuel delivered, the method used to determine the sulfur content of the oil, and a statement from the fuel supplier that the ULSD complies with the specifications of 40 CFR 80.510. **[Reference: CPCN Case No. 9136, Condition B-V-8 and 15]**

The Permittee shall report fuel supplier certifications or fuel analyses to the Department upon request. **[Reference: COMAR 26.11.09.07C]**

The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

to the Department within 60 days after completion of the test. **[Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25]**

The Permittee shall submit reports of NSPS Subpart KKKK excess emissions and monitor downtime associated with the combustion turbines, in accordance with 40 CFR 60.79(c). Excess emissions as defined in 40 CFR 60.4385 (SO₂) must be reported for all periods of unit operation, including startup, shutdown, and malfunction. **[Reference: CPCN Case No. 9136, Condition B-IV-27]**

C. Control of Particulate Matter

COMAR 26.11.06.03B(2)(a) - Particulate Matter from Confined Sources. “A person may not cause or permit to be discharged into the outdoor atmosphere from any other installation, particulate matter in excess of 0.03 gr/SCFD (68.7 mg/dscm).”

CPCN#9136 states PM₁₀ and PM_{2.5} (filterable and condensable), when burning NG emissions from the two (2) combustion turbines shall not exceed the following emission limits: 5.0 lb/hr (0.0079 lb/MMBtu High heat value (HHV) at all times, averaged over 3 stack test runs. **[Reference: CPCN Case No. 9136, Condition B-IV-4: BACT/LAER]**

CPCN#9136 states PM₁₀ and PM_{2.5} (filterable and condensable), when burning ULSD emissions from the two (2) combustion turbines shall not exceed the following emission limits: 15.0 lb/hr (0.0248 lb/MMBtu High heat value (HHV) at all times, averaged over 3 stack test runs. **[Reference: CPCN Case No. 9136, Condition B-IV-4: BACT/LAER]**

Compliance Demonstration

The Permittee shall conduct stack test annually for PM₁₀, and PM_{2.5}. Unless otherwise approved by the Department, the stack testing shall be conducted in accordance with the following EPA approved test methods to determine compliance: (d) Reference Method 201A – Determination of PM₁₀ and PM_{2.5} Emissions From Stationary Sources and (e) Reference Method 202 – Dry Impinger Method for Determining Condensable Particulate Emissions from Stationary Sources. **[Reference: CPCN Case No. 9136, Condition B-IV-11]**

The Permittee may submit to the Department a request to reduce the frequency of stack testing for any pollutant listed in this condition. **[Reference: CPCN Case No. 9136, Condition B-IV-9]**

The Permittee shall operate and maintain the combustion turbines and associated air pollution control equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction. **[Reference: CPCN Case No. 9136, Condition B-IV-14]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

The Permittee shall maintain all annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted to the Department within 60 days after completion of the test. **[Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Monthly and consecutive rolling 12-month emissions (in tons per month and tons per year) of GHGs (as CO_{2e}), PM₁₀, PM_{2.5}, and NO_x for the entire Perryman 6 Project.

Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[Reference: CPCN Case No. 9136, Condition B-III-5]**

Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine.

Monthly and 12-month consecutive rolling quantity of pipeline natural gas and ULSD for each combustion turbine, inclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, inclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, exclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling total number of startup events and shutdown events.

Total NO_x emission expressed in lb/event for each startup event and shutdown event

Monthly and 12-month consecutive rolling gross generation (MWh) for each combustion turbine for each fuel burned.

For any period where a combustion turbine burned ULSD, an explanation for why ULSD used was burned.

[Reference: CPCN Case No. 9136, Condition B-IV-23]

D. Control of Nitrogen Oxides

COMAR 26.11.09.08G - Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

“(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall:

- (a) Provide certification of the capacity factor of the equipment to the Department in writing;
- (b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually;
- (c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request;
- (d) *Not Applicable.*
- (e) *Not Applicable.*

(2) A person who owns or operates a combustion turbine with a capacity factor greater than 15 percent shall meet an hourly average NO_x emission rate of not more than **42 ppm when burning gas or 65 ppm when burning fuel oil (dry volume at 15 percent oxygen)** or meet applicable Prevention of Significant Deterioration limits, whichever is more restrictive. “

Subpart KKKK—Standards of Performance for Stationary Combustion Turbines

40 CFR §60.4320, which states that NO_x emissions standard (**when burning NG**) shall not exceed 25 ppm at 15% O₂ or 150 ng/J (1.2 lb/MWh) of useful output at all times greater than or equal to 75 percent of peak load or greater than or equal to 0°F, average 4-hr rolling.

40 CFR §60.4320, which states that NO_x emissions standard (**when burning ULSD**) shall not exceed 74 ppm at 15% O₂ or 460 ng/J (3.6 lb/MWh) of useful output, average 4-hr rolling.

CPCN#9136 which states the NO_x (when burning NG) shall not exceed 2.5 ppm at 15% O₂ (5.8 lb/hr) at all times, excluding during startup events and shutdown events, averaged over 3-hr block. [LAER]

CPCN#9136 which states the NO_x (when burning NG or ULSD) shall not exceed 36.4 lb/startup event (1 CT or 2 CTs) and 9.27 lb/shutdown event (1 CT or 2 CTs). [LAER]

CPCN#9136 which states the NO_x (when burning ULSD) shall not exceed 5 ppm at 15% O₂ (11.7 lb/hr) at all times, excluding during startup events and shutdown events, averaged over 3-hr block. [LAER]

CPCN#9136 which states the NO_x (when burning either NG or ULSD) shall not exceed 96 ppm at 15% O₂ or 150 ng/J (1.2 lb/MWh) of useful output at all times greater than or equal to 75 percent of peak load or greater than or equal to 0°F, averaged over 4-hr rolling average [NSPS KKKK 40 CFR §60.4320, §60.4325]. [LAER]

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

CPCN#9136 states A “*Startup Event*” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a startup event is defined as the period of time during which one CTs output is increased with the intent to startup, beginning with initiation of fuel combustion in one CT and ending when the SCR system catalyst reaches 600 degrees Fahrenheit. In the case of 2 CTs, the startup event begins at the point at which 1 CT initiates combustion and ends when the SCR system catalyst reaches 600F. **[Reference: CPCN Case No. 9136, Condition B-II-5]**

CPCN#9136 states A “*Shutdown Event*” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a shutdown event is defined as the period of time during which one CTs output is lowered with the intent to shutdown, beginning at the point at which the load drops below 50% and ending when fuel combustion ceases. In the case a shutdown event of 2 CTs occurs, a shutdown event begins at the point at which the first CT drops below 50% and ends when fuel combustion for both CTs ceases. Notwithstanding the foregoing, if 2 CTs are in operation and 1 CT’s load is lowered below 50% with the intent to shutdown while the other CT continues in normal operation during and beyond the point fuel combustion ceases from the first Ct that shall not constitute a “Shutdown Event.” **[Reference: CPCN Case No. 9136, Condition B-II-4]**

Cross-State Air Pollution Rule
See Table IV-7: CSAPR for requirements.

Compliance Demonstration

The Permittee shall conduct the stack testing annually. Unless otherwise approved by the Department, for each fuel burned, the performance test shall be conducted in accordance with the following EPA approved test methods to determine compliance: (b) Reference Method 3A – Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure) or as an alternative to annual stack testing for CO₂, and upon approval by the Department, the Permittee may choose to demonstrate compliance with emission limitations by installing and operating a certified CEMS in accordance with the performance specifications of 40 CFR Part 75, Appendix A. **[Reference: CPCN Case No. 9136, Condition B-IV-11]**
The Permittee may submit to the Department a request to reduce the frequency of stack testing for any pollutant listed in this condition. **[Reference: CPCN Case No. 9136, Condition B-IV-9]**

The Permittee shall install ULSD and pipeline quality natural gas flow meters and continuously monitor each fuel flow into the two (2) combustion turbines. The fuel flow for each fuel shall be recorded monthly. **[Reference: CPCN Case No. 9136, Condition B-IV-7]**

The Permittee shall demonstrate compliance for NO_x emission standards by installing a certified NO_x CEMS in accordance with the performance

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

specifications of 40 CFR Part 60, Appendix B or 40 CFR Part 75, Appendix A. The CEMS shall be operated and maintained to meet the quality assurance requirements of 40 CFR 60, Appendix F, and applicable requirement of 40 CFR Part 75. **[Reference: CPCN Case No. 9136, Condition B-IV-10]**

The Permittee shall install and maintain a temperature gauge to accurately indicate the temperature in degrees Fahrenheit of the SCR catalyst system. During startup events, the temperature of the SCR system catalyst should be continuously monitored. **[Reference: CPCN Case No. 9136, Condition B-IV-13]**

The Permittee shall maintain the following:

(1) All CEMS reports submitted to the Department. **[Reference: CPCN Case No. 9136, Condition B-IV-20]**

(2) Records of the SCR system catalyst temperature during startup events. **[Reference: CPCN Case No. 9136, Condition B-IV-22]**

The Permittee shall submit:

(1) A quarterly CEMS summary report in a format approved by the Department and include the information required under COMAR 26.11.01.11E(2)(c)(i)-(vii). **[Reference: CPCN Case No. 9136, Condition B-IV-19(b)]**

(2) CEMS System Downtime Reports for any CEMS system downtime that lasts or is expected to last more than 24 hours by telephone before 10 a.m. of the first regular business day following the breakdown. **[Reference: CPCN Case No. 9136, Condition B-IV-19(a)]**

(3) Reports of NSPS Subpart KKKK excess emissions and monitor downtime associated with the combustion turbines, in accordance with 40 CFR 60.79(c). Excess emissions as defined in 40 CFR 60.4380 (NO_x) must be reported for all periods of unit operation, including startup, shutdown, and malfunction. **[Reference: CPCN Case No. 9136, Condition B-IV-27]**

E. Control of GHG Emissions

CPCN#9136 which states the emissions from the two (2) combustion turbines shall not exceed the following emission limits:

GHG (when burning NG) shall not exceed 1,394 lb CO_{2e}/MWh gross at all times excluding startup events and shutdown events, over a 12-month rolling averaging period.

GHG (when burning ULSD) shall not exceed 1,741 lb CO_{2e}/MWh gross at all times excluding startup events and shutdown events, over a 12-month rolling averaging period. **[Reference: CPCN Case No. 9136, Condition B-IV-4]**

Compliance Demonstration

The Permittee shall conduct the stack testing annually. Unless otherwise approved by the Department, for each fuel burned, the performance test shall be conducted in accordance with the following EPA approved test methods to

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

determine compliance: (b) Reference Method 3A – Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure) or as an alternative to annual stack testing for CO₂, and upon approval by the Department, the Permittee may choose to demonstrate compliance with emission limitations by installing and operating a certified CEMS in accordance with the performance specifications of 40 CFR Part 75, Appendix A. **[Reference: CPCN Case No. 9136, Condition B-IV-11]** The Permittee may submit to the Department a request to reduce the frequency of stack testing for any pollutant listed in this condition. **[Reference: CPCN Case No. 9136, Condition B-IV-9]**

The GHG emissions for the project shall be calculated as follows:
The total GHG emissions shall be presented on a CO₂e basis using the following global warming potential values:

Chemical Formula	Global Warming Potential
CO ₂	1
CH ₄	25
N ₂ O	298
SF ₆	23,900

For the combustion turbines, the CO₂ emissions shall be based on fuel flow and the measured carbon content of the fuel using procedures specified in Appendix G of 40 CFR Part 75, or other emission factors approved by the Department. The CH₄ and N₂O emissions shall be calculated using the procedures specified in 40 CFR Part 98 Subpart C. The total generation of the combustion turbines shall be monitored to calculate the emission rate of lb CO₂e/MWh, determined each month by summing the CO₂e emission for all hours in which power is being generated by the turbines during the previous 12 months and dividing that value by the sum of electrical energy output over that same period. **[Reference: CPCN Case No. 9136, Condition B-IV-12]**

The Permittee shall maintain all annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

Monthly and 12-month consecutive rolling GHG emission rate, expressed in lb/CO₂/MWh gross, for each combustion turbine for each fuel burned.

[Reference: CPCN Case No. 9136, Condition B-IV-23]

The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted to the Department within 60 days after completion of the test. **[Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation:

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine.

Monthly and 12-month consecutive rolling GHG emission rate, expressed in lb/CO₂/MWh gross, for each combustion turbine for each fuel burned.

Monthly and 12-month consecutive rolling gross generation (MWh) for each combustion turbine for each fuel burned.

[Reference: CPCN Case No. 9136, Condition B-IV-23]

NSPS Subpart TTTT - Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units

§60.5520 - What CO₂ emissions standard must I meet?

(a) For each affected EGU subject to this subpart, you must not discharge from the affected EGU any gases that contain CO₂ in excess of the applicable CO₂ emission standard specified in **table 1** or **2** of this subpart, consistent with paragraphs (b), (c), and (d) of this section, as applicable.

Table 2 of Subpart TTTT of Part 60—CO₂ Emission Standards for Affected Stationary Combustion Turbines That Commenced Construction After January 8, 2014 and Reconstruction After June 18, 2014 (Net Energy Output-Based Standards Applicable as Approved by the Administrator)

[Note: Numerical values of 1,000 or greater have a minimum of 3 significant figures and numerical values of less than 1,000 have a minimum of 2 significant figures]

Affected EGU	CO₂ Emission standard
Newly constructed or reconstructed stationary combustion turbine that supplies its design efficiency or 50 percent, whichever is less, times its potential electric output or less as net-electric sales on either a 12-operating month or a 3-year rolling average basis and combusts more than 90% natural gas on a heat input basis on a 12-operating-month rolling average basis	50 kg CO ₂ per gigajoule (GJ) of heat input (120 lb CO ₂ /MMBtu).

(d) Stationary combustion turbines subject to a heat input-based standard in table 2 of this subpart that are only permitted to burn one or more uniform fuels, as described in paragraph (d)(1) of this section, are only subject to the monitoring requirements in paragraph (d)(1). All other stationary combustion turbines subject to a heat input based standard in table 2 are subject to the requirements in paragraph (d)(2) of this section.

(1) Stationary combustion turbines that are only permitted to burn fuels with a consistent chemical composition (*i.e.*, uniform fuels) that result in a consistent emission rate of 160 lb CO₂/MMBtu or less are **not subject to any monitoring or reporting requirements under this subpart**. These fuels include, but are not limited to, natural gas, methane, butane, butylene, ethane, ethylene, propane,

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

naphtha, propylene, jet fuel kerosene, No. 1 fuel oil, No. 2 fuel oil, and biodiesel. Stationary combustion turbines qualifying under this paragraph are only required to maintain purchase records for permitted fuels.

Compliance Demonstration

§60.5535 - How do I monitor and collect data to demonstrate compliance?

"(a) Combustion turbines qualifying under §60.5520(d)(1) are not subject to any requirements in this section other than the requirement to maintain fuel purchase records for permitted fuel(s)."

The Permittee shall maintain fuel purchase records as required by 40 CFR §60.5520(d)(1).

F. Control of Ammonia Emissions

CPCN#9136 which states the emissions from the two (2) combustion turbines shall not exceed the following emission limits:

Ammonia (when burning NG or ULSD) shall not exceed 5 ppmvd at 15% O₂ at all times, over an averaged period of 3 stack test runs. **[Reference: CPCN Case No. 9136, Condition B-IV-4]**

Compliance Demonstration

The Permittee shall conduct the stack testing every five (5) years for ammonia. Unless otherwise approved by the Department, the stack test shall be conducted in accordance with the following EPA approved test methods to determine compliance: (a) Conditional Test Method 027 – Procedure for Collection and Analysis of Ammonia in Stationary Sources. **[Reference: CPCN Case No. 9136, Condition B-IV-11]**

The Permittee may submit to the Department a request to reduce the frequency of stack testing for any pollutant listed in this condition. **[Reference: CPCN Case No. 9136, Condition B-IV-9]**

The Permittee shall operate and maintain the combustion turbines and associated air pollution control equipment in a manner consistent with good air pollution control practices for minimizing emissions at all times including during startup, shutdown, and malfunction. **[Reference: CPCN Case No. 9136, Condition B-IV-14]**

The Permittee shall maintain all annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine. **[Reference: CPCN Case No. 9136, Condition B-IV-23]**

The Permittee shall submit written notification to the Department and EPA the anticipated date of compliance testing and stack test protocol at least 30 days prior to such a date. Final results of all compliance stack tests must be submitted

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

to the Department within 60 days after completion of the test. **[Reference: CPCN Case No. 9136, Condition B-IV-24 and B-IV-25]**

G. Operational Limit

CPCN#9136 which states the combustion turbines may not exceed the following operational restrictions:

- (a) The total number of hours of operation for the two (2) combustion turbines, inclusive of startup and shutdown, shall not exceed 10,512 hours in any consecutive rolling 12-month period.
- (b) The total number of hours burning fuel oil on the two (2) combustion turbines, exclusive of startup and shutdown, shall not exceed 2,628 hours in any consecutive rolling 12-month period.
- (c) The total number of startup events (one or two turbines) shall not exceed 1,040 events in any consecutive rolling 12-month period.
- (d) The total number of shutdown events (one or two turbines) shall not exceed 1,040 events in any consecutive rolling 12-month period.

[Reference: CPCN Case No. 9136, Condition B-IV-2]

CPCN#9136 states A “*Startup Event*” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a startup event is defined as the period of time during which one CTs output is increased with the intent to startup, beginning with initiation of fuel combustion in one CT and ending when the SCR system catalyst reaches 600 degrees Fahrenheit. In the case of 2 CTs, the startup event begins at the point at which 1 CT initiates combustion and ends when the SCR system catalyst reaches 600F. **[Reference: CPCN Case No. 9136, Condition B-II-5]**

CPCN#9136 states A “*Shutdown Event*” as it relates to the CTs can involve either 1 CT or 2 CTs. In the case of 1 CT, a shutdown event is defined as the period of time during which one CTs output is lowered with the intent to shutdown, beginning at the point at which the load drops below 50% and ending when fuel combustion ceases. In the case a shutdown event of 2 CTs occurs, a shutdown event begins at the point at which the first CT drops below 50% and ends when fuel combustion for both CTs ceases. Notwithstanding the foregoing, if 2 CTs are in operation and 1 CT’s load is lowered below 50% with the intent to shutdown while the other CT continues in normal operation during and beyond the point fuel combustion ceases from the first Ct that shall not constitute a “Shutdown Event.” **[Reference: CPCN Case No. 9136, Condition B-II-4]**

Compliance Demonstration

The Permittee shall install ULSD and pipeline quality natural gas flow meters and continuously monitor each fuel flow into the two (2) combustion turbines. The fuel flow for each fuel shall be recorded monthly. **[Reference: CPCN Case No. 9136, Condition B-IV-7]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

The Permittee shall maintain all annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[Reference: CPCN Case No. 9136, Condition B-III-5]**

Monthly and 12-month consecutive rolling quantity of pipeline natural gas and ULSD for each combustion turbine, inclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, inclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, exclusive of startup events and shutdown events.

Monthly and 12-month consecutive rolling total number of startup events and shutdown events.

[Reference: CPCN Case No. 9136, Condition B-IV-23]

Emission Unit – EG6 & FWP6

EG6: One (1) diesel-fired emergency generator rated at 268 hp **(025-0024-9-0492)**.

FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp **(025-0024-9-0502)**

These generators will only be fired with ultra-low sulfur diesel (ULSD).

Compliance Status:

During the July 20, 2017 inspection, records of fuel sulfur from 2015, 2016 & 2017 were reviewed and deemed in compliance. The emergency engines have no operators on site and maintenance is performed by an outside contractor. Engines meet limits by manufacture certification.

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05E - Visible Emissions.

- (2) "Emissions during Idle Mode. A person may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.
- (3) Emissions during Operating Mode. A person may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.
- (4) Exceptions.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (a) Section E(2) of this regulation does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system.
- (b) Section E(3) of this regulation does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods: (i) Engines that are idled continuously when not in service: 30 minutes; (ii) All other engines: 15 minutes.
- (c) Sections E(2) and (3) of this regulation do not apply while maintenance, repair, or testing is being performed by qualified mechanics.”

Compliance Demonstration

The emergency generator and firewater pump engine shall be operated and maintained in accordance with the manufacturer’s emission-related written instructions, changing only those emission-related settings that are permitted by the manufacturer, and meet the requirements of 40 CFR Parts 89, 94, and/or 1068 as applicable. **[Reference: CPCN Case No. 9136, Condition B-V-10]**
The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations” **[Reference: COMAR 26.11.01.07 & COMAR 26.11.03.06C(7)]**

B. Control of Sulfur Oxides

COMAR 26.11.09.07A - Control of Sulfur Oxides From Fuel Burning Equipment. “A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: (2) In Areas III and IV: (b) Distillate fuel oils, 0.3 percent;”

The only permissible fuels for the emergency generator and the firewater pump engine is ULSD with a sulfur content not to exceed 15 parts per million by weight. **[Reference: CPCN Case No. 9136, Condition B-V-1]**
The emergency generator and firewater pump engine must be fitted with a non-resettable hour meter prior to startup of each engine. **[Reference: CPCN Case No. 9136, Condition B-V-9]**

Compliance Demonstration

The Permittee shall obtain a certification from the fuel oil supplier indicating that the oil complies with the limitation on the sulfur content of the fuel oil or obtain sulfur in fuel analyses of oil that is representative of oil burned.

[Reference: COMAR 26.11.09.07C]

The Permittee shall maintain:

All annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

A certification from the fuel supplier indicating that the ULSD complies with the limitation of sulfur content in the fuel oil. The certification should include the name of the supplier, the date of delivery, the amount of fuel delivered, the method used to determine the sulfur content of the oil, and a statement from the fuel supplier that the ULSD complies with the specifications of 40 CFR 80.510. **[Reference: CPCN Case No. 9136, Condition B-V-8 and 15]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[Reference: CPCN Case No. 9136, Condition B-III-5]**

For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling emissions;

For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling hours of operation;

For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling quantity of ULSD burned;

The reason the engine was in operation for each time operated.

[Reference: CPCN Case No. 9136, Condition B-V-17]

C. Control of Nitrogen Oxides

COMAR 26.11.09.08G - Requirements for Fuel-Burning Equipment with a Capacity Factor of 15 Percent or Less, and Combustion Turbines with a Capacity Factor Greater than 15 Percent.

“(1) A person who owns or operates fuel-burning equipment with a capacity factor (as defined in 40 CFR Part 72.2) of 15 percent or less shall:

(a) Provide certification of the capacity factor of the equipment to the Department in writing;

(b) For fuel-burning equipment that operates more than 500 hours during a calendar year, perform a combustion analysis and optimize combustion at least once annually;

(c) Maintain the results of the combustion analysis at the site for at least 2 years and make these results available to the Department and the EPA upon request;

(d) Require each operator of an installation, except combustion turbines, to attend operator training programs at least once every 3 years, on combustion optimization that are sponsored by the Department, the EPA, or equipment vendors; and

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

(e) Maintain a record of training program attendance for each operator at the site, and make these records available to the Department upon request.

Compliance Demonstration

The emergency generator and firewater pump engine must be fitted with a non-resettable hour meter prior to startup of each engine. **[Reference: CPCN Case No. 9136, Condition B-V-9]**

The Permittee shall maintain:

Results of any combustion analyses on the emergency generator or firewater pump engine. **[Reference: CPCN Case No. 9136, Condition B-V-12(a)]**

Records of training program attendance for each operator of the emergency generator and firewater pump engine. **[Reference: CPCN Case No. 9136, Condition B-V-12(b)]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[Reference: CPCN Case No. 9136, Condition B-III-5]**

For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling hours of operation.

The reason the engine was in operation for each time operated. **[Reference: CPCN Case No. 9136, Condition B-V-17]**

Emission Unit – EG6 & FWP6 (Cont'd)

EG6: One (1) diesel-fired emergency generator rated at 268 hp **(025-0024-9-0492)**.

FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp **(025-0024-9-0502)**.

These generators will only be fired with ultra-low sulfur diesel (ULSD).

Applicable Standards and limits:

NSPS

40 CFR 60 Subpart III - Standards of Performance for Stationary Compression Ignition Internal Combustion Engines

The emergency generator and the firewater pump engine must meet the following emissions limits for the entire life of the engines:

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Pollutant	Emergency Generator	Firewater Pump Engine
	Emissions Limit g/kW-hr (g/hp-hr)	Emissions Limit g/kW-hr (g/hp-hr)
NO _x + NMHC	4.0 (3.0)	4.0 (3.0)
CO	3.5 (2.5)	n/a
PM (filterable only)	0.20 (0.15)	0.20 (0.15)

[Reference: CPCN Case No. 9136, Condition B-V-4.]

Note the emergency generator actually installed on the project was 268 hp, not the 1300 hp engine specified in the application and CPCN. Thus, the emission limit for NO_x+NHMC was reduced from 6.4 to 4.0 g/kW-hr to reflect the requirements in 40 CFR 60, Subpart IIII.

The emergency generator and firewater pump engine must be certified to meet the emission standards of 40 CFR 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in paragraph 40 CFR 60.4211(g). **[Reference: CPCN Case No. 9136, Condition B-V-5(b)]**

The emergency generator may only be operated for emergencies, maintenance, and testing purposes; any other operation is prohibited. Operation of the emergency generator for maintenance and testing purposes is limited to a maximum of 100 hours per year. There is no limit on emergency usage.

[Reference: CPCN Case No. 9136, Condition B-V-5(c)]

The firewater pump engine may operate for emergencies, maintenance and testing purposes, and emergency demand response as defined in 40 CFR 60.4211(f)(1) and (2). Operation of the engine for maintenance, testing, and emergency demand response is limited to a maximum of 100 hours per year. There is no limit on emergency usage. **[Reference: CPCN Case No. 9136, Condition B-V-5(d)]**

The emergency generator and firewater pump engine shall not have PM₁₀ and PM_{2.5} total emissions (filterable and condensable) exceed 0.17 g/hp-hr with PM condensable emissions alone not to exceed 0.02 g/hp-hr. **[Reference: CPCN Case No. 9136, Condition B-V-7]**

NESHAP

To satisfy the requirements of 40 CFR Part 63, Subpart ZZZZ, the emergency generator and firewater pump engine shall comply with all the applicable requirements of NSPS Subpart IIII. **[Reference: CPCN Case No. 9136, Condition B-V-6]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Compliance Demonstration

NSPS

The emergency generator and firewater pump engine shall be operated and maintained in accordance with the manufacturer's emission-related written instructions, changing only those emission-related settings that are permitted by the manufacturer, and meet the requirements of 40 CFR Parts 89, 94, and/or 1068 as applicable. **[Reference: CPCN Case No. 9136, Condition B-V-10]**

The emergency generator and firewater pump engine must be fitted with a non-resettable hour meter prior to startup of each engine. **[Reference: CPCN Case No. 9136, Condition B-V-9]**

The Permittee shall maintain:

All annual fuel records for the project. **[Reference: CPCN Case No. 9136, Condition B-IV-21]**

Results of any combustion analyses on the emergency generator or firewater pump engine. **[Reference: CPCN Case No. 9136, Condition B-V-12(a)]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[Reference: CPCN Case No. 9136, Condition B-III-5]**

For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling emissions

For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling hours of operation.

The reason the engine was in operation for each time operated. **[Reference: CPCN Case No. 9136, Condition B-V-17]**

Emission Unit – FUG6, CB6 & PR6

FUG6: Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.

CB6: Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF₆).

PR6: Paved road emissions associated with the Perryman 6 Project. Emissions from this emission unit are assumed to be entirely PM_{2.5} and PM₁₀.

Applicable Standards and limits:

Operational Limit

For FUG6 only

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

GHG BACT Emission Limit - The GHG Emissions from **FUG6** shall be included as part of the Project-wide GHG Emissions limit listed in Condition B-III-3 of the CPCN#9136.

Pollutant	Project-Wide Emission Limit (tpy)
Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210

The Permittee shall implement an audio, visual, and olfactory (AVO) program to monitor fugitive GHG emissions. **[Reference: CPCN Case No. 9136, Condition B-VI-3]**

Compliance Demonstration

Monthly and 12-month consecutive rolling emissions for the FUG6 shall be calculated as follows:

The fugitive GHG emissions shall be based on EPA AP-42 emission factors, methodology described in 40 CFR Part 98 Subpart W, or other emission factors approved by the Department. **[Reference: CPCN Case No. 9136, Condition B-VI-2(a)]**

The total GHG emissions from FUG6 shall be presented on a CO₂e basis using the following global warming potential values:

Chemical Formula	Global Warming Potential
CO ₂	1
CH ₄	25

[Reference: CPCN Case No. 9136, Condition B-VI-2(b); 40 CFR 98]

The Permittee shall implement an audio, visual, and olfactory (AVO) program to monitor fugitive GHG emissions. These emissions shall be evaluated on a weekly basis from the natural gas pipeline and associated components through the AVO program. The AVO inspections shall be documented. Leaks identified from the AVO assessment shall be repaired within 5 days of discovery; repairs shall be documented, and associated repair records shall be maintained.

[Reference: CPCN Case No. 9136, Condition B-VI-3]

The Permittee shall maintain for at least five (5) years and make available to the Department upon request the following:

Records of monitoring and repair associated with fugitive emissions.

[Reference: CPCN Case No. 9136, Condition B-VI-4]

Monthly and 12-month consecutive rolling GHG emissions for FUG6. The emissions and supporting calculations shall be included in the quarterly report.

[Reference: CPCN Case No. 9136, Condition B-VI-5]

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[Reference: CPCN Case No. 9136, Condition B-III-5]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

Monthly and 12-month consecutive rolling GHG emissions from fugitive sources. **[Reference: CPCN Case No. 9136, Condition B-VI-5]**

For CB6 only

GHG BACT Emission Limit - The GHG Emissions from **CB6** shall be included as part of the Project-wide GHG Emissions limit listed in Condition B-III-3 of the CPCN#9136.

Pollutant	Project-Wide Emission Limit (tpy)
Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210

A state-of-the-art circuit breaker shall be installed that is designed to meet ANSI C37.013 or equivalent to detect and minimize SF₆ leaks. **[Reference: CPCN Case No. 9136, Condition B-VII-3]**

Compliance Demonstration

Monthly and 12-month consecutive rolling emissions for the CB6 shall be calculated as follows:

The GHG emissions from the circuit breaker shall be calculated using manufacturer provided leak rate, the methodology in 40 CFR 98, Subpart DD, and assuming 8,760 hours per year of operation. **[Reference: CPCN Case No. 9136, Condition B-VII-2(a)]**

The total GHG emissions from CB6 shall be presented on a CO₂e basis using a global warming potential value of 23,900 for SF₆. **[Reference: CPCN Case No. 9136, Condition B-VII-2(a)]; 40 CFR 98**

Leaks detected shall be repaired within 5 days of discovery; repairs shall be documented, and associated repair records shall be maintained. **[Reference: CPCN Case No. 9136, Condition B-VII-3]**

The Permittee shall maintain for at least five (5) years and make available to the Department upon request the following:

Records of all monitoring and repair associated with the circuit breaker.

[Reference: CPCN Case No. 9136, Condition B-VII-4]

Monthly and 12-month consecutive rolling GHG emissions for CB6. The emissions and supporting calculations shall be included in the quarterly report.

[Reference: CPCN Case No. 9136, Condition B-VII-5]

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Monthly and 12-month consecutive rolling GHG emissions from the circuit breaker. **[Reference: CPCN Case No. 9136, Condition B-VII-5]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

For PR6 only

BACT/LAER Emission Limits - The PM₁₀ and PM_{2.5} emissions from **PR6** shall be included as part of the Project-wide PM₁₀ and PM_{2.5} emissions limits listed in Condition B-III-3 of the CPCN#9136

Pollutant	Project-Wide Emission Limit (tpy)
Particulate Matter less than 10 microns (PM ₁₀) – Filterable and Condensable	43.0
Particulate Matter less than 2.5 microns (PM _{2.5}) – Filterable and Condensable	43.0

[Reference: CPCN Case No. 9136, Condition B-III-3]

Compliance Demonstration

The Permittee shall maintain for at least five (5) years and make available to the Department upon request the following:

Reasonable precautions shall be taken to prevent particulate matter from becoming airborne via paved roads. **[Reference: CPCN Case No. 9136, Condition B-VIII-3]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation: Monthly and 12-month consecutive rolling PM₁₀ and PM_{2.5} emissions from paved roads. **[Reference: CPCN Case No. 9136, Condition B-VIII-4]**

Emission Unit – CT6A, CT6B, EG6, FWP6, FUG6, CB6 & PR6 (Project-wide)

CT6A & CT6B

One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted. **[025-0024-5-0353 & 5-0354]**

EG6: One (1) diesel-fired emergency generator rated at 268 hp (025-0024-9-0492).

FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp (025-0024-9-0502)

FUG6: Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.

CB6: Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF₆).

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

PR6: Paved road emissions associated with the Perryman 6 Project. Emissions from this emission unit are assumed to be entirely PM_{2.5} and PM₁₀.

Applicable Standards and limits:

Operational Limit

Emissions for all sources identified as part of the Perryman 6 Project, including emissions during periods of startup and shutdown, shall be limited to the following, in tons per year, in any consecutive 12-month rolling period:

Pollutant	Project-Wide Emission Limit (tpy)
Greenhouse Gas (GHG) as Carbon Dioxide Equivalent (CO ₂ e)	430,210
Particulate Matter less than 10 microns (PM ₁₀) – Filterable and Condensable	43.0
Particulate Matter less than 2.5 microns (PM _{2.5}) – Filterable and Condensable	43.0
Nitrogen Dioxides (NO _x)	58.5

[Reference: CPCN Case No. 9136, Condition B-III-3]

Compliance Demonstration

The Permittee shall calculate monthly and consecutive rolling 12-month emissions (in tons per month and tons per year) of GHGs (as CO₂e), PM₁₀, PM_{2.5}, and NO_x for the entire Perryman 6 Project. **[Reference: CPCN Case No. 9136, Condition B-III-4]**

The GHG emissions for the project shall be calculated as follows:

(a) The total GHG emissions shall be presented on a CO₂e basis using the following global warming potential values:

Chemical Formula	Global Warming Potential
CO ₂	1
CH ₄	25
N ₂ O	298
SF ₆	23,900

(b) For the combustion turbines, the CO₂ emissions shall be based on fuel flow and the measured carbon content of the fuel using procedures specified in Appendix G of 40 CFR Part 75, or other emission factors approved by the Department. The CH₄ and N₂O emissions shall be calculated using the procedures specified in 40 CFR Part 98 Subpart C.

(c) The total generation of the combustion turbines shall be monitored to calculate the emission rate of lb CO₂e/MWh, determined each month

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

by summing the CO₂e emission for all hours in which power is being generated by the turbines during the previous 12 months and dividing that value by the sum of electrical energy output over that same period.

- (d) For the emergency generator and firewater pump engine, the GHG emissions shall be based on the methodology described in 40 CFR Part 98 Subpart C, or other emission factors approved by the Department.
- (e) The fugitive GHG emissions shall be based on EPA AP-42 emission factors, methodology described in 40 CFR Part 98 Subpart W, or other emission factors approved by the Department.
- (f) The GHG emissions from the circuit breaker shall be calculated using manufacturer provided leak rate, the methodology in 40 CFR 98, Subpart DD, and assuming 8,760 hours per year of operation.

The Permittee shall install ULSD and pipeline quality natural gas flow meters and continuously monitor each fuel flow into the two (2) combustion turbines. The fuel flow for each fuel shall be recorded monthly. **[Reference: CPCN Case No. 9136, Condition B-IV-7]**

The Permittee shall maintain the following:

The fuel flow for each fuel shall be recorded monthly. **[Reference: CPCN Case No. 9136, Condition B-IV-7]**

All CEMS reports submitted to the Department. **[Reference: CPCN Case No. 9136, Condition B-IV-20]**

The Permittee shall submit quarterly reports to the Department to be postmarked by the 30th day of the month following the end of each calendar quarter that includes the following emissions information and supporting documentation:

- (a) Monthly and consecutive rolling 12-month emissions (in tons per month and tons per year) of GHGs (as CO₂e), PM₁₀, PM_{2.5}, and NO_x for the entire Perryman 6 Project. **[Reference: CPCN Case No. 9136, Condition B-III-5(a)]**
- (b) Additional emissions source specific supporting documentation as defined within each emissions source section of conditions. **[COMAR 26.11.02.02H] [Reference: CPCN Case No. 9136, Condition B-III-5(b)]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (c) Monthly and 12-month consecutive rolling emissions and supporting calculations for each combustion turbine. **[Reference: CPCN Case No. 9136, Condition B-IV-23(a)]**
- (d) Monthly and 12-month consecutive rolling quantity of pipeline natural gas and ULSD for each combustion turbine, inclusive of startup events and shutdown events. **[Reference: CPCN Case No. 9136, Condition B-IV-23(b)]**
- (e) Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, inclusive of startup events and shutdown events. **[Reference: CPCN Case No. 9136, Condition B-IV-23(c)]**
- (f) Monthly and 12-month consecutive rolling hours of operation for each combustion turbine, exclusive of startup events and shutdown events. **[Reference: CPCN Case No. 9136, Condition B-IV-23(d)]**
- (g) Monthly and 12-month consecutive rolling total number of startup events and shutdown events. **[Reference: CPCN Case No. 9136, Condition B-IV-23(e)]**
- (h) Total NO_x emission expressed in lb/event for each startup event and shutdown event. **[Reference: CPCN Case No. 9136, Condition B-IV-23(f)]**
- (i) Monthly and 12-month consecutive rolling GHG emissions rate, expressed in lb/CO₂/MWh gross, for each combustion turbine for each fuel burned. **[Reference: CPCN Case No. 9136, Condition B-IV-23(g)]**
- (j) Monthly and 12-month consecutive rolling gross generation (MWh) for each combustion turbine for each fuel burned. **[Reference: CPCN Case No. 9136, Condition B-IV-23(h)]**
- (k) A quarterly CEMS summary report in a format approved by the Department and include the information required under COMAR 26.11.01.11E(2)(c)(i)-(vii). **[Reference: CPCN Case No. 9136, Condition B-IV-19(b)]**
- (l) For the emergency generator and firewater pump engine, the monthly and 12-month consecutive rolling emissions. **[Reference: CPCN Case No. 9136, Condition B-V-17(a)]**

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (m) Monthly and 12-month consecutive rolling GHG emissions from fugitive sources. **[Reference: CPCN Case No. 9136, Condition B-VI-5]**
- (n) Monthly and 12-month consecutive rolling GHG emissions from the circuit breaker. **[Reference: CPCN Case No. 9136, Condition B-VII-5]**
- (o) Monthly and 12-month consecutive rolling PM₁₀ and PM_{2.5} emissions from paved roads. **[Reference: CPCN Case No. 9136, Condition B-VIII-4]**
- (p) For any period where a combustion turbine burned ULSD, an explanation for why ULSD was burned. **[Reference: CPCN Case No. 9136, Condition B-IV-23(i)]**

Emission Unit – PY-Unit1, PY-Unit2, PY-Unit3, PY-Unit4, PY-Unit51, CT6A, CT6B, EG6, FWP6, FUG6, CB6 & PR6

Cross State Air Pollution Rule (CSAPR)

PY-Unit1, PY-Unit2, PY-Unit3, PY-Unit4

Four (4) Westinghouse model 501 simple cycle combustion turbines, each with a design heat input of 704 mm Btu/hr, rated at a nominal 51 megawatt output and capable of only burning No.2 distillate oil. **[12-4-0081 thru 12-4-0084]**

PY-Unit51

General Electric Frame 7FA stationary, single-shaft combustion turbine operating in the simple cycle mode, rated at a nominal 150-megawatt output. This turbine has dual fuel (natural gas and No. 2 oil) firing capacity. **[12-5-0088]**

CT6A & CT6B

One (1) Pratt & Whitney FT4000 SWIFTPAC gas turbine generator package, which consists of two (2) simple cycle combustion turbines (CTs), each with a nominal generating capacity of 60 MW (633 MMBtu), sharing a single stack. The CTs will combust pipeline-quality natural gas as a primary fuel, and only combust secondary fuel, ultra-low sulfur diesel fuel (ULSD) fuel oil (with a sulfur content not to exceed 0.0015% by weight) during periods when natural gas supply has been interrupted. **[025-0024-5-0353 & 5-0354]**

EG6: One (1) diesel-fired emergency generator rated at 268 hp **(025-0024-9-0492)**.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

FWP6: One (1) diesel-fired emergency firewater pump engine rated at 350 hp
(025-0024-9-0502)

FUG6: Natural gas pipeline associated with the Perryman 6 Project, including valves, connectors, flanges, pumps seals, and pressure relief devices.

CB6: Circuit breaker associated with the Perryman 6 Project. The circuit breaker contains sulfur hexafluoride (SF₆).

PR6: Paved road emissions associated with the Perryman 6 Project. Emissions from this emission unit are assumed to be entirely PM_{2.5} and PM₁₀.

Applicable Standards and limits:

TR SO₂ Group 1 - Trading Program 40 CFR Part 97 Subpart CCCCC

The Permittee shall comply with the provisions and requirements of §97.601 through §97.635.

Note: §97.606(c) SO₂ emissions requirements. For TR SO₂ Group 1 emissions limitation: As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall hold, in the source's compliance account, TR SO₂ Group 1 allowances available for deduction for such control period under §97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all TR SO₂ Group 1 units at the source.

Allowance transfer deadline means, for a control period in a given year, midnight of March 1 (if it is a business day), or midnight of the first business day thereafter (if March 1 is not a business day), immediately after such control period and is the deadline by which a TR SO₂ Group 1 allowance transfer must be submitted for recordation in a TR SO₂ Group 1 source's compliance account in order to be available for use in complying with the source's TR SO₂ Group 1 emissions limitation for such control period in accordance with §§97.606 and 97.624.

TR NO_x Annual Trading Program 40 CFR Part 97 Subpart AAAAA

The Permittee shall comply with the provisions and requirements of §97.401 through §97.435.

Note: §97.406(c) NO_x emissions requirements. For TR NO_x Annual emissions limitation: As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall hold, in the source's compliance account, TR NO_x Annual allowances available for deduction for such control period under §97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Annual units at the source.

Allowance transfer deadline means, for a control period in a given year, midnight of March 1 (if it is a business day), or midnight of the first business day thereafter

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

(if March 1 is not a business day), immediately after such control period and is the deadline by which a TR NO_x Annual allowance transfer must be submitted for recordation in a TR NO_x Annual source's compliance account in order to be available for use in complying with the source's TR NO_x Annual emissions limitation for such control period in accordance with §§97.406 and 97.424.

TR NO_x Ozone Season Trading Program 40 CFR Part 97 Subpart BBBBB

The Permittee shall comply with the provisions and requirements of §97.501 through §97.535.

Note: §97.506(c) NO_x emissions requirements. For TR NO_x Ozone Season emissions limitation: As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, TR NO_x Ozone Season allowances available for deduction for such control period under §97.524(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Ozone Season units at the source.

Allowance transfer deadline means, for a control period in a given year, midnight of December 1 (if it is a business day), or midnight of the first business day thereafter (if December 1 is not a business day), immediately after such control period and is the deadline by which a TR NO_x Ozone Season allowance transfer must be submitted for recordation in a TR NO_x Ozone Season source's compliance account in order to be available for use in complying with the source's TR NO_x Ozone Season emissions limitation for such control period in accordance with §§97.506 and 97.524.

Compliance Demonstration

The Permittee shall comply with the monitoring, recordkeeping and reporting requirements found in §97.606, §97.630, §97.631, §97.632, and §97.633.

The Permittee operates continuous emission monitoring system (CEMS) pursuant to 40 CFR Part 75, Subpart B (for SO₂ monitoring) and 40 CFR Part 75, Subpart H (for NO_x monitoring).

The Permittee shall comply with the monitoring, recordkeeping and reporting requirements found in §97.406, §97.430, §97.431, §97.432, and §97.433 for the NO_x Annual Trading Program and §97.506, §97.530, §97.531, §97.532, and §97.533 for the NO_x Ozone Season Trading Program.

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

COMPLIANCE SCHEDULE

The Perryman Generating Station is currently in compliance with all applicable air quality regulations.

TITLE IV – ACID RAIN

Emission Units PY-Unit51, CT6A and CT6B are subject to the Acid Rain Program requirements. The Phase II Acid Rain Permit renewal will be issued in conjunction with this Part 70 permit.

TITLE VI – OZONE DEPLETING SUBSTANCES

The Perryman Generating Station is subject to 40 CFR 82, Subpart F. Perryman shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR Part 82, Subpart F.

SECTION 112(r) – ACCIDENTAL RELEASE

The Perryman Generating Station is not subject to the requirements of Section 112(r).

PERMIT SHIELD

The Perryman Generating Station requested that a permit shield be expressly included in the Permittee's Part 70 permit. Permit shields are granted on an emission unit by emission unit basis. If an emission unit is covered by a permit shield, a permit shield statement will follow the emission unit table in Section IV - Plant Specific Conditions of the permit. In this case, a permit shield was granted for each emission unit covered by the permit.

INSIGNIFICANT ACTIVITIES

This section provides a list of insignificant emissions units that were reported in the Title V permit application. The applicable Clean Air Act requirements, if any, are listed below the insignificant activity.

- (1) No. 2 Stationary internal combustion engines with an output less than 500 brake horsepower (373 kilowatts) and which are not used to generate electricity for sale or for peak or load shaving;

The affected units are subject to the following requirements:

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (A) COMAR 26.11.09.05E(2), Emissions During Idle Mode: The Permittee may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.
- (B) COMAR 26.11.09.05E(3), Emissions During Operating Mode: The Permittee may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.
- (C) Exceptions:
 - (i) COMAR 26.11.09.05E(2) does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system.
 - (ii) COMAR 26.11.09.05E(2) does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods:
 - (a) Engines that are idled continuously when not in service: 30 minutes
 - (b) all other engines: 15 minutes.
 - (iii) COMAR 26.11.09.05E(2) & (3) do not apply while maintenance, repair or testing is being performed by qualified mechanics.

- (2) ✓ Space heaters utilizing direct heat transfer and used solely for comfort heat;
- (3) ✓ Charbroilers and pit barbecues as defined in COMAR 26.11.18.01 with a total cooking area of 5 square feet (0.46 square meter) or less;
- (4) ✓ Comfort air conditioning subject to requirements of Title VI of the Clean Air Act;

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

STATE ONLY ENFORCEABLE REQUIREMENTS

This section of the permit contain state-only enforceable requirements. The requirements in this section will not be enforced by the U.S. Environmental Protection Agency. The requirements in this section are not subject to COMAR 26.11.03 10 - Public Petitions for Review to EPA Regarding Part 70 Permits.

1. Applicable Regulations:

COMAR 26.11.06.08 - Nuisance.

"An installation or premises may not be operated or maintained in such a manner that a nuisance or air pollution is created. Nothing in this regulation relating to the control of emissions may in any manner be construed as authorizing or permitting the creation of, or maintenance of, nuisance or air pollution."

COMAR 26.11.06.09 - Odors.

"A person may not cause or permit the discharge into the atmosphere of gases, vapors, or odors beyond the property line in such a manner that a nuisance or air pollution is created."

2. Operating Conditions:

Annotated Code of Maryland, Environment, Title 2, and Subtitle 5 – Temporary Fuel Variances. The Permittee may file a petition to the Department to request a temporary fuel variance in accordance with the procedures specified under this subtitle.

3. CO₂ Budget Permit

The Permittee shall comply with the requirements of the CO₂ Budget Permit issued for Perryman Generating Station. Note: A CO₂ Budget Permit will be issued in conjunction with this Part 70 permit and is attached to the Part 70 permit as Appendix C.

4. Record Keeping and Reporting:

The Permittee shall submit to the Department, by April 1 of each year during the term of this permit, a written certification of the results of an analysis of emissions of toxic air pollutants from the Permittee's facility during the previous calendar year. The analysis shall include either:

- (a) a statement that previously submitted compliance demonstrations for emissions of toxic air pollutants remain valid; or

**CONSTELLATION POWER SOURCE GENERATION, LLC
PERRYMAN GENERATING STATION
PERMIT NO. 24-025-0024
PART 70 OPERATING PERMIT FACT SHEET**

- (b) a revised compliance demonstration, developed in accordance with requirements included under COMAR 26.11.15 & 16, that accounts for changes in operations, analytical methods, emissions determinations, or other factors that have invalidated previous demonstrations.