

KEEP PERMIT AT SITE

CONTROL NO. B- 05931

Larry Hogan
Governor



Ben Grumbles
Secretary

Boyd Rutherford
Lieutenant Governor

DEPARTMENT OF THE ENVIRONMENT
Air and Radiation Administration
1800 Washington Boulevard, Suite 720
Baltimore, MD 21230

Construction Permit

Part 70
 Operating Permit

PERMIT NO. 24-015-0202

DATE ISSUED NOV - 1 2019

PERMIT FEE To be paid in accordance with
COMAR 26.11.02.19B

EXPIRATION DATE October 31, 2024

LEGAL OWNER & ADDRESS
Rock Springs Generation Facility
1423 Rock Springs Road
Rising Sun, MD 21911
Attn: Mr. Ralph Jones, General Manager

SITE
Same
Cecil County

SOURCE DESCRIPTION

One Natural Gas-fired Power Generation Plant.

This source is subject to the conditions described on the attached pages.

Page 1 of 79

William Paul
Program Manager

Angel Bravino
Director, Air and Radiation Administration

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

SECTION I	SOURCE IDENTIFICATION	4
1.	DESCRIPTION OF FACILITY	4
2.	FACILITY INVENTORY LIST	4
SECTION II	GENERAL CONDITIONS	6
1.	DEFINITIONS	6
2.	ACRONYMS	6
3.	EFFECTIVE DATE	7
4.	PERMIT EXPIRATION	7
5.	PERMIT RENEWAL	7
6.	CONFIDENTIAL INFORMATION	8
7.	PERMIT ACTIONS	8
8.	PERMIT AVAILABILITY	9
9.	REOPENING THE PART 70 PERMIT FOR CAUSE BY THE EPA	9
10.	TRANSFER OF PERMIT	9
11.	REVISION OF PART 70 PERMITS – GENERAL CONDITIONS	9
12.	SIGNIFICANT PART 70 OPERATING PERMIT MODIFICATIONS	10
13.	MINOR PERMIT MODIFICATIONS	11
14.	ADMINISTRATIVE PART 70 OPERATING PERMIT AMENDMENTS	14
15.	OFF-PERMIT CHANGES TO THIS SOURCE	16
16.	ON-PERMIT CHANGES TO SOURCES	17
17.	FEE PAYMENT	19
18.	REQUIREMENTS FOR PERMITS-TO-CONSTRUCT AND APPROVALS	19
19.	CONSOLIDATION OF PROCEDURES FOR PUBLIC PARTICIPATION	20
20.	PROPERTY RIGHTS	21
21.	SEVERABILITY	21
22.	INSPECTION AND ENTRY	21
23.	DUTY TO PROVIDE INFORMATION	22
24.	COMPLIANCE REQUIREMENTS	22
25.	CREDIBLE EVIDENCE	23
26.	NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE	23
27.	CIRCUMVENTION	23
28.	PERMIT SHIELD	23
29.	ALTERNATE OPERATING SCENARIOS	24
SECTION III	PLANT WIDE CONDITIONS	25
1.	PARTICULATE MATTER FROM CONSTRUCTION AND DEMOLITION	25
2.	OPEN BURNING	25
3.	AIR POLLUTION EPISODE	25
4.	REPORT OF EXCESS EMISSIONS AND DEVIATIONS	25
5.	ACCIDENTAL RELEASE PROVISIONS	26
6.	GENERAL TESTING REQUIREMENTS	27
7.	EMISSIONS TEST METHODS	27
8.	EMISSIONS CERTIFICATION REPORT	28
9.	COMPLIANCE CERTIFICATION REPORT	29
10.	CERTIFICATION BY RESPONSIBLE OFFICIAL	30
11.	SAMPLING AND EMISSIONS TESTING RECORD KEEPING	30

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

12.	GENERAL RECORDKEEPING	31
13.	GENERAL CONFORMITY	31
14.	ASBESTOS PROVISIONS.....	31
15.	OZONE DEPLETING REGULATIONS.....	32
16.	ACID RAIN PERMIT.....	32
SECTION IV	PLANT SPECIFIC CONDITIONS.....	33
SECTION V	INSIGNIFICANT ACTIVITIES	78
SECTION VI	STATE-ONLY ENFORCEABLE CONDITIONS	79

ATTACHMENTS:

Acid Rain Permit

CO2 Budget Permit

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

SECTION I SOURCE IDENTIFICATION

1. DESCRIPTION OF FACILITY

The Rock Springs Generation Facility, located at 1423 Rock Springs Road in Rising Sun, Maryland 21911 (Cecil County), is a simple-cycle natural gas-fired power generation plant. Its applicable Standard Industrial Classification (SIC) Code is 4911-Electric Services.

The facility is permitted for six (6) General Electric 7 FA gas turbines, each rated 190 MW at base load, zero degrees ambient temperature. Each turbine operates in simple cycle mode and combusts only pipeline quality natural gas. Each turbine is equipped with dry, low-NO_x burners. All four turbines (EU 1-4) are limited to a combined 8,000 hours of operation per year, based on a cumulative 12-month rolling average.

Four of the six turbines were installed in October 2001, and the remaining two (EU-5 and EU-6) were never installed. Each of the four operating combustion turbines is equipped with a single discharge stack.

The plant also includes two (2) [7.5 & 9.0] million British Thermal Units per hour (MMBtu/hr) natural gas-fired heaters and one (1) 200 horsepower (hp) emergency diesel firewater pump and one (1) 4-stroke cycle, 6 cylinder switchyard diesel-fired emergency generator.

2. FACILITY INVENTORY LIST

Emissions Unit Number	MDE - ARA Registration Number	Emissions Unit Name and Description	Date of Installation
EU-1	5-0076	Four (4) General Electric 7 FA gas turbines, each with a maximum output of 190 MW	October 2001
EU-2	5-0077		
EU-3	5-0078		
EU-4	5-0079		
EU-7	6-0205	One (1) 9 million Btu per hour natural gas fired heater equipped with low NO _x burners.	2001
EU-8	N/A	One (1) 200 horsepower (hp) emergency diesel fire-water engine and pump.	September 2002
EU-9	N/A	One (1) 100 kilowatt (kW) emergency diesel switchyard generator.	September 2002
EU-10	015-0202-5-0148	One (1) 7.5 million Btu per hour natural gas fired heater equipped with low NO _x	November 2017

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Emissions Unit Number	MDE - ARA Registration Number	Emissions Unit Name and Description	Date of Installation
		burners.	

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

SECTION II GENERAL CONDITIONS

1. DEFINITIONS

[COMAR 26.11.01.01] and [COMAR 26.11.02.01]

The words or terms in this Part 70 permit shall have the meanings established under COMAR 26.11.01 and .02 unless otherwise stated in this permit.

2. ACRONYMS

ARA	Air and Radiation Administration
BACT	Best Available Control Technology
Btu	British thermal unit
CAA	Clean Air Act
CAM	Compliance Assurance Monitoring
CEM	Continuous Emissions Monitor
CFR	Code of Federal Regulations
CO	Carbon Monoxide
COMAR	Code of Maryland Regulations
EPA	United States Environmental Protection Agency
FR	Federal Register
gr	grains
HAP	Hazardous Air Pollutant
MACT	Maximum Achievable Control Technology
MDE	Maryland Department of the Environment
MVAC	Motor Vehicle Air Conditioner
NESHAPS	National Emission Standards for Hazardous Air Pollutants
NO _x	Nitrogen Oxides
NSPS	New Source Performance Standards
NSR	New Source Review
OTR	Ozone Transport Region
PM	Particulate Matter
PM10	Particulate Matter with Nominal Aerodynamic Diameter of 10 micrometers or less
ppm	parts per million
ppb	parts per billion
PSD	Prevention of Significant Deterioration
PTC	Permit to construct
PTO	Permit to operate (State)
SIC	Standard Industrial Classification
SO ₂	Sulfur Dioxide

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

TAP	Toxic Air Pollutant
tpy	tons per year
VE	Visible Emissions
VOC	Volatile Organic Compounds

3. EFFECTIVE DATE

The effective date of the conditions in this Part 70 permit is the date of permit issuance, unless otherwise stated in the permit.

4. PERMIT EXPIRATION

[COMAR 26.11.03.13B(2)]

Upon expiration of this permit, the terms of the permit will automatically continue to remain in effect until a new Part 70 permit is issued for this facility provided that the Permittee has submitted a timely and complete application and has paid applicable fees under COMAR 26.11.02.16.

Otherwise, upon expiration of this permit the right of the Permittee to operate this facility is terminated.

5. PERMIT RENEWAL

[COMAR 26.11.03.02B(3)] and [COMAR 26.11.03.02E]

The Permittee shall submit to the Department a completed application for renewal of this Part 70 permit at least 12 months before the expiration of the permit. Upon submitting a completed application, the Permittee may continue to operate this facility pending final action by the Department on the renewal.

The Permittee, upon becoming aware that any relevant facts were omitted or incorrect information was submitted in the permit application, shall submit such supplementary facts or corrected information no later than 10 days after becoming aware that this occurred. The Permittee shall also provide additional information as necessary to address any requirements that become applicable to the facility after the date a completed application was submitted, but prior to the release of a draft permit. This information shall be submitted to the Department no later than 20 days after a new requirement has been adopted.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

6. CONFIDENTIAL INFORMATION

[COMAR 26.11.02.02G]

In accordance with the provisions of the State Government Article, Sec. 10-611 et seq., Annotated Code of Maryland, all information submitted in an application shall be considered part of the public record and available for inspection and copying, unless the Permittee claims that the information is confidential when it is submitted to the Department. At the time of the request for inspection or copying, the Department will make a determination with regard to the confidentiality of the information. The Permittee, when requesting confidentiality, shall identify the information in a manner specified by the Department and, when requested by the Department, promptly provide specific reasons supporting the claim of confidentiality. Information submitted to the Department without a request that the information be deemed confidential may be made available to the public. Subject to approval of the Department, the Permittee may provide a summary of confidential information that is suitable for public review. The content of this Part 70 permit is not subject to confidential treatment.

7. PERMIT ACTIONS

[COMAR 26.11.03.06E(3)] and [COMAR 26.11.03.20(A)]

This Part 70 permit may be revoked or reopened and revised for cause. The filing of an application by the Permittee for a permit revision or renewal; or a notification of termination, planned changes or anticipated noncompliance by the facility, does not stay a term or condition of this permit.

The Department shall reopen and revise, or revoke the Permittee's Part 70 permit under the following circumstances:

- a. Additional requirements of the Clean Air Act become applicable to this facility and the remaining permit term is 3 years or more;
- b. The Department or the EPA determines that this Part 70 permit contains a material mistake, or is based on false or inaccurate information supplied by or on behalf of the Permittee;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- c. The Department or the EPA determines that this Part 70 permit must be revised or revoked to assure compliance with applicable requirements of the Clean Air Act; or
- d. Additional requirements become applicable to an affected source under the Federal Acid Rain Program.

8. PERMIT AVAILABILITY

[COMAR 26.11.02.13G]

The Permittee shall maintain this Part 70 permit in the vicinity of the facility for which it was issued, unless it is not practical to do so, and make this permit immediately available to officials of the Department upon request.

9. REOPENING THE PART 70 PERMIT FOR CAUSE BY THE EPA

[COMAR 26.11.03.20B]

The EPA may terminate, modify, or revoke and reissue a permit for cause as prescribed in 40 CFR §70.7(g)

10. TRANSFER OF PERMIT

[COMAR 26.11.02.02E]

The Permittee shall not transfer this Part 70 permit except as provided in COMAR 26.11.03.15.

11. REVISION OF PART 70 PERMITS – GENERAL CONDITIONS

[COMAR 26.11.03.14] and [COMAR 26.11.03.06A(8)]

- a. The Permittee shall submit an application to the Department to revise this Part 70 permit when required under COMAR 26.11.03.15 -.17.
- b. When applying for a revision to a Part 70 permit, the Permittee shall comply with the requirements of COMAR 26.11.03.02 and .03 except that the application for a revision need include only information listed that is related to the proposed change to the source and revision to

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

the permit. This information shall be sufficient to evaluate the proposed change and to determine whether it will comply with all applicable requirements of the Clean Air Act.

- c. The Permittee may not change any provision of a compliance plan or schedule in a Part 70 permit as an administrative permit amendment or as a minor permit modification unless the change has been approved by the Department in writing.
- d. A permit revision is not required for a change that is provided for in this permit relating to approved economic incentives, marketable permits, emissions trading, and other similar programs.

12. SIGNIFICANT PART 70 OPERATING PERMIT MODIFICATIONS

[COMAR 26.11.03.17]

The Permittee may apply to the Department to make a significant modification to its Part 70 Permit as provided in COMAR 26.11.03.17 and in accordance with the following conditions:

- a. A significant modification is a revision to the federally enforceable provisions in the permit that does not qualify as an administrative permit amendment under COMAR 26.11.03.15 or a minor permit modification as defined under COMAR 26.11.03.16.
- b. This permit does not preclude the Permittee from making changes, consistent with the provisions of COMAR 26.11.03, that would make the permit or particular terms and conditions of the permit irrelevant, such as by shutting down or reducing the level of operation of a source or of an emissions unit within the source. Air pollution control equipment shall not be shut down or its level of operation reduced if doing so would violate any term of this permit.
- c. Significant permit modifications are subject to all requirements of COMAR 26.11.03 as they apply to permit issuance and renewal, including the requirements for applications, public participation, and review by affected states and EPA, except:
 - (1) An application need include only information pertaining to the proposed change to the source and modification of this permit, including a description of the change and modification, and any

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

new applicable requirements of the Clean Air Act that will apply if the change occurs;

- (2) Public participation, and review by affected states and EPA, is limited to only the application and those federally enforceable terms and conditions of the Part 70 permit that are affected by the significant permit modification.
- d. As provided in COMAR 26.11.03.15B(5), an administrative permit amendment may be used to make a change that would otherwise require a significant permit modification if procedures for enhanced preconstruction review of the change are followed that satisfy the requirements of 40 CFR 70.7(d)(1)(v).
- e. Before making a change that qualifies as a significant permit modification, the Permittee shall obtain all permits-to-construct and approvals required by COMAR 26.11.02.
- f. The Permittee shall not make a significant permit modification that results in a violation of any applicable requirement of the Clean Air Act.
- g. The permit shield in COMAR 26.11.03.23 applies to a final significant permit modification that has been issued by the Department, to the extent applicable under COMAR 26.11.03.23.

13. MINOR PERMIT MODIFICATIONS

[COMAR 26.11.03.16]

The Permittee may apply to the Department to make a minor modification to the federally enforceable provisions of this Part 70 permit as provided in COMAR 26.11.03.16 and in accordance with the following conditions:

- a. A minor permit modification is a Part 70 permit revision that:
 - (1) Does not result in a violation of any applicable requirement of the Clean Air Act;
 - (2) Does not significantly revise existing federally enforceable monitoring, including test methods, reporting, record keeping, or compliance certification requirements except by:

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- (a) Adding new requirements,
 - (b) Eliminating the requirements if they are rendered meaningless because the emissions to which the requirements apply will no longer occur, or
 - (c) Changing from one approved test method for a pollutant and source category to another;
- (3) Does not require or modify a:
- (a) Case-by-case determination of a federally enforceable emissions standard,
 - (b) Source specific determination for temporary sources of ambient impacts, or
 - (c) Visibility or increment analysis;
- (4) Does not seek to establish or modify a federally enforceable permit term or condition for which there is no corresponding underlying applicable requirement of the Clean Air Act, but that the Permittee has assumed to avoid an applicable requirement to which the source would otherwise be subject, including:
- (a) A federally enforceable emissions standard applied to the source pursuant to COMAR 26.11.02.03 to avoid classification as a Title I modification; and
 - (b) An alternative emissions standard applied to an emissions unit pursuant to regulations promulgated under Section 112(i)(5) of the Clean Air Act
- (5) Is not a Title I modification; and
- (6) Is not required under COMAR 26.11.03.17 to be processed as a significant modification to this Part 70 permit.
- b. Application for a Minor Permit Modification

The Permittee shall submit to the Department an application for a minor permit modification that satisfies the requirements of COMAR 26.11.03.03 which includes the following:

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- (1) A description of the proposed change, the emissions resulting from the change, and any new applicable requirements that will apply if the change is made;
- (2) The proposed minor permit modification;
- (3) Certification by a responsible official, in accordance with COMAR 26.11.02.02F, that:
 - (a) The proposed change meets the criteria for a minor permit modification, and
 - (b) The Permittee has obtained or applied for all required permits-to-construct required by COMAR 26.11.03.16 with respect to the proposed change;
- (4) Completed forms for the Department to use to notify the EPA and affected states, as required by COMAR 26.11.03.07-.12.

c. Permittee's Ability to Make Change

- (1) For changes proposed as minor permit modifications to this permit that will require the applicant to obtain a permit to construct, the permit to construct must be issued prior to the new change.
- (2) During the period of time after the Permittee applies for a minor modification but before the Department acts in accordance with COMAR 26.11.03.16F(2):
 - (a) The Permittee shall comply with applicable requirements of the Clean Air Act related to the change and the permit terms and conditions described in the application for the minor modification.
 - (b) The Permittee is not required to comply with the terms and conditions in the permit it seeks to modify. If the Permittee fails to comply with the terms and conditions in the application during this time, the terms and conditions of both this permit and the application for modification may be enforced against it.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- d. The Permittee is subject to enforcement action if it is determined at any time that a change made under COMAR 26.11.03.16 is not within the scope of this regulation.
- e. Minor permit modification procedures may be used for Part 70 permit modifications involving the use of economic incentives, marketable permits, emissions trading, and other similar approaches, but only to the extent that the minor permit modification procedures are explicitly provided for in regulations approved by the EPA as part of the Maryland SIP or in other applicable requirements of the Clean Air Act.

14. ADMINISTRATIVE PART 70 OPERATING PERMIT AMENDMENTS

[COMAR 26.11.03.15]

The Permittee may apply to the department to make an administrative permit amendment as provided in COMAR 26.11.03.15 and in accordance with the following conditions:

- a. An application for an administrative permit amendment shall:
 - (1) Be in writing;
 - (2) Include a statement certified by a responsible official that the proposed amendment meets the criteria in COMAR 26.11.03.15 for an administrative permit amendment, and
 - (3) Identify those provisions of this part 70 permit for which the amendment is requested, including the basis for the request.
- b. An administrative permit amendment:
 - (1) Is a correction of a typographical error;
 - (2) Identifies a change in the name, address, or phone number of a person identified in this permit, or a similar administrative change involving the Permittee or other matters which are not directly related to the control of air pollution;
 - (3) requires more frequent monitoring or reporting by the Permittee;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- (4) Allows for a change in ownership or operational control of a source for which the Department determines that no other revision to the permit is necessary and is documented as per COMAR 26.11.03.15B(4);
 - (5) Incorporates into this permit the requirements from preconstruction review permits or approvals issued by the Department in accordance with COMAR 26.11.03.15B(5), but only if it satisfies 40 CFR 70.7(d)(1)(v);
 - (6) Incorporates any other type of change, as approved by the EPA, which is similar to those in COMAR 26.11.03.15B(1)—(4);
 - (7) Notwithstanding COMAR 26.11.03.15B(1)—(6), all modifications to acid rain control provisions included in this Part 70 permit are governed by applicable requirements promulgated under Title IV of the Clean Air Act; or
 - (8) Incorporates any change to a term or condition specified as State-only enforceable, if the Permittee has obtained all necessary permits-to-construct and approvals that apply to the change.
- c. The Permittee may make the change addressed in the application for an administrative amendment upon receipt by the Department of the application, if all permits-to-construct or approvals otherwise required by COMAR 26.11.02 prior to making the change have first been obtained from the Department.
 - d. The permit shield in COMAR 26.11.03.23 applies to administrative permit amendments made under Section B(5) of COMAR 26.11.03.15 , but only after the Department takes final action to revise the permit.
 - e. The Permittee is subject to enforcement action if it is determined at any time that a change made under COMAR 26.11.03.15 is not within the scope of this regulation.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

15. OFF-PERMIT CHANGES TO THIS SOURCE

[COMAR 26.11.03.19]

The Permittee may make off-permit changes to this facility as provided in COMAR 26.11.03.19 and in accordance with the following conditions:

- a. The Permittee may make a change to this permitted facility that is not addressed or prohibited by the federally enforceable conditions of this Part 70 permit without obtaining a Part 70 permit revision if:
 - (1) The Permittee has obtained all permits and approvals required by COMAR 26.11.02 and .03;
 - (2) The change is not subject to any requirements under Title IV of the Clean Air Act;
 - (3) The change is not a Title I modification; and
 - (4) The change does not violate an applicable requirement of the Clean Air Act or a federally enforceable term or condition of the permit.
- b. For a change that qualifies under COMAR 26.11.03.19, the Permittee shall provide contemporaneous written notice to the Department and the EPA, except for a change to an emissions unit or activity that is exempt from the Part 70 permit application, as provided in COMAR 26.11.03.04. This written notice shall describe the change, including the date it was made, any change in emissions, including the pollutants emitted, and any new applicable requirements of the Clean Air Act that apply as a result of the change.
- c. Upon satisfying the requirements of COMAR 26.11.03.19, the Permittee may make the proposed change.
- d. The Permittee shall keep a record describing:
 - (1) Changes made at the facility that result in emissions of a regulated air pollutant subject to an applicable requirement of the Clean Air Act , but not otherwise regulated under this permit; and
 - (2) The emissions resulting from those changes.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- e. Changes that qualify under COMAR 26.11.03.19 are not subject to the requirements for Part 70 revisions.
- f. The Permittee shall include each off-permit change under COMAR 26.11.03.19 in the application for renewal of the part 70 permit.
- g. The permit shield in COMAR 26.11.03.23 does not apply to off-permit changes made under COMAR 26.11.03.19.
- h. The Permittee is subject to enforcement action if it is determined that an off-permit change made under COMAR 26.11.03.19 is not within the scope of this regulation.

16. ON-PERMIT CHANGES TO SOURCES

[COMAR 26.11.03.18]

The Permittee may make on-permit changes that are allowed under Section 502(b)(10) of the Clean Air Act as provided in COMAR 26.11.03.18 and in accordance with the following conditions:

- a. The Permittee may make a change to this facility without obtaining a revision to this Part 70 permit if:
 - (1) The change is not a Title I modification;
 - (2) The change does not result in emissions in excess of those expressly allowed under the federally enforceable provisions of the Part 70 permit for the permitted facility or for an emissions unit within the facility, whether expressed as a rate of emissions or in terms of total emissions;
 - (3) The Permittee has obtained all permits and approvals required by COMAR 26.11.02 and .03;
 - (4) The change does not violate an applicable requirement of the Clean Air Act;
 - (5) The change does not violate a federally enforceable permit term or condition related to monitoring, including test methods, record keeping, reporting, or compliance certification requirements;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- (6) The change does not violate a federally enforceable permit term or condition limiting hours of operation, work practices, fuel usage, raw material usage, or production levels if the term or condition has been established to limit emissions allowable under this permit;
 - (7) If applicable, the change does not modify a federally enforceable provision of a compliance plan or schedule in this Part 70 permit unless the Department has approved the change in writing; and
 - (8) This permit does not expressly prohibit the change under COMAR 26.11.03.18.
- b. The Permittee shall notify the Department and the EPA in writing of a proposed on-permit change under COMAR 26.11.03.18 not later than 7 days before the change is made. The written information shall include the following information:
- (1) A description of the proposed change;
 - (2) The date on which the change is proposed to be made;
 - (3) Any change in emissions resulting from the change, including the pollutants emitted;
 - (4) Any new applicable requirement of the Clean Air Act; and
 - (5) Any permit term or condition that would no longer apply.
- c. The responsible official of this facility shall certify in accordance with COMAR 26.11.02.02F that the proposed change meets the criteria for the use of on-permit changes under COMAR 26.11.03.18.
- d. The Permittee shall attach a copy of each notice required by condition b. above to this Part 70 permit.
- e. On-permit changes that qualify under COMAR 26.11.03.18 are not subject to the requirements for part 70 permit revisions.
- f. Upon satisfying the requirements under COMAR 26.11.03.18, the Permittee may make the proposed change.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- g. The permit shield in COMAR 26.11.03.23 does not apply to on-permit changes under COMAR 26.11.03.18.
- h. The Permittee is subject to enforcement action if it is determined that an on-permit change made under COMAR 26.11.03.18 is not within the scope of the regulation or violates any requirement of the State air pollution control law.

17. FEE PAYMENT

[COMAR 26.11.02.16A(2) & (5)(b)]

- a. The fee for this Part 70 permit is as prescribed in Regulation .19 of COMAR 26.11.02.
- b. The fee is due on and shall be paid on or before each 12-month anniversary date of the permit.
- c. Failure to pay the annual permit fee constitutes cause for revocation of the permit by the Department.

18. REQUIREMENTS FOR PERMITS-TO-CONSTRUCT AND APPROVALS

[COMAR 26.11.02.09.]

The Permittee may not construct or modify or cause to be constructed or modified any of the following sources without first obtaining, and having in current effect, the specified permits-to-construct and approvals:

- a. New Source Review source, as defined in COMAR 26.11.01.01, approval required, except for generating stations constructed by electric companies;
- b. Prevention of Significant Deterioration source, as defined in COMAR 26.11.01.01, approval required, except for generating stations constructed by electric companies;
- c. New Source Performance Standard source, as defined in COMAR 26.11.01.01, permit to construct required, except for generating stations constructed by electric companies;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- d. National Emission Standards for Hazardous Air Pollutants source, as defined in COMAR 26.11.01.01, permit to construct required, except for generating stations constructed by electric companies;
- e. A stationary source of lead that discharges one ton per year or more of lead or lead compounds measured as elemental lead, permit to construct required, except for generating stations constructed by electric companies;
- f. All stationary sources of air pollution, including installations and air pollution control equipment, except as listed in COMAR 26.11.02.10, permit to construct required;
- g. In the event of a conflict between the applicability of (a.— e.) above and an exemption listed in COMAR 26.11.02.10, the provision that requires a permit applies.
- h. Approval of a PSD or NSR source by the Department does not relieve the Permittee obtaining an approval from also obtaining all permits-to-construct required by (c.— g.) above.

19. CONSOLIDATION OF PROCEDURES FOR PUBLIC PARTICIPATION

[COMAR 26.11.02.11C] and [COMAR 26.11.03.01K]

The Permittee may request the Department to authorize special procedures for the Permittee to apply simultaneously, to the extent possible, for a permit to construct and a revision to this permit.

These procedures may provide for combined public notices, informational meetings, and public hearings for both permits but shall not adversely affect the rights of a person, including EPA and affected states, to obtain information about the application for a permit, to comment on an application, or to challenge a permit that is issued.

These procedures shall not alter any existing permit procedures or time frames.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

20. PROPERTY RIGHTS

[COMAR 26.11.03.06E(4)]

This Part 70 permit does not convey any property rights of any sort, or any exclusive privileges.

21. SEVERABILITY

[COMAR 26.11.03.06A(5)]

If any portion of this Part 70 permit is challenged, or any term or condition deemed unenforceable, the remainder of the requirements of the permit continues to be valid.

22. INSPECTION AND ENTRY

[COMAR 26.11.03.06G(3)]

The Permittee shall allow employees and authorized representatives of the Department, the EPA, and local environmental health agencies, upon presentation of credentials or other documents as may be required by law, to:

- a. Enter at a reasonable time without delay and without prior notification the Permittee's property where a Part 70 source is located, emissions-related activity is conducted, or records required by this permit are kept;
- b. Have access to and make copies of records required by the permit;
- c. Inspect all emissions units within the facility subject to the permit and all related monitoring systems, air pollution control equipment, and practices or operations regulated or required by the permit; and
- d. Sample or monitor any substances or parameters at or related to the emissions units at the facility for the purpose of determining compliance with the permit.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

23. DUTY TO PROVIDE INFORMATION

[COMAR 26.11.03.06E(5)]

The Permittee shall furnish to the Department, within a reasonable time specified by the Department, information requested in writing by the Department in order to determine whether the Permittee is in compliance with the federally enforceable conditions of this Part 70 permit, or whether cause exists for revising or revoking the permit. Upon request, the Permittee shall also furnish to the Department records required to be kept under the permit.

For information claimed by the Permittee to be confidential and therefore potentially not discloseable to the public, the Department may require the Permittee to provide a copy of the records directly to the EPA along with a claim of confidentiality.

The Permittee shall also furnish to the Department, within a reasonable time specified by the Department, information or records requested in writing by the Department in order to determine if the Permittee is in compliance with the State-only enforceable conditions of this permit.

24. COMPLIANCE REQUIREMENTS

[COMAR 26.11.03.06E(1)] and [COMAR 26.11.03.06A(11)] and [COMAR 26.11.02.05]

The Permittee shall comply with the conditions of this Part 70 permit. Noncompliance with the permit constitutes a violation of the Clean Air Act, and/or the Environment Article Title 2 of the Annotated Code of Maryland and may subject the Permittee to:

- a. Enforcement action,
- b. Permit revocation or revision,
- c. Denial of the renewal of a Part 70 permit, or
- d. Any combination of these actions.

The conditions in this Part 70 permit are enforceable by EPA and citizens under the Clean Air Act except for the State-only enforceable conditions.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Under Environment Article Section 2-609, Annotated Code of Maryland, the Department may seek immediate injunctive relief against a person who violates this permit in such a manner as to cause a threat to human health or the environment.

25. CREDIBLE EVIDENCE

Nothing in this permit shall be interpreted to preclude the use of credible evidence to demonstrate noncompliance with any term of this permit.

26. NEED TO HALT OR REDUCE ACTIVITY NOT A DEFENSE

[COMAR 26.11.03.06E(2)]

The need to halt or reduce activity in order to comply with the conditions of this permit may not be used as a defense in an enforcement action.

27. CIRCUMVENTION

[COMAR 26.11.01.06]

The Permittee may not install or use any article, machine, equipment or other contrivance, the use of which, without resulting in a reduction in the total weight of emissions, conceals or dilutes emissions which would otherwise constitute a violation of any applicable air pollution control regulation.

28. PERMIT SHIELD

[COMAR 26.11.03.23]

A permit shield as described in COMAR 26.11.03.23 shall apply only to terms and conditions in this Part 70 permit that have been specifically identified as covered by the permit shield. Neither this permit nor COMAR 26.11.03.23 alters the following:

- a. The emergency order provisions in Section 303 of the Clean Air Act, including the authority of EPA under that section;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- b. The liability of the Permittee for a violation of an applicable requirement of the Clean Air Act before or when this permit is issued or for a violation that continues after issuance;
- c. The requirements of the Acid Rain Program, consistent with Section 408(a) of the Clean Air Act;
- d. The ability of the Department or EPA to obtain information from a source pursuant to Maryland law and Section 114 of the Clean Air Act; or
- e. The authority of the Department to enforce an applicable requirement of the State air pollution control law that is not an applicable requirement of the Clean Air Act.

29. ALTERNATE OPERATING SCENARIOS

[COMAR 26.11.03.06A(9)]

For all alternate operating scenarios approved by the Department and contained within this permit, the Permittee, while changing from one approved scenario to another, shall contemporaneously record in a log maintained at the facility each scenario under which the emissions unit is operating and the date and time the scenario started and ended.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

SECTION III PLANT WIDE CONDITIONS

1. PARTICULATE MATTER FROM CONSTRUCTION AND DEMOLITION

[COMAR 26.11.06.03D]

The Permittee shall not cause or permit any building, its appurtenances, or a road to be used, constructed, altered, repaired, or demolished without taking reasonable precautions to prevent particulate matter from becoming airborne.

2. OPEN BURNING

[COMAR 26.11.07]

Except as provided in COMAR 26.11.07.04, the Permittee shall not cause or permit an open fire from June 1 through August 31 of any calendar year. Prior to any open burning, the Permittee shall request and receive approval from the Department.

3. AIR POLLUTION EPISODE

[COMAR 26.11.05.04]

When requested by the Department, the Permittee shall prepare in writing standby emissions reduction plans, consistent with good industrial practice and safe operating procedures, for reducing emissions creating air pollution during periods of Alert, Warning, and Emergency of an air pollution episode.

4. REPORT OF EXCESS EMISSIONS AND DEVIATIONS

[COMAR 26.11.01.07] and [COMAR 26.11.03.06C(7)]

The Permittee shall comply with the following conditions for occurrences of excess emissions and deviations from requirements of this permit, including those in Section VI – State-only Enforceable Conditions:

- a. Report any deviation from permit requirements that could endanger human health or the environment, by orally notifying the Department immediately upon discovery of the deviation;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- b. Promptly report all occurrences of excess emissions that are expected to last for one hour or longer by orally notifying the Department of the onset and termination of the occurrence;
- c. When requested by the Department the Permittee shall report all deviations from permit conditions, including those attributed to malfunctions as defined in COMAR 26.11.01.07A, within 5 days of the request by submitting a written description of the deviation to the Department. The written report shall include the cause, dates and times of the onset and termination of the deviation, and an account of all actions planned or taken to reduce, eliminate, and prevent recurrence of the deviation;
- d. The Permittee shall submit to the Department semi-annual monitoring reports that confirm that all required monitoring was performed, and that provide accounts of all deviations from permit requirements that occurred during the reporting periods. Reporting periods shall be January 1 through June 30 and July 1 through December 31, and reports shall be submitted within 30 days of the end of each reporting period. Each account of deviation shall include a description of the deviation, the dates and times of onset and termination, identification of the person who observed or discovered the deviation, causes and corrective actions taken, and actions taken to prevent recurrence. If no deviations from permit conditions occurred during a reporting period, the Permittee shall submit a written report that so states.
- e. When requested by the Department, the Permittee shall submit a written report to the Department within 10 days of receiving the request concerning an occurrence of excess emissions. The report shall contain the information required in COMAR 26.11.01.07D(2).

5. ACCIDENTAL RELEASE PROVISIONS

[COMAR 26.11.03.03B(23)] and [40 CFR 68]

Should the Permittee become subject to 40 CFR 68 during the term of this permit, the Permittee shall submit risk management plans by the date specified in 40 CFR 68.150 and shall certify compliance with the requirements of 40 CFR 68 as part of the annual compliance certification as required by 40 CFR 70.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

The Permittee shall initiate a permit revision or reopening according to the procedures of 40 CFR 70.7 to incorporate appropriate permit conditions into the Permittee's Part 70 permit.

6. GENERAL TESTING REQUIREMENTS

[COMAR 26.11.01.04]

The Department may require the Permittee to conduct, or have conducted, testing to determine compliance with this Part 70 permit. The Department, at its option, may witness or conduct these tests. This testing shall be done at a reasonable time, and all information gathered during a testing operation shall be provided to the Department.

7. EMISSIONS TEST METHODS

[COMAR 26.11.01.04]

Compliance with the emissions standards and limitations in this Part 70 permit shall be determined by the test methods designated and described below or other test methods submitted to and approved by the Department.

Reference documents of the test methods approved by the Department include the following:

- a. 40 CFR 60, appendix A
- b. 40 CFR 51, appendix M
- c. The Department's Technical Memorandum 91-01 "Test Methods and Equipment Specifications for Stationary Sources", (January 1991), as amended through Supplement 3, (October 1, 1997)

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

8. EMISSIONS CERTIFICATION REPORT

**[COMAR 26.11.01.05-1] and [COMAR 26.11.02.19C] and
[COMAR 26.11.02.19D]**

The Permittee shall certify actual annual emissions of regulated pollutants from the facility on a calendar year basis.

- a. The certification shall be on forms obtained from the Department and submitted to the Department not later than April 1 of the year following the year for which the certification is required;
- b. The individual making the certification shall certify that the information is accurate to the individual's best knowledge. The individual shall be:
 - (1) Familiar with each source for which the certifications forms are submitted, and
 - (2) Responsible for the accuracy of the emissions information;
- c. The Permittee shall maintain records necessary to support the emissions certification including the following information if applicable:
 - (1) The total amount of actual emissions of each regulated pollutant and the total of all regulated pollutants;
 - (2) An explanation of the methods used to quantify the emissions and the operating schedules and production data that were used to determine emissions, including significant assumptions made;
 - (3) Amounts, types and analyses of all fuels used;
 - (4) Emissions data from continuous emissions monitors that are required by this permit, including monitor calibration and malfunction information;
 - (5) Identification, description, and use records of all air pollution control equipment and compliance monitoring equipment including:

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- (a) Significant maintenance performed,
 - (b) Malfunctions and downtime, and
 - (c) Episodes of reduced efficiency of all equipment;
- (6) Limitations on source operation or any work practice standards that significantly affect emissions; and
- (7) Other relevant information as required by the Department.

9. COMPLIANCE CERTIFICATION REPORT

[COMAR 26.11.03.06G(6) and (7)]

The Permittee shall submit to the Department and EPA Region III a report certifying compliance with each term of this Part 70 permit including each applicable standard, emissions limitation, and work practice for the previous calendar year by April 1 of each year.

- a. The compliance certification shall include:
 - (1) The identification of each term or condition of this permit which is the basis of the certification;
 - (2) The compliance status;
 - (3) Whether the compliance was continuous or intermittent;
 - (4) The methods used for determining the compliance status of each source, currently and over the reporting period; and
 - (5) Any other information required to be reported to the Department that is necessary to determine the compliance status of the Permittee with this permit.
- b. The Permittee shall submit the compliance certification reports to the Department and EPA simultaneously.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

10. CERTIFICATION BY RESPONSIBLE OFFICIAL

[COMAR 26.11.02.02F]

All application forms, reports, and compliance certifications submitted pursuant to this permit shall be certified by a responsible official as to truth, accuracy, and completeness. The Permittee shall expeditiously notify the Department of an appointment of a new responsible official.

The certification shall be in the following form:

“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.”

11. SAMPLING AND EMISSIONS TESTING RECORD KEEPING

[COMAR 26.11.03.06C(5)]

The Permittee shall gather and retain the following information when sampling and testing for compliance demonstrations:

- a. The location as specified in this permit, and the date and time that samples and measurements are taken;
- b. All pertinent operating conditions existing at the time that samples and measurements are taken;
- c. The date that each analysis of a sample or emissions test is performed and the name of the person taking the sample or performing the emissions test;
- d. The identity of the Permittee, individual, or other entity that performed the analysis;
- e. The analytical techniques and methods used; and

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

- f. The results of each analysis.

12. GENERAL RECORDKEEPING

[COMAR 26.11.03.06C(6)]

The Permittee shall retain records of all monitoring data and information that support the compliance certification for a period of five (5) years from the date that the monitoring, sample measurement, application, report or emissions test was completed or submitted to the Department.

These records and support information shall include:

- a. All calibration and maintenance records;
- b. All original data collected from continuous monitoring instrumentation;
- c. Records which support the annual emissions certification; and
- d. Copies of all reports required by this permit.

13. GENERAL CONFORMITY

[COMAR 26.11.26.09]

The Permittee shall comply with the general conformity requirements of 40 CFR 93, Subpart B and COMAR 26.11.26.09.

14. ASBESTOS PROVISIONS

[40 CFR 61, Subpart M]

The Permittee shall comply with 40 CFR 61, Subpart M when conducting any renovation or demolition activities at the facility.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

15. OZONE DEPLETING REGULATIONS

[40 CFR 82, Subpart F]

The Permittee shall comply with the standards for recycling and emissions reduction pursuant to 40 CFR 82, Subpart F, except as provided for MVACs in subpart B:

- a. Persons opening appliances for maintenance, service, repair, or disposal shall comply with the prohibitions and required practices pursuant to 40 CFR 82.154 and 82.156.
- b. Equipment used during the maintenance, service, repair or disposal of appliances shall comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- c. Persons performing maintenance, service, repairs or disposal of appliances shall be certified by an approved technician certification program pursuant to 40 CFR 82.161.
- d. Persons disposing of small appliances, MVACS, and MVAC-like appliances as defined in 40 CFR 82.152, shall comply with record keeping requirements pursuant to 40 CFR 82.155.
- e. Persons owning commercial or industrial process refrigeration equipment shall comply with the leak repair requirements pursuant to 40 CFR 82.156.
- f. Owners/operators of appliances normally containing 50 or more pounds of refrigerant shall keep records of refrigerant purchased and added to such appliances pursuant to 40 CFR 82.166.

16. ACID RAIN PERMIT

Not applicable

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

SECTION IV PLANT SPECIFIC CONDITIONS

This section provides tables that include the emissions standards, emissions limitations, and work practices applicable to each emissions unit located at this facility. The Permittee shall comply with all applicable emissions standards, emissions limitations and work practices included herein.

The tables also include testing, monitoring, record keeping and reporting requirements specific to each emissions unit. In addition to the requirements included here in **Section IV**, the Permittee is also subject to the general testing, monitoring, record keeping and reporting requirements included in **Section III – Plant Wide Conditions** of this permit.

Unless otherwise provided in the specific requirements for an emissions unit, the Permittee shall maintain at the facility for at least five (5) years, and shall make available to the Department upon request, all records that the Permittee is required under this section to establish. [Reference: **COMAR 26.11.03.06C(5)(g)**]

Table IV – 1	
1.0	<p><u>Emissions Unit Number(s) - Combustion Turbines</u></p> <p>EU-1 thru EU-4 – Four (4) identical simple cycle mode combustion turbines fueled by natural gas and rated 190 MW at base load, zero degrees ambient temperature. Each turbine operates in simple cycle mode and combusts only pipeline quality natural gas. Each turbine is equipped with dry, low-NO_x burners. (5-0076 thru 5-0079)</p>
1.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05A(1)–Fuel Burning Equipment. “In Areas, I, II, V, and VI, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is greater than 20 percent opacity.” <u>Exceptions.</u> “Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, start-up, or adjustments or occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40 percent opacity; and (b) The visible emissions do not occur for more than sixty consecutive minute period.”</p> <p>B. <u>Control of Particulate Matter Emissions</u> Concentration of PM₁₀ shall not exceed 18 lb/hr when not injecting</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 1

wastewater into the turbine exhaust stacks and 31.2 lb/hr for each turbine when wastewater is being injected into the turbine exhaust and shall not exceed 134.5 tpy for all six combustion turbines (*only 4 units installed*) combined on a 12-month rolling cumulative basis. **[Reference: CPCN #8821, Condition #14(a)(iii) & #17].**

C. Control of Sulfur Oxide Emissions

40 CFR 60.333 – NSPS Subpart GG which limits sulfur content in any fuel burned a gas turbine to 0.8 wt %.

“SO₂ emissions shall not exceed 2.5 lb/hr for each combustion turbine, and 15 tpy for all six combustion turbines (*only 4 units installed*) combined in on a 12-month rolling cumulative basis.” **[Reference: CPCN #8821, Condition #17]**

Note: Compliance with these limitations will be by the use of fuel supplier certifications.

Phase II Acid Rain Permit: The Permittee shall comply with the requirements of the Phase II Acid Rain Permit. (See Appendix A)

Cross-State Air Pollution Rule

See Table IV-1a.- CSAPR

D-Control of Nitrogen Oxide Emissions

40 CFR 60.332 – NSPS Subpart GG which limits each turbine to 75 ppmvd NO_x emissions at 15% O₂.

BACT shall be the use of natural gas fuel only, operation of advanced dry low-NO_x burner technology, and application of good combustion practices so that: “Concentrations of NO_x shall not exceed 9 parts per million by volume on dry basis (ppmvd) at 15% oxygen on a 30-day rolling average basis for each combustion turbine and the maximum one-hour average NO_x concentrations shall not exceed 10.5 ppmvd at 15% oxygen for each combustion turbine.” **[Reference: CPCN #8821, Condition 14(a)(i)]**

Note: Compliance shall be demonstrated by use of CEM.

“LAER for NO_x shall be the use of natural gas only, operation of advanced dry low-NO_x burner technology, and application of good combustion practices. Concentrations of NO_x shall not exceed 9 ppmvd at 15% oxygen on a 30-day rolling average basis (except during startup and shutdown) for each combustion turbine. Maximum 1-hour average (except during startup and shutdown) shall not exceed 10.5 ppmvd at

**ROCK SPRINGS GENERATION FACILITY
 1423 ROCK SPRINGS ROAD
 RISING SUN, MARYLAND 21911
 PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 1

	<p>15% oxygen. NO_x emissions shall not exceed 64 lb/hr per turbine and 384 tons per year for all six turbines (<i>only 4 units installed</i>) combined on a 12-month rolling cumulative basis.” [Reference: CPCN #8821, Condition #14a(i), 15, 17a & MDE April 29, 2003 Letter] Note: Compliance shall be demonstrated by use of CEM</p> <p><u>Cross-State Air Pollution Rule</u> See Table IV-1a.- CSAPR</p> <p><u>E Control of VOC Emissions</u> VOC emissions shall not exceed 3 lb/hr for each combustion turbine, and 18 tpy for all six combustion turbines (<i>only 4 units installed</i>) combined in on a 12-month rolling cumulative basis. [Reference: CPCN #8821, Condition #17]</p> <p><u>F Control of Carbon Monoxide Emissions</u> “BACT for CO shall be good combustion practices. Concentration of CO shall not exceed 9 ppmvd at 15% oxygen for each combustion turbine on a 30-day rolling average basis for each combustion turbine. Emissions of CO shall not exceed 32 lb/hr (except during startup and shutdown) from each combustion turbine and 192 tons per year for all six combustion turbines (<i>only 4 units installed</i>) combined on a 12-month rolling cumulative basis.” [Reference: CPCN #8821, Condition #14(a)(ii), 17 & MDE April 29, 2003 Letter].</p> <p><u>G Operational Limitations</u> “The Operating hours for the six combustion turbines (<i>only 4 units installed</i>) combined shall not exceed 12,000 hours per year, on a 12-month rolling cumulative basis. The period of time during which the Permittee shall inject a wastewater stream into the turbine exhaust stack shall be limited to 4000 hours per year total.” [Reference: CPCN #8821, Condition #16]</p> <p>Note: In addition, based on the installation of four combustion turbines, the allowable aggregate hours of operation cannot exceed 8000 hrs, an average of 2000 hours per combustion turbine.</p>
1.2	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 1	
	<p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall stack test one of the four identical units at least once during the life of the permit. The Permittee shall submit a test protocol to the Department for approval at least 30 days prior to the proposed test date. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> See Monitoring Requirements.</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall perform QC/QA procedures as required by 40 CFR 75.10(a)(2). [Reference: COMAR 26.11.03.06C]</p> <p>E. <u>Control of VOC Emissions</u> The Permittee shall stack test one of the four identical units at least once during the life of the permit. The Permittee shall submit a test protocol to the Department for approval at least 30 days prior to the proposed test date. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall perform QC/QA procedures as required by 40 CFR 60, Appendix F [Reference: COMAR 26.11.03.06C]</p> <p>G. <u>Operational Limitations</u> See Monitoring Requirements.</p>
1.3	<p><u>Monitoring Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p> <p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall perform preventative maintenance to maintain the turbine in a condition such that it operates as designed. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall monitor the sulfur content and nitrogen content of the fuel being burned in the turbine. The frequency of determination of these values shall be as follows: (1) If the turbine is supplied its fuel from a bulk storage tank, the value shall be determined on each occasion that fuel is transferred to the storage tank from any other source.</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 1

	<p>(2) If the turbine is supplied without intermediate bulk storage the values shall be determined and recorded daily. The Permittee may develop custom schedules for determination of values based on design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with paragraph (b) of this section. [Reference: 40 CFR 60.334(b)]</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall operate, calibrate and maintain a CEMS to monitor the NO_x emissions from each turbine. [Reference: CPCN #8821, Condition #9(o)]. The Permittee shall certify CEM system in accordance with 40 CFR 75, Appendix A. [Reference: 40 CFR §75.70]</p> <p>40 CFR 60.334(a) - NSPS Subpart GG which require any stationary turbine using water injection to control NO_x emissions to install and operate a Continuous Emissions Monitoring system to monitor and record the fuel being fired and the consumption and the ratio of water to fuel being fired in the turbine (and shall be accurate to within +/- 5.0% and shall be approved by the Administrator).</p> <p>40 CFR 60.334(b) - NSPS Subpart GG which require the Permittee to monitor the nitrogen content of the fuel. (See Condition C above)</p> <p>E. <u>Control of VOC Emissions</u> The Permittee shall perform preventative maintenance to maintain the turbine in a condition such that it operates as designed. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall use a CEM to monitor CO emissions. [Reference: COMAR 26.11.03.06C]</p> <p>G. <u>Operational Limitations</u> The Permittee shall perform preventative maintenance to maintain the turbine as designed. [Reference: COMAR 26.11.03.06C]</p>
1.4	<p><u>Record Keeping Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 1	
	<p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance and records of the stack test results. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall maintain on site for at least five years documents certifying the sulfur content of gas received or copies of the sulfur in fuel analyses. [Reference: COMAR 26.11.03.06C]</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall maintain records necessary to prepare a quarterly emissions reports that contain the requirements of COMAR 26.11.01.10G(2)(d). [Reference: COMAR 26.11.03.06C].</p> <p>E. <u>Control of VOC Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance and records of the stack test results. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall maintain records of the CO CEMs data. [Reference: COMAR 26.11.03.06C]</p> <p>G. <u>Operational Limitations</u> The Permittee shall record the hours of operation. [Reference: COMAR 26.11.03.06C]</p>
1.5	<p><u>Reporting Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.</p> <p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall submit records of maintenance to the Department upon request. The Permittee shall submit the results of any stack tests within 45 days after completion of the stack test. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> For the purpose of reports required under §60.7(c), periods of excess emissions are any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 percent. The Permittee shall</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 1

submit a summary report of excess emissions semiannually. All reports shall be postmarked by the 30th day following the end of each six-month period. **[Reference: 40CFR 60.334(c) and 60.7(c)]**

D. Control of Nitrogen Oxide Emissions

The Permittee shall submit a quarterly summary report to the Department not later than 30 days following each calendar quarter. The report shall be in a format approved by the Department, and shall include the following:

- (1) The cause, time periods, and magnitude of all emissions which exceed the applicable emission standards;
- (2) The source downtime including the time and date of the beginning and end of each downtime period and whether the source downtime was planned or unplanned;
- (3) The time periods and cause of all CEM downtime including records of any repairs, adjustments, or maintenance that may affect the validity of emission data;
- (4) Quarterly totals of excess emissions, installation downtime, and CEM downtime during the calendar quarter;
- (5) Quarterly quality assurance activities; and
- (6) Daily calibration activities that include reference values, actual values, absolute or percent of span differences, and drift status; and
- (7) Other information required by the Department that is determined to be necessary to evaluate the data, to ensure that compliance is achieved, or to determine the applicability of this regulation.” **[Reference: COMAR 26.11.09.08K(1) and COMAR 26.11.01.10G(2)(d)]**

E. Control of VOC Emissions

The Permittee shall submit records of maintenance to the Department upon request. The Permittee shall submit the results of any stack tests within 45 days after completion of the stack test. **[Reference: COMAR 26.11.03.06C]**

F. Control of Carbon Monoxide Emissions

The Permittee shall submit quarterly, the summaries of valid CEMs data for CO concentrations. The quarterly summary reports shall satisfy the reporting requirements of COMAR 26.11.01.10G(2)(d). **[Reference: COMAR 26.11.03.06C]**

G. Operational Limitations

The Permittee shall submit to the Department hours of operation. **[Reference: COMAR 26.11.03.06C].**

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

Table IV-1a: Cross State Air Pollution Rule (CSAPR)	
1a.0	<p><u>Emissions Unit Number(s): Combustion Turbines (Cont'd)</u></p> <p>EU-1 thru EU-4 – Four (4) identical simple cycle mode combustion turbines fueled by natural gas and rated 190 MW at base load, zero degrees ambient temperature. Each turbine operates in simple cycle mode and combusts only pipeline quality natural gas. Each turbine is equipped with dry, low-NO_x burners. (5-0076 thru 5-0079)</p>
1a.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. 40 CFR Part 97 Subpart AAAAA-TR NO_x Annual Trading Program TR NO_x Annual Trading Program requirements (40 CFR 97.406)</p> <p>(a) Designated representative requirements. The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.413 through 97.418.</p> <p>(b) Emissions monitoring, reporting, and recordkeeping requirements.</p> <p>(1) The owners and operators, and the designated representative, of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.430 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.431 (initial monitoring system certification and recertification procedures), 97.432 (monitoring system out-of-control periods), 97.433 (notifications concerning monitoring), 97.434 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.435 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).</p> <p>(2) The emissions data determined in accordance with 40 CFR 97.430 through 97.435 shall be used to calculate allocations of TR NO_x Annual allowances under 40 CFR 97.411(a)(2) and (b) and 97.412 and to determine compliance with the TR NO_x Annual emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV–1a: Cross State Air Pollution Rule (CSAPR)

calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.430 through 97.435 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.

(c) NO_x emissions requirements.

(1) TR NO_x Annual emissions limitation.

- (i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall hold, in the source's compliance account, TR NO_x Annual allowances available for deduction for such control period under 40 CFR 97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Annual units at the source.
- (ii). If total NO_x emissions during a control period in a given year from the TR NO_x Annual units at a TR NO_x Annual source are in excess of the TR NO_x Annual emissions limitation set forth in paragraph (c)(1)(i) above, then:
 - (A). The owners and operators of the source and each TR NO_x Annual unit at the source shall hold the TR NO_x Annual allowances required for deduction under 40 CFR 97.424(d); and
 - (B). The owners and operators of the source and each TR NO_x Annual unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.

(2) TR NO_x Annual assurance provisions.

- (i). If total NO_x emissions during a control period in a given year from all TR NO_x Annual units at TR NO_x Annual sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO_x Annual

**ROCK SPRINGS GENERATION FACILITY
 1423 ROCK SPRINGS ROAD
 RISING SUN, MARYLAND 21911
 PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV–1a: Cross State Air Pollution Rule (CSAPR)

	<p>allowances available for deduction for such control period under 40 CFR 97.425(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.425(b), of multiplying— (A) The quotient of the amount by which the common designated representative’s share of such NO_x emissions exceeds the common designated representative’s assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative’s share of such NO_x emissions exceeds the respective common designated representative’s assurance level; and (B) The amount by which total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the state for such control period exceed the state assurance level.</p> <p>(ii). The owners and operators shall hold the TR NO_x Annual allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.</p> <p>(iii). Total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the State during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the state NO_x Annual trading budget under 40 CFR 97.410(a) and the state’s variability limit under 40 CFR 97.410(b).</p> <p>(iv). It shall not be a violation of 40 CFR part 97, subpart AAAAA or of the Clean Air Act if total NO_x emissions from all TR NO_x Annual units at TR NO_x Annual sources in the State during a control period exceed the state assurance level or if a common designated representative’s share of total NO_x emissions from the TR NO_x Annual units at TR NO_x Annual sources in the state during a control period exceeds the common designated representative’s assurance level.</p> <p>(v). To the extent the owners and operators fail to hold TR NO_x Annual allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above, (A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and (B). Each TR NO_x Annual allowance that the owners and operators fail to hold for such control period in accordance</p>
--	--

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)

	<p>with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart AAAAA and the Clean Air Act.</p> <p>(3) Compliance periods.</p> <p style="padding-left: 20px;">(i). A TR NO_x Annual unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015, or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.</p> <p style="padding-left: 20px;">(ii). A TR NO_x Annual unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.430(b) and for each control period thereafter.</p> <p>(4) Vintage of allowances held for compliance.</p> <p style="padding-left: 20px;">(i). A TR NO_x Annual allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO_x Annual allowance that was allocated for such control period or a control period in a prior year.</p> <p style="padding-left: 20px;">(ii). A TR NO_x Annual allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO_x Annual allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.</p> <p>(5) Allowance Management System requirements. Each TR NO_x Annual allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart AAAAA.</p> <p>(6) Limited authorization. A TR NO_x Annual allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:</p> <p style="padding-left: 20px;">(i). Such authorization shall only be used in accordance with the TR NO_x Annual Trading Program; and</p> <p style="padding-left: 20px;">(ii). Notwithstanding any other provision of 40 CFR part 97, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.</p> <p>(7) Property right. A TR NO_x Annual allowance does not constitute a property right.</p>
--	--

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)

(d) Title V permit revision requirements.

- (1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO_x Annual allowances in accordance with 40 CFR part 97, subpart AAAAA.
- (2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.430 through 97.435, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.406(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

- (1) Unless otherwise provided, the owners and operators of each TR NO_x Annual source and each TR NO_x Annual unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.
 - (i). The certificate of representation under 40 CFR 97.416 for the designated representative for the source and each TR NO_x Annual unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.416 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart AAAAA.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO_x Annual Trading Program.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)

(2) The designated representative of a TR NO_x Annual source and each TR NO_x Annual unit at the source shall make all submissions required under the TR NO_x Annual Trading Program, except as provided in 40 CFR 97.418. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

(f) Liability.

(1) Any provision of the TR NO_x Annual Trading Program that applies to a TR NO_x Annual source or the designated representative of a TR NO_x Annual source shall also apply to the owners and operators of such source and of the TR NO_x Annual units at the source.

(2) Any provision of the TR NO_x Annual Trading Program that applies to a TR NO_x Annual unit or the designated representative of a TR NO_x Annual unit shall also apply to the owners and operators of such unit.

(g) Effect on other authorities.

No provision of the TR NO_x Annual Trading Program or exemption under 40 CFR 97.405 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO_x Annual source or TR NO_x Annual unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

B. 40 CFR Part 97 Subpart BBBB-TR NO_x Ozone Season Trading Program

TR NO_x Ozone Season Trading Program Requirements (40 CFR 97.506)

(a) Designated representative requirements.

The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.513 through 97.518.

(b) Emissions monitoring, reporting, and recordkeeping requirements.

(1) The owners and operators, and the designated representative, of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.530 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.531 (initial monitoring system certification and recertification procedures), 97.532 (monitoring

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)

	<p>system out-of-control periods), 97.533 (notifications concerning monitoring), 97.534 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.535 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).</p> <p>(2) The emissions data determined in accordance with 40 CFR 97.530 through 97.535 shall be used to calculate allocations of TR NO_x Ozone Season allowances under 40 CFR 97.511(a)(2) and (b) and 97.512 and to determine compliance with the TR NO_x Ozone Season emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.530 through 97.535 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.</p> <p>(c) NO_x emissions requirements.</p> <p>(1) TR NO_x Ozone Season emissions limitation.</p> <p>(i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, TR NO_x Ozone Season allowances available for deduction for such control period under 40 CFR 97.524(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Ozone Season units at the source.</p> <p>(ii). If total NO_x emissions during a control period in a given year from the TR NO_x Ozone Season units at a TR NO_x Ozone Season source are in excess of the TR NO_x Ozone Season emissions limitation set forth in paragraph (c)(1)(i) above, then:</p> <p>(A). The owners and operators of the source and each TR NO_x Ozone Season unit at the source shall hold the TR NO_x Ozone Season allowances required for deduction under 40 CFR 97.524(d); and</p> <p>(B). The owners and operators of the source and each TR NO_x Ozone Season unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart BBBBB and the Clean Air Act.</p> <p>(2) TR NO_x Ozone Season assurance provisions.</p>
--	---

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV–1a: Cross State Air Pollution Rule (CSAPR)

	<p>(i). If total NO_x emissions during a control period in a given year from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such NO_x emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR NO_x Ozone Season allowances available for deduction for such control period under 40 CFR 97.525(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.525(b), of multiplying—</p> <p>(A). The quotient of the amount by which the common designated representative's share of such NO_x emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such NO_x emissions exceeds the respective common designated representative's assurance level; and</p> <p>(B). The amount by which total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state for such control period exceed the state assurance level.</p> <p>(ii). The owners and operators shall hold the TR NO_x Ozone Season allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.</p> <p>(iii). Total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state during a control period in a given year exceed the state assurance level if such total NO_x emissions exceed the sum, for such control period, of the State NO_x Ozone Season trading budget under 40 CFR 97.510(a) and the state's variability limit under 40 CFR 97.510(b).</p> <p>(iv). It shall not be a violation of 40 CFR part 97, subpart BBBBB</p>
--	---

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)

	<p>or of the Clean Air Act if total NO_x emissions from all TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state during a control period exceed the state assurance level or if a common designated representative's share of total NO_x emissions from the TR NO_x Ozone Season units at TR NO_x Ozone Season sources in the state during a control period exceeds the common designated representative's assurance level.</p> <p>(v). To the extent the owners and operators fail to hold TR NO_x Ozone Season allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,</p> <p>(A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and</p> <p>(B). Each TR NO_x Ozone Season allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart BBBB and the Clean Air Act.</p> <p>(3) Compliance periods.</p> <p>(i). A TR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of May 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.530(b) and for each control period thereafter.</p> <p>(ii). A TR NO_x Ozone Season unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting on the later of May 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.530(b) and for each control period thereafter.</p> <p>(4) Vintage of allowances held for compliance.</p> <p>(i). A TR NO_x Ozone Season allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR NO_x Ozone Season allowance that was allocated for such control period or a control period in a prior year.</p> <p>(ii). A TR NO_x Ozone Season allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR NO_x Ozone Season allowance that was allocated for a control period in a prior year or the control period in the</p>
--	---

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV–1a: Cross State Air Pollution Rule (CSAPR)

	<p>given year or in the immediately following year.</p> <p>(5) Allowance Management System requirements. Each TR NO_x Ozone Season allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart BBBBB.</p> <p>(6) Limited authorization. A TR NO_x Ozone Season allowance is a limited authorization to emit one ton of NO_x during the control period in one year. Such authorization is limited in its use and duration as follows:</p> <ul style="list-style-type: none"> (i). Such authorization shall only be used in accordance with the TR NO_x Ozone Season Trading Program; and (ii). Notwithstanding any other provision of 40 CFR part 97, subpart BBBBB, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act. <p>(7) Property right. A TR NO_x Ozone Season allowance does not constitute a property right.</p> <p>(d) Title V permit revision requirements.</p> <p>(1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR NO_x Ozone Season allowances in accordance with 40 CFR part 97, subpart BBBBB.</p> <p>(2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.530 through 97.535, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E). Therefore, the Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.506(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).</p> <p>(e) Additional recordkeeping and reporting requirements.</p> <p>(1) Unless otherwise provided, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.</p>
--	--

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)

- (i). The certificate of representation under 40 CFR 97.516 for the designated representative for the source and each TR NO_x Ozone Season unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.516 changing the designated representative.
 - (ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart BBBB.
 - (iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR NO_x Ozone Season Trading Program.
- (2) The designated representative of a TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall make all submissions required under the TR NO_x Ozone Season Trading Program, except as provided in 40 CFR 97.518. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.
- (f) Liability.**
- (1) Any provision of the TR NO_x Ozone Season Trading Program that applies to a TR NO_x Ozone Season source or the designated representative of a TR NO_x Ozone Season source shall also apply to the owners and operators of such source and of the TR NO_x Ozone Season units at the source.
 - (2) Any provision of the TR NO_x Ozone Season Trading Program that applies to a TR NO_x Ozone Season unit or the designated representative of a TR NO_x Ozone Season unit shall also apply to the owners and operators of such unit.
- (g) Effect on other authorities.**
- No provision of the TR NO_x Ozone Season Trading Program or exemption under 40 CFR 97.505 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR NO_x Ozone Season source or TR NO_x Ozone Season unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV–1a: Cross State Air Pollution Rule (CSAPR)	
	<p>C. 40 CFR Part 97 Subpart CCCC-TR SO₂ Group 1 Trading Program TR SO₂ Group 1 Trading Program requirements (40 CFR 97.606)</p> <p>(a) Designated representative requirements. The owners and operators shall comply with the requirement to have a designated representative, and may have an alternate designated representative, in accordance with 40 CFR 97.613 through 97.618.</p> <p>(b) Emissions monitoring, reporting, and recordkeeping requirements.</p> <p>(1) The owners and operators, and the designated representative, of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall comply with the monitoring, reporting, and recordkeeping requirements of 40 CFR 97.630 (general requirements, including installation, certification, and data accounting, compliance deadlines, reporting data, prohibitions, and long-term cold storage), 97.631 (initial monitoring system certification and recertification procedures), 97.632 (monitoring system out-of-control periods), 97.633 (notifications concerning monitoring), 97.634 (recordkeeping and reporting, including monitoring plans, certification applications, quarterly reports, and compliance certification), and 97.635 (petitions for alternatives to monitoring, recordkeeping, or reporting requirements).</p> <p>(2) The emissions data determined in accordance with 40 CFR 97.630 through 97.635 shall be used to calculate allocations of TR SO₂ Group 1 allowances under 40 CFR 97.611(a)(2) and (b) and 97.612 and to determine compliance with the TR SO₂ Group 1 emissions limitation and assurance provisions under paragraph (c) below, provided that, for each monitoring location from which mass emissions are reported, the mass emissions amount used in calculating such allocations and determining such compliance shall be the mass emissions amount for the monitoring location determined in accordance with 40 CFR 97.630 through 97.635 and rounded to the nearest ton, with any fraction of a ton less than 0.50 being deemed to be zero.</p> <p>(c) SO₂ emissions requirements.</p> <p>(1) TR SO₂ Group 1 emissions limitation.</p> <p style="padding-left: 20px;">(i). As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall hold, in the source's compliance account, TR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all TR SO₂ Group 1 units at the source.</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)	
	<p>(ii). If total SO₂ emissions during a control period in a given year from the TR SO₂ Group 1 units at a TR SO₂ Group 1 source are in excess of the TR SO₂ Group 1 emissions limitation set forth in paragraph (c)(1)(i) above, then:</p> <p>(A). The owners and operators of the source and each TR SO₂ Group 1 unit at the source shall hold the TR SO₂ Group 1 allowances required for deduction under 40 CFR 97.624(d); and</p> <p>(B). The owners and operators of the source and each TR SO₂ Group 1 unit at the source shall pay any fine, penalty, or assessment or comply with any other remedy imposed, for the same violations, under the Clean Air Act, and each ton of such excess emissions and each day of such control period shall constitute a separate violation 40 CFR part 97, subpart CCCCC and the Clean Air Act.</p> <p>(2) TR SO₂ Group 1 assurance provisions.</p> <p>(i). If total SO₂ emissions during a control period in a given year from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state exceed the state assurance level, then the owners and operators of such sources and units in each group of one or more sources and units having a common designated representative for such control period, where the common designated representative's share of such SO₂ emissions during such control period exceeds the common designated representative's assurance level for the state and such control period, shall hold (in the assurance account established for the owners and operators of such group) TR SO₂ Group 1 allowances available for deduction for such control period under 40 CFR 97.625(a) in an amount equal to two times the product (rounded to the nearest whole number), as determined by the Administrator in accordance with 40 CFR 97.625(b), of multiplying—</p> <p>(A). The quotient of the amount by which the common designated representative's share of such SO₂ emissions exceeds the common designated representative's assurance level divided by the sum of the amounts, determined for all common designated representatives for such sources and units in the state for such control period, by which each common designated representative's share of such SO₂ emissions exceeds the respective common designated representative's assurance level; and</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV–1a: Cross State Air Pollution Rule (CSAPR)

	<p>(B). The amount by which total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state for such control period exceed the state assurance level.</p> <p>(ii). The owners and operators shall hold the TR SO₂ Group 1 allowances required under paragraph (c)(2)(i) above, as of midnight of November 1 (if it is a business day), or midnight of the first business day thereafter (if November 1 is not a business day), immediately after such control period.</p> <p>(iii). Total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period in a given year exceed the state assurance level if such total SO₂ emissions exceed the sum, for such control period, of the state SO₂ Group 1 trading budget under 40 CFR 97.610(a) and the state’s variability limit under 40 CFR 97.610(b).</p> <p>(iv). It shall not be a violation of 40 CFR part 97, subpart CCCCC or of the Clean Air Act if total SO₂ emissions from all TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period exceed the state assurance level or if a common designated representative’s share of total SO₂ emissions from the TR SO₂ Group 1 units at TR SO₂ Group 1 sources in the state during a control period exceeds the common designated representative’s assurance level.</p> <p>(v). To the extent the owners and operators fail to hold TR SO₂ Group 1 allowances for a control period in a given year in accordance with paragraphs (c)(2)(i) through (iii) above,</p> <p>(A). The owners and operators shall pay any fine, penalty, or assessment or comply with any other remedy imposed under the Clean Air Act; and</p> <p>(B). Each TR SO₂ Group 1 allowance that the owners and operators fail to hold for such control period in accordance with paragraphs (c)(2)(i) through (iii) above and each day of such control period shall constitute a separate violation of 40 CFR part 97, subpart CCCCC and the Clean Air Act.</p> <p>(3) Compliance periods.</p> <p>(i). A TR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(1) above for the control period starting on the later of January 1, 2015 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.</p> <p>(ii). A TR SO₂ Group 1 unit shall be subject to the requirements under paragraph (c)(2) above for the control period starting</p>
--	--

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)	
	<p>on the later of January 1, 2017 or the deadline for meeting the unit's monitor certification requirements under 40 CFR 97.630(b) and for each control period thereafter.</p> <p>(4) Vintage of allowances held for compliance.</p> <p style="padding-left: 20px;">(i). A TR SO₂ Group 1 allowance held for compliance with the requirements under paragraph (c)(1)(i) above for a control period in a given year must be a TR SO₂ Group 1 allowance that was allocated for such control period or a control period in a prior year.</p> <p style="padding-left: 20px;">(ii). A TR SO₂ Group 1 allowance held for compliance with the requirements under paragraphs (c)(1)(ii)(A) and (2)(i) through (iii) above for a control period in a given year must be a TR SO₂ Group 1 allowance that was allocated for a control period in a prior year or the control period in the given year or in the immediately following year.</p> <p>(5) Allowance Management System requirements. Each TR SO₂ Group 1 allowance shall be held in, deducted from, or transferred into, out of, or between Allowance Management System accounts in accordance with 40 CFR part 97, subpart CCCCC.</p> <p>(6) Limited authorization. A TR SO₂ Group 1 allowance is a limited authorization to emit one ton of SO₂ during the control period in one year. Such authorization is limited in its use and duration as follows:</p> <p style="padding-left: 20px;">(i). Such authorization shall only be used in accordance with the TR SO₂ Group 1 Trading Program; and</p> <p style="padding-left: 20px;">(ii). Notwithstanding any other provision of 40 CFR part 97, subpart CCCCC, the Administrator has the authority to terminate or limit the use and duration of such authorization to the extent the Administrator determines is necessary or appropriate to implement any provision of the Clean Air Act.</p> <p>(7) Property right. A TR SO₂ Group 1 allowance does not constitute a property right.</p> <p>(d) Title V permit revision requirements.</p> <p>(1) No title V permit revision shall be required for any allocation, holding, deduction, or transfer of TR SO₂ Group 1 allowances in accordance with 40 CFR part 97, subpart CCCCC.</p> <p>(2) This permit incorporates the TR emissions monitoring, recordkeeping and reporting requirements pursuant to 40 CFR 97.630 through 97.635, and the requirements for a continuous emission monitoring system (pursuant to 40 CFR part 75, subparts B and H), an excepted monitoring system (pursuant to 40 CFR part 75, appendices D and E), a low mass emissions excepted monitoring methodology (pursuant to 40 CFR part 75.19), and an alternative monitoring system (pursuant to 40 CFR part 75, subpart E), Therefore, the</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)

Description of TR Monitoring Provisions table for units identified in this permit may be added to, or changed, in this title V permit using minor permit modification procedures in accordance with 40 CFR 97.606(d)(2) and 70.7(e)(2)(i)(B) or 71.7(e)(1)(i)(B).

(e) Additional recordkeeping and reporting requirements.

(1) Unless otherwise provided, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall keep on site at the source each of the following documents (in hardcopy or electronic format) for a period of 5 years from the date the document is created. This period may be extended for cause, at any time before the end of 5 years, in writing by the Administrator.

(i). The certificate of representation under 40 CFR 97.616 for the designated representative for the source and each TR SO₂ Group 1 unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such certificate of representation and documents are superseded because of the submission of a new certificate of representation under 40 CFR 97.616 changing the designated representative.

(ii). All emissions monitoring information, in accordance with 40 CFR part 97, subpart CCCCC.

(iii). Copies of all reports, compliance certifications, and other submissions and all records made or required under, or to demonstrate compliance with the requirements of, the TR SO₂ Group 1 Trading Program.

(2) The designated representative of a TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall make all submissions required under the TR SO₂ Group 1 Trading Program, except as provided in 40 CFR 97.618. This requirement does not change, create an exemption from, or otherwise affect the responsible official submission requirements under a title V operating permit program in 40 CFR parts 70 and 71.

(f) Liability.

(1) Any provision of the TR SO₂ Group 1 Trading Program that applies to a TR SO₂ Group 1 source or the designated representative of a TR SO₂ Group 1 source shall also apply to the owners and operators of such source and of the TR SO₂ Group 1 units at the source.

(2) Any provision of the TR SO₂ Group 1 Trading Program that applies to a TR SO₂ Group 1 unit or the designated representative of a TR SO₂ Group 1 unit shall also apply to the owners and operators of such unit.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV–1a: Cross State Air Pollution Rule (CSAPR)	
	<p>(g) Effect on other authorities. No provision of the TR SO₂ Group 1 Trading Program or exemption under 40 CFR 97.605 shall be construed as exempting or excluding the owners and operators, and the designated representative, of a TR SO₂ Group 1 source or TR SO₂ Group 1 unit from compliance with any other provision of the applicable, approved state implementation plan, a federally enforceable permit, or the Clean Air Act.</p>
1a.2	<p><u>Testing Requirements:</u></p> <p>A, B & C: See Monitoring Requirements.</p>
1a.3	<p><u>Monitoring Requirements:</u></p> <p>A. 40 CFR Part 97 Subpart AAAAA-TR NO_x Annual Trading Program The Permittee shall comply with the monitoring requirements found in §97.406, §97.430, and §97.434 for the NO_x Annual Trading Program.</p> <p>B. 40 CFR Part 97 Subpart BBBB-TR NO_x Ozone Season Trading Program The Permittee shall comply with the monitoring requirements found in §97.506, §97.530, and §97.534 for the NO_x Ozone Season Trading Program.</p> <p>C. 40 CFR Part 97 Subpart CCCC-TR SO₂ Group 1 Trading Program The Permittee shall comply with the monitoring requirements found in §97.606, §97.630, §97.631, §97.632, and §97.633.</p> <p>The Permittee operates continuous emission monitoring system (CEMS) pursuant to 40 CFR Part 75, Subpart H (for NO_x monitoring).</p>
1a.4	<p><u>Record Keeping Requirements:</u></p> <p>A. 40 CFR Part 97 Subpart AAAAA-TR NO_x Annual Trading Program The Permittee shall comply with the recordkeeping requirements found in §97.406, §97.430, and §97.434 for the NO_x Annual Trading Program.</p> <p>B. 40 CFR Part 97 Subpart BBBB-TR NO_x Ozone Season Trading Program The Permittee shall comply with the recordkeeping requirements found in §97.506, §97.530, and §97.534 for the NO_x Ozone Season Trading</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV-1a: Cross State Air Pollution Rule (CSAPR)	
	<p>Program.</p> <p>C. 40 CFR Part 97 Subpart CCCCC-TR SO₂ Group 1 Trading Program The Permittee shall comply with the recordkeeping requirements found in §97.606, §97.630, and §97.634.</p>
1a.5	<p><u>Reporting Requirements:</u></p> <p>A. 40 CFR Part 97 Subpart AAAAA-TR NO_x Annual Trading Program The Permittee shall comply with the reporting requirements found in §97.406, §97.430, §97.433 and §97.434 for the NO_x Annual Trading Program.</p> <p>B. 40 CFR Part 97 Subpart BBBBB-TR NO_x Ozone Season Trading Program The Permittee shall comply with the reporting requirements found in §97.506, §97.530, §97.533, and §97.534 for the NO_x Ozone Season Trading Program.</p> <p>C. 40 CFR Part 97 Subpart CCCCC-TR SO₂ Group 1 Trading Program The Permittee shall comply with the reporting requirements found in §97.606, §97.630, §97.633 and §97.634.</p>

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 2			
2.0	<p><u>Emissions Unit Number(s) - Natural Gas heater</u></p> <p>EU-7 – One (1) 9 million Btu/hr natural gas fuel-fired heater equipped with low NO_x burners. [6-0205]</p>		
2.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05A(1) – <u>Visible Emissions.</u> “A person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is greater than 20 percent opacity. <u>Exceptions.</u> “Section A (1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, start-up, or adjustments or occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40 percent opacity; and (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period.”</p> <p>B. <u>Control of Particulate Matter Emissions</u> CPCN #8821 BACT - For the natural gas-fired heater, BACT shall be the use of natural gas fuel only, operation of low-NO_x burner technology, and application of good combustion controls. In addition, the heater shall be designed to achieve a PM emission rate not to exceed 0.01 lb/MMBtu.</p> <p>CPCN #8821, Condition #18 – The gas heater shall be designed to achieve PM emissions not to exceed the following:</p> <table border="1" style="margin-left: 20px; width: 50%; border-collapse: collapse;"> <tr> <td style="padding: 2px;">PM10</td> <td style="padding: 2px;">0.09 lb/hr</td> </tr> </table> <p>C. <u>Control of Sulfur Oxide Emissions</u> SO₂ Emissions from the gas heater shall not exceed 0.05 lb/hr. [Reference: CPCN #8821, Condition #18]</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> LAER & BACT for the natural gas heater shall be the use of natural gas fuel only, operation of advanced dry low-NO_x burner technology, and application of good combustion control. In addition, the heater shall be designed to achieve a NO_x emissions rate not exceed 0.1 lb/MMBtu. [Reference: CPCN #8821, Condition #14b(i) #15b]</p>	PM10	0.09 lb/hr
PM10	0.09 lb/hr		

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 2

CPCN #8821, Condition #18 –The gas heater shall be designed to achieve NO_x emissions not to exceed the following:

NO _x	0.9 lb/hr and 3.9 tpy on a 12-month rolling cumulative basis
-----------------	--

E. Control of Carbon Monoxide Emissions

BACT for the natural gas heater shall be the use of natural gas fuel only, operation of advanced dry low-NO_x burner technology, and application of good combustion control. In addition, the heater shall be designed to achieve a CO emission rate not exceed **0.08 lb/MMBtu**. [Reference: **CPCN #8821, Condition #14b(ii)**]

CPCN #8821, Condition #18 –The gas heater shall be designed to achieve CO emissions not to exceed the following:

CO	0.45 lb/hr
----	------------

F. Control of VOC Emissions

CPCN #8821, Condition #18 –The gas heater shall be designed to achieve VOC emissions not to exceed the following:

VOCs	0.225 lb/hr
------	-------------

2.2 Testing Requirements:

A. Control of Visible Emissions

See Reporting Requirements.

B. Control of Particulate Matter Emissions

See Monitoring Requirements.

C. Control of Sulfur Oxide Emissions

See Monitoring Requirements.

D. Control of Nitrogen Oxide Emissions

See Monitoring Requirements.

E. Control of Carbon Monoxide Emissions

See Monitoring Requirements.

G. Control of VOC Emissions

See Monitoring Requirements.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 2	
2.3	<p><u>Monitoring Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p> <p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall perform preventative maintenance to maintain the gas heater as designed. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall perform preventative maintenance to maintain the gas heater as designed. [Reference: COMAR 26.11.03.06C]</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall perform preventative maintenance to maintain the gas heater as designed. [Reference: COMAR 26.11.03.06C]</p> <p>E. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall perform preventative maintenance to maintain the gas heater as designed. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of VOC Emissions</u> The Permittee shall perform preventative maintenance to maintain the gas heater as designed. [Reference: COMAR 26.11.03.06C]</p>
2.4	<p><u>Record Keeping Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p> <p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C].</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 2	
	<p>E. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of VOC Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p>
2.5	<p><u>Reporting Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.</p> <p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p> <p>E. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of VOC Emissions</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p>

A permit shield shall cover the applicable requirements of the Clean Air Act that are listed in the table above.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3			
3.0	<p><u>Emissions Unit Number(s) - Emergency diesel engine</u></p> <p>EU-8: One 200 horsepower (hp) emergency diesel firewater engine.</p>		
3.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05E(2) - <u>Emissions During Idle Mode:</u> “The Permittee may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.” COMAR 26.11.09.05E(3) - <u>Emissions During Operating Mode:</u> “The Permittee may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.” <u>Exceptions:</u> “(i) COMAR 26.11.09.05E(2) does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system. (ii) COMAR 26.11.09.05E(2) does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods: (a) Engines that are idled continuously when not in service: 30 minutes (b) all other engines: 15 minutes. (iii) COMAR 26.11.09.05E(2) & (3) do not apply while maintenance, repair or testing is being performed by qualified mechanics.”</p> <p>B. <u>Control of Particulate Matter Emissions</u> CPCN #8821, Condition 14c, BACT - For the diesel firewater engine, BACT shall be application of good combustion controls and lean burn technology. In addition, the engine shall be designed to achieve a PM emission rate not to exceed 0.15 g/BHP.</p> <p>CPCN #8821, Condition #19 – The engine shall be designed to achieve PM emissions not to exceed the following:</p> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 20%;">PM10</td> <td>0.07 lb/hr</td> </tr> </table> <p>C. <u>Control of Sulfur Oxide Emissions</u> COMAR 26.11.09.07A(1)(c) – <u>Sulfur Content Limitations for Fuel.</u> “A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: Distillate fuel oils, 0.3 percent.”</p> <p>SO₂ Emissions from the gas heater shall not exceed 0.29 lb/hr. [Reference: CPCN #8821, Condition #19]</p>	PM10	0.07 lb/hr
PM10	0.07 lb/hr		

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3

D. Control of Nitrogen Oxide Emissions

LAER & BACT for the emergency diesel firewater engine shall be the application of good combustion controls, lean burn technology, and operation of the unit for a period not to exceed 100 hours per year on a 12-month rolling cumulative basis. In addition, the engine shall be designed to achieve NO_x emissions not to exceed 10.5 g/BHP.

[Reference: CPCN #8821, Condition #14c and 15c]

CPCN #8821, Condition #19 –The engine shall be designed to achieve NO_x emissions not to exceed the following:

NO _x	0.46 lb/hr and 0.02 tpy on a 12-month rolling cumulative basis
-----------------	--

E. Control of Carbon Monoxide Emissions

BACT for the emergency diesel firewater engine shall be the application of good combustion controls and lean burn technology. In addition, the engine shall be designed to achieve a CO emission rate not exceed **2.7 g/BHP**. **[Reference: CPCN #8821, Condition #14c]**

CPCN #8821, Condition #19 –The engine shall be designed to achieve CO emissions not to exceed the following:

CO	1.19lb/hr
----	-----------

F. Control of VOC Emissions

CPCN #8821, Condition #19 –The emergency diesel firewater engine shall be designed to achieve VOC emissions not to exceed the following:

VOCs	0.03 lb/hr
------	------------

G. Control of Hazardous Air Pollutants

40 CFR §63.6603(a) – “If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart.”

Table 2d, Item 4 – “a. Change oil and filter every 500 hours of operation or annually, whichever comes first; b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.”

40 CFR §63.6605(a) – “You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.”

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3

40 CFR §63.6605(b) – “At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.”

40 CFR §63.6640(f) – “If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

- (1) There is no time limit on the use of emergency stationary RICE in emergency situations.
- (2) You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).
 - i. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.”

(3) Not applicable for Area Sources

**ROCK SPRINGS GENERATION FACILITY
 1423 ROCK SPRINGS ROAD
 RISING SUN, MARYLAND 21911
 PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3

	<p>(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.</p> <p>(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.</p> <p>(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:</p> <p>(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.</p> <p>(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.</p> <p>(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.</p> <p>(D) The power is provided only to the facility itself or to support the local transmission and distribution system.</p> <p>(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.”</p>
<p>3.2</p>	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Monitoring Requirements.</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3	
	<p>B. <u>Control of Particulate Matter Emissions</u> See Monitoring Requirements.</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> See Monitoring Requirements.</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> See Monitoring Requirements.</p> <p>E. <u>Control of Carbon Monoxide Emissions</u> See Monitoring Requirements.</p> <p>F. <u>Control of VOC Emissions</u> See Monitoring Requirements.</p> <p>G. <u>Control of Hazardous Air Pollutants</u> See Monitoring Requirements.</p>
3.3	<p><u>Monitoring Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall: (1) properly operate and maintain the engine; and (2) maintain an operations manual and preventive maintenance plan. [Reference: COMAR 26.11.03.06C]</p> <p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall perform preventative maintenance to maintain the engine as designed. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall obtain fuel suppliers' certification indicating that the gas complies with the limitation on the sulfur content of the gas or obtain sulfur in fuel analyses of gas that is representative of oil burned. [Reference: COMAR 26.11.03.06C]</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall perform preventative maintenance to maintain the engine as designed. [Reference: COMAR 26.11.03.06C]</p> <p>E. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall perform preventative maintenance to maintain the engine as designed. [Reference: COMAR 26.11.03.06C]</p>

**ROCK SPRINGS GENERATION FACILITY
 1423 ROCK SPRINGS ROAD
 RISING SUN, MARYLAND 21911
 PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3

	<p>F. <u>Control of VOC Emissions</u> The Permittee shall perform preventative maintenance to maintain the engine as designed. [Reference: COMAR 26.11.03.06C]</p> <p>G. <u>Control of Hazardous Air Pollutants</u> The engine must be operated and maintained according to the manufacturer’s emission-related written instructions or develop a maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution practice for minimizing emissions. [Reference: 40 CFR §63.6625(e) and Table 6, Item 9]</p> <p>A non-resettable hour meter must be installed on the engine if one is not already installed. [Reference: 40 CFR §63.6625(f)]</p> <p>Minimize the time spent at idle during startup and minimize the startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [Reference: 40 CFR §63.6625(h)]</p>
3.4	<p><u>Record Keeping Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall maintain a log of maintenance performed on the engine pump that relates to combustion performance. [Reference: COMAR 26.11.03.06C].</p> <p>B. <u>Control of Particulate Matter Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall maintain on site for at least five years documents certifying the sulfur content of gas received or copies of the sulfur in fuel analyses. [Reference: COMAR 26.11.03.06C].</p> <p>D. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3	
	<p>E. <u>Control of Carbon Monoxide Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p> <p>F. <u>Control of VOC Emissions</u> The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance. [Reference: COMAR 26.11.03.06C]</p> <p>G. <u>Control of Hazardous Air Pollutants</u> The Permittee must keep records of the occurrence and duration of each malfunction of operation or the air pollution control and monitoring equipment. [Reference: 40 CFR §63.6655(a)(2)]</p> <p>The Permittee must keep records of all maintenance performed on the air pollution control and monitoring equipment. [Reference: 40 CFR §63.6655(a)(4)]</p> <p>The Permittee must keep records of action taken during periods of malfunction to minimize emissions including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [Reference: 40 CFR §63.6655(a)(5)]</p> <p>The Permittee must keep a copy of the manufacturer’s written instructions or maintenance plan for the engine. [Reference: 40 CFR §63.6655(d)]</p> <p>The Permittee must keep records of the maintenance conducted on the engine. [Reference: 40 CFR §63.6655(e)]</p> <p>The Permittee must keep records of the hours of operation of the engine recorded through the non-resettable hour meter. Records documenting the date, start time, end time, and reason for operation must also be kept. [Reference: 40 CFR §63.6655(f)]</p>
3.5	<p><u>Reporting Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 3

B. Control of Particulate Matter Emissions

The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

C. Control of Sulfur Oxide Emissions

The Permittee shall report fuel supplier certifications or sulfur in fuel analyses to the Department upon request **[Reference: COMAR 26.11.09.07C]**.

D. Control of Nitrogen Oxide Emissions

The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

E. Control of Carbon Monoxide Emissions

The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

F. Control of VOC Emissions

The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

G. Control of Hazardous Air Pollutants

The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable. **[Reference: 40 CFR §63.6650]**

“A permit shield shall cover the applicable requirements identified for the emission unit listed in the table above.”

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 4	
4.0	<p><u>Emissions Unit Number(s): Emergency diesel engine</u></p> <p>EU-9: One (1) 100 kilowatt (kW) emergency diesel switchyard generator.</p>
4.1	<p><u>Applicable Standards/Limits:</u></p> <p><u>A. Control of Visible Emissions</u> COMAR 26.11.09.05E(2) - Emissions During Idle Mode: “The Permittee may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.” COMAR 26.11.09.05E(3) - Emissions During Operating Mode: “The Permittee may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.”</p> <p><u>Exceptions:</u> “(i) COMAR 26.11.09.05E(2) does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system. (ii) COMAR 26.11.09.05E(2) does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods: (a)Engines that are idled continuously when not in service: 30 minutes (b)all other engines: 15 minutes. (iii) COMAR 26.11.09.05E(2) & (3) do not apply while maintenance, repair or testing is being performed by qualified mechanics.”</p> <p><u>B. Control of Sulfur Oxide Emissions</u> COMAR 26.11.09.07A(1)(c) – Sulfur Content Limitations for Fuel. “A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: Distillate fuel oils, 0.3 percent.”</p> <p><u>C. Control of Hazardous Air Pollutants</u> 40 CFR §63.6603(a) – “If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart.” Table 2d, Item 4 – “a. Change oil and filter every 500 hours of operation or annually, whichever comes first; b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.”</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 4

40 CFR §63.6605(a) – “You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.”

40 CFR §63.6605(b) – “At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.”

40 CFR §63.6640(f) – “If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

- (1) There is no time limit on the use of emergency stationary RICE in emergency situations.
- (2) You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).
 - i. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 4

	<p>maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.</p> <p>(3) Not applicable for Area Sources</p> <p>(4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.</p> <p>(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.</p> <p>(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:</p> <p>(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.</p> <p>(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.</p> <p>(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.</p> <p>(D) The power is provided only to the facility itself or to support the local transmission and distribution system.</p> <p>(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.”</p>
--	---

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 4

4.2	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Monitoring Requirements.</p> <p>B. <u>Control of Sulfur Oxide Emissions</u> See Monitoring Requirements.</p> <p>C. <u>Control of Hazardous Air Pollutants</u> See Monitoring Requirements.</p>
4.3	<p><u>Monitoring Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall: (1) properly operate and maintain the engine; and (2) maintain an operations manual and preventive maintenance plan. [Reference: COMAR 26.11.03.06C]</p> <p>B. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall obtain fuel suppliers' certification indicating that the gas complies with the limitation on the sulfur content of the gas or obtain sulfur in fuel analyses of gas that is representative of oil burned. [Reference: COMAR 26.11.03.06C]</p> <p>C. <u>Control of Hazardous Air Pollutants</u> The engine must be operated and maintained according to the manufacturer's emission-related written instructions or develop a maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution practice for minimizing emissions. [Reference: 40 CFR §63.6625(e) and Table 6, Item 9]</p> <p>A non-resettable hour meter must be installed on the engine if one is not already installed. [Reference: 40 CFR §63.6625(f)]</p> <p>Minimize the time spent at idle during startup and minimize the startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [Reference: 40 CFR §63.6625(h)]</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 4

4.4	<p><u>Record Keeping Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall maintain a log of maintenance performed on the engine pump that relates to combustion performance. [Reference: COMAR 26.11.03.06C].</p> <p>B. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall maintain on site for at least five years documents certifying the sulfur content of gas received or copies of the sulfur in fuel analyses. [Reference: COMAR 26.11.03.06C].</p> <p>C. <u>Control of Hazardous Air Pollutants</u> The Permittee must keep records of the occurrence and duration of each malfunction of operation or the air pollution control and monitoring equipment. [Reference: 40 CFR §63.6655(a)(2)]</p> <p>The Permittee must keep records of all maintenance performed on the air pollution control and monitoring equipment. [Reference: 40 CFR §63.6655(a)(4)]</p> <p>The Permittee must keep records of action taken during periods of malfunction to minimize emissions including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [Reference: 40 CFR §63.6655(a)(5)]</p> <p>The Permittee must keep a copy of the manufacturer’s written instructions or maintenance plan for the engine. [Reference: 40 CFR §63.6655(d)]</p> <p>The Permittee must keep records of the maintenance conducted on the engine. [Reference: 40 CFR §63.6655(e)]</p> <p>The Permittee must keep records of the hours of operation of the engine recorded through the non-resettable hour meter. Records documenting the date, start time, end time, and reason for operation must also be kept. [Reference: 40 CFR §63.6655(f)]</p>
4.5	<p><u>Reporting Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 4	
	<p>B. <u>Control of Sulfur Oxide Emissions</u> The Permittee shall report fuel supplier certifications or sulfur in fuel analyses to the Department upon request [Reference: COMAR 26.11.09.07C].</p> <p>C. <u>Control of Hazardous Air Pollutants</u> The Permittee shall submit records of maintenance to the Department upon request. [Reference: COMAR 26.11.03.06C]</p> <p>If an emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements on the schedule required, or if performing the management practice on the required schedule would otherwise pose an unacceptable risk under federal, state, or local law, the management practice can be delayed until the emergency is over or the unacceptable risk under federal, state, or local law has abated. The management practice should be performed as soon as practicable after the emergency has ended or the unacceptable risk under federal, state, or local law has abated. Sources must report any failure to perform the management practice on the schedule required and the federal, state or local law under which the risk was deemed unacceptable. [Reference: 40 CFR §63.6650]</p>

“A permit shield shall cover the applicable requirements identified for the emission unit listed in the table above.”

Table IV – 5	
5.0	<p><u>Emissions Unit Number(s) - Natural Gas heater</u></p> <p>EU-10 – One (1) 7.5 million Btu/hr natural gas fuel-fired heater equipped with low NO_x burners. [015-0202-5-0148]</p>
5.1	<p><u>Applicable Standards/Limits:</u></p> <p>A. <u>Control of Visible Emissions</u> COMAR 26.11.09.05A(1) – <u>Visible Emissions.</u> “A person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is greater than 20 percent opacity. <u>Exceptions.</u> “Section A (1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, start-up, or adjustments or</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 5	
	<p>occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40 percent opacity; and (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period.”</p> <p>B. <u>Control of Nitrogen Oxide Emissions</u> COMAR 26.11.09.08B(5) - <u>Operator Training</u>. (a) “For purposes of this regulation, the equipment operator to be trained may be the person who maintains the equipment and makes the necessary adjustments for efficient operation. (b) The operator training course sponsored by the Department shall include an in-house training course that is approved by the Department.” COMAR 26.11.09.08E. - <u>Requirements for Fuel-Burning Equipment with a Rated Heat Input Capacity of 100 Million Btu Per Hour or Less</u>. “A person who owns or operates fuel-burning equipment with a rated heat input capacity of 100 Million Btu per hour or less shall: (1) Submit to the Department an identification of each affected installation, the rated heat input capacity of each installation, and the type of fuel burned in each; (2) Perform a combustion analysis for each installation at least once each year and optimize combustion based on the analysis; (3) Maintain the results of the combustion analysis at the site for at least 2 years and make this data available to the Department and the EPA upon request; (4) Once every 3 years, require each operator of the installation to attend operator training programs on combustion optimization that are sponsored by the Department, the EPA, or equipment vendors; and (5) Prepare and maintain a record of training program attendance for each operator at the site, and make these records available to the Department upon request.”</p>
5.2	<p><u>Testing Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p> <p>B. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall perform combustion analysis on the heater at least once per year and optimize combustion based on the analysis. [Reference: COMAR 26.11.09.08E(2)]</p>

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

Table IV – 5	
5.3	<p><u>Monitoring Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p> <p>B. <u>Control of Nitrogen Oxide Emissions</u> See Record Keeping Requirements</p>
5.4	<p><u>Record Keeping Requirements:</u></p> <p>NOTE: All records must be maintained for a period of 5 years. [Reference: COMAR 26.11.03.06C(5)(g)]</p> <p>A. <u>Control of Visible Emissions</u> See Reporting Requirements.</p> <p>B. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall maintain the following records on-site for a period of at least five years: (1) Training program attendance for each operator at the site and make these records available to the Department upon request. (2) Results of combustion analysis. [Reference: COMAR 26.11.09.09E(3)&(5)]</p>
5.5	<p><u>Reporting Requirements:</u></p> <p>A. <u>Control of Visible Emissions</u> The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.</p> <p>B. <u>Control of Nitrogen Oxide Emissions</u> The Permittee shall submit: (1) The results of combustion analysis to the department and the EPA upon request. [Reference: COMAR 26.11.09.08E(3)] (2) A record of training program attendance for each operator to the Department upon request. [Reference: COMAR 26.11.09.08E(5)].</p>

“A permit shield shall cover the applicable requirements identified for the emission unit listed in the table above.”

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

SECTION V INSIGNIFICANT ACTIVITIES

This section provides a list of insignificant emissions units that were reported in the Title V permit application. The applicable Clean Air Act requirements, if any, are listed below the insignificant activity.

- (1) ✓ Space heaters utilizing direct heat transfer and used solely for comfort heat;

- (2) Containers, reservoirs, or tanks used exclusively for:
 - (a) ✓ Storage of butane, propane, or liquefied petroleum, or natural gas;

 - (b) No. ✓ Storage of lubricating oils;

 - (c) No. 2 Storage of Numbers 1, 2, 4, 5, and 6 fuel oil and aviation jet engine fuel;

- (3) ✓ Potable water treatment equipment, not including air stripping equipment;

- (4) ✓ Comfort air conditioning subject to requirements of Title VI of the Clean Air Act;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MARYLAND 21911
PART 70 OPERATING PERMIT NO. 24-015-0202**

SECTION VI STATE-ONLY ENFORCEABLE CONDITIONS

The Permittee is subject to the following State-only enforceable requirements:

Applicable Regulations:

- (A) COMAR 26.11.06.08, Nuisance.
“An installation or premises may not be operated or maintained in such a manner that a nuisance or air pollution is created. Nothing in this regulation relating to the control of emissions may in any manner be construed as authorizing or permitting the creation of, or maintenance of, nuisance or air pollution.”

- (B) COMAR 26.11.06.09, Odors.
“A person may not cause or permit the discharge into the atmosphere of gases, vapors, or odors beyond the property line in such a manner that a nuisance or air pollution is created.”

Maryland Department of the Environment
Air and Radiation Administration

PHASE II ACID RAIN PERMIT

Plant Name:	Rock Springs Generation Facility		
Affected Units:	1, 2, 3, and 4		
Owners:	Essential Power Rock Springs, LLC	ORIS Code	7835
Effective Date From:	_____	To:	December 31, 2024


Contents:

1. Statement of Basis
2. SO₂ and NO_x requirements for each affected unit.
3. Comments, notes and justifications regarding permit decisions and changes made to permit application forms during the review process, and any additional requirements or conditions.
4. The permit application forms submitted for this source. The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application.

1. Statement of Basis

Statutory and Regulatory Authorities: In accordance with Environmental Article §2-401, Annotated Code of Maryland and Titles IV and V of the Clean Air Act, the Maryland Department of the Environment, Air and Radiation Administration issues this permit pursuant to COMAR 26.11.02 and COMAR 26.11.03.

Renewal Permit Approval


George S. Aburn, Jr., Director
Air and Radiation Administration

NOV - 1 2019

Date of Issue

Plant Name: Rock Springs Generation Facility

2. SO₂ and NO_x Requirements for each affected unit

Units No. 1,2,3,and 4

SO ₂ Requirements	
SO ₂ Allowances	Essential Power Rock Springs LLC will hold allowances for units 1, 2, 3, and 4 in accordance with 40 CFR 72.9(c)(1).

NO _x Requirements	
NO _x Limit	None


3. **Comments, notes and justifications regarding decisions, and changes made to the permit application forms during the review process:**

These units burn only pipeline natural gas. Because this unit is not coal-fired, the oxides of nitrogen emissions reduction regulations of 40 CFR Part 76 is not applicable.

Essential Power Rock Springs, LLC is now the sole owner of the Rock Springs Generation Facility.

Note that the original proposal for the facility was for six units; however, units 5 and 6 were never built. North American Energy Alliance acquired Consolidated Edison Development in June 2008. EP Rock Springs, LLC acquired Consolidated Edison Development in 2013.

Renewal Permit Approval



George S. Aburn, Jr., Director
Air and Radiation Administration

NOV - 1 2019

Date of Issue

Maryland Department of the Environment
Air and Radiation Administration

CO₂ BUDGET TRADING PROGRAM PERMIT

Plant Name: Rock Springs Generation Facility	
Affected Trading Units: Unit 1, Unit 2, Unit 3, and Unit 4	
Owner: Essential Power Rock Springs, LLC	ORIS Code 7835
Effective Date From: _____ To: December 31, 2024	


Contents:

1. Statement of Basis
2. Table of Affected Units
3. Standard Requirements.
4. The permit application forms submitted for this source.

1. Statement of Basis

Statutory and Regulatory Authorities: In accordance with Environmental Article §2-401, Annotated Code of Maryland, the Maryland Department of the Environment, Air and Radiation Administration issues this permit pursuant to COMAR 26.09.01 thru COMAR 26.09.04.

Renewal Permit Approval



George S. Aburn, Jr., Director
Air and Radiation Administration

NOV - 1 2019

Date of Issue

2. Affected Units

Unit ID #	ARA ID#	Unit Description
Unit 1	5-0076	General Electric 7 FA gas turbine, with a maximum output of 190
Unit 2	5-0077	General Electric 7 FA gas turbine, with a maximum output of 190 MW
Unit 3	5-0078	General Electric 7 FA gas turbine, with a maximum output of 190 MW
Unit 4	5-0078	General Electric 7 FA gas turbine, with a maximum output of 190 MW

3. Standard Requirements:

A. Selection and Responsibilities of CO₂ Budget Source Compliance Account Authorized Account Representatives.

1. Each CO₂ budget source shall have a CO₂ authorized account representative and an alternate CO₂ authorized account representative. **(COMAR 26.09.01.04B)**
2. Upon receipt of a complete account certificate of representation:
 - (a) The CO₂ authorized account representative and alternate CO₂ authorized account representative shall represent and, by representations, actions, inactions, or submissions, legally bind each owner or operator of the CO₂ budget source represented and each CO₂ budget unit at the source in all matters pertaining to this subtitle, notwithstanding any agreement between the CO₂ authorized account representative, alternate CO₂ authorized account representative, and the owners or operators; and **(COMAR 26.09.01.04E(1))**
 - (b) The owners or operators shall be bound by any decision or order issued to the CO₂ authorized account representative or alternate CO₂ authorized account representative by the Department or a court regarding the CO₂ budget source or unit. **(COMAR 26.09.01.04E(2))**
3. A CO₂ budget permit may not be issued or a compliance account established for a CO₂ budget source until the Department has received a complete account certificate of representation for a CO₂ authorized account representative and alternate CO₂ authorized account representative of the source and the CO₂ budget units at the source. **(COMAR 26.09.01.04F)**
4. Each submission shall be signed and certified by the CO₂ authorized account representative or alternate CO₂ authorized account representative on behalf of each CO₂ budget source and shall include the following statement by the CO₂ authorized account representative or alternate CO₂ authorized account representative: "I am authorized to make the submission on behalf of the owners or operators of the CO₂ budget sources or CO₂ budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in the document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that

the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment." (COMAR 26.09.01.04G)

B. Distribution Of CO₂ Allowances And Compliance

1. Unless otherwise specified in this chapter, a CO₂ budget source shall demonstrate compliance with its CO₂ budget emissions limitation by having one CO₂ allowance in its compliance account for every ton of CO₂ that it emits in a control period, by the allowance transfer deadline for that control period. (COMAR 26.09.02.03K(1))
2. Allowances Available for Compliance Deduction. The following CO₂ allowances may be deducted from a compliance account for purposes of complying with a budget source's CO₂ budget emissions limitation for a control period or an interim control period:
 - (a) CO₂ allowances that are not CO₂ offset allowances and are identified as allowances falling within a prior control period, the same control period, or the same interim control period for which the allowances are deducted;
 - (b) CO₂ allowances that are held or transferred into the CO₂ budget source's compliance account as of the CO₂ allowance transfer deadline for that control period or for the interim control period contained within that control period;
 - (c) CO₂ offset allowances that are available to be deducted for compliance during a control period or an interim control period where the quantity of allowances is limited to:
 - (i) 3.3 percent of the CO₂ budget source's CO₂ emissions for that control period; or
 - (ii) 3.3 percent of the CO₂ budget source's CO₂ emissions for an interim control period multiplied by 0.50.(COMAR 26.09.02.03K(3)(a)-(c))
3. Deduction of CO₂ allowances: The Department shall deduct allowances from the CO₂ budget source's compliance account until: (i) the number of CO₂ allowances deducted equals 50 percent of the total CO₂ emissions for an interim control period; or (ii) the number CO₂ allowances deducted equals the total CO₂ emissions for the control period. No deduction shall be made for any CO₂ emissions attributable to the burning of eligible biomass. (COMAR 26.09.02.03K(4)(a)-(b))
4. The identification of available CO₂ allowances for compliance deduction by serial number or by default is as follows:
 - (a) The CO₂ authorized account representative for a source's compliance account may request that specific CO₂ allowances, identified by serial number for a control period or interim control period, be deducted; and
 - (b) In the absence of an identification or in the case of a partial identification of available CO₂ allowances by serial number, the Department shall deduct CO₂ allowances for a control period or interim control period in the following descending order:
 - (i) For the first control period, all CO₂ allowances purchased by direct sale from the

Department during years 2009, 2010, and 2011 resulting from the occurrence of the \$7 auction clearing price;

(ii) All CO₂ allowances for a control period allocated to a CO₂ budget unit from the Long Term Contract Set-aside Account or the Clean Generation Set-aside Account;

(iii) Subject to the relevant compliance deduction limitations identified in §K(3)(c) of this regulation, any CO₂ offset allowances transferred and recorded in the compliance account, in chronological order; and

(iv) Any CO₂ allowances, other than those identified in §K(5)(b)(i)—(iii) of this regulation, that are available for deduction in the order they were recorded.
(COMAR 26.09.02.03K(5)(a)-(b))

5. Deductions for Excess Emissions:

(a) If a CO₂ budget source has excess emissions, the Department shall deduct CO₂ allowances from the CO₂ budget source's compliance account equal to three times the excess emissions.

(b) If a source's compliance account holds insufficient CO₂ allowances to cover the excess emissions, the source shall immediately transfer sufficient allowances into its compliance account.

(c) CO₂ offset allowances may not be deducted to account for the source's excess emissions.

(d) No CO₂ allowance deduction shall relieve the owners or operators of the CO₂ budget units at the source of liability for any fine, penalty, assessment or obligation to comply with any other remedy, for the same violation, as ordered under applicable State law.

(COMAR 26.09.02.03K(6)(a)-(d))

6. The following guidelines apply in assessing fines, penalties, or other obligations:

(a) For purposes of determining the number of days of violation, if a CO₂ budget unit has excess emissions for a control period or interim control period, each day in the control period or interim control period, as applicable, constitutes a separate day of violation unless the owners or operators of the unit can demonstrate to the satisfaction of the Department that a lesser number of days should be considered; and **(COMAR 26.09.02.03K(7)(a)(i))**

(b) The Department shall consider the amount of excess emissions in determining the severity of the violation. **(COMAR 26.09.02.03K(7)(a)(ii))**

(c) Each ton of excess interim emissions is a separate violation. (COMAR 26.09.02.03K(7)(b))

7. If the CO₂ budget source's compliance account no longer exists, the CO₂ allowances shall be deposited in a general account selected by the owner or operator of the CO₂ budget source. (COMAR 26.09.02.03K(8))
8. Adjustments and Errors:
 - (a) The Department may review and conduct independent audits concerning any submission under this subtitle and make appropriate adjustments of the information, if necessary.
 - (b) The Department may correct any error in any account and, within 10 business days of making any correction, notify the CO₂ authorized account representative for the account. (COMAR 26.09.02.03K(9)(a)-(b))

C. Applicability and Administration

1. The requirements of this permit apply to the owner or operator of a CO₂ budget unit. When this permit establishes a requirement such as the submittal of a permit application, a report, a request for allowances or transfer of allowances, or general information, these actions shall be achieved through the CO₂ authorized account representative on behalf of the owner or operator of the affected CO₂ budget source or unit. (COMAR 26.09.02.02A)
2. The requirements of this subtitle are effective on January 1, 2009 or, for new CO₂ budget units, on the day on which the unit commences operation. (COMAR 26.09.02.02C)
3. The provisions of this permit do not exempt or otherwise relieve the owners or operators of a CO₂ budget source from achieving compliance with any other provision of applicable State and federal laws and regulations. (COMAR 26.09.02.02D).
4. Unless otherwise stated under this subtitle, any time period scheduled to begin:
 - (a) On the occurrence of an act or event, begins on the day the act or event occurs; and
 - (b) Before the occurrence of an act or event, is computed so that the period ends the day before the act or event occurs. (COMAR 26.09.02.02E)
5. Unless otherwise stated, if the final day of any time period for performing an act required by this subtitle falls on a weekend or on a State or federal holiday, the time period is extended until or to the next business day. (COMAR 26.09.02.02F)

D. Permit Requirements

1. The account representative or designate alternate account representative) of each affected unit at a source, (every fossil fuel fired unit with a nameplate capacity of 25 MW or greater) for that source shall comply with the following:
 - (a) The CO₂ authorized account representative for the source shall submit an initial CO₂ budget permit application by October 1, 2008, or 12 months before the date on which the CO₂ budget source, or a new unit at the source, commences operation. (COMAR

26.09.02.04A(2)

- (b) The CO₂ budget permit application shall include the following in a format prescribed by the Department: 1) the identification of the CO₂ budget source; 2) facility name and the ORIS (Office of Regulatory Information Systems) or facility code assigned to the source by the Energy Information Administration of the U. S. Department of Energy, if applicable; 3) each CO₂ budget unit at the source; and 4) other information required by the Department. **(COMAR 26.09.02.04A(3))**
- (c) A CO₂ authorized account representative for the source shall submit a complete application for the renewal of an existing CO₂ budget permit on forms provided by the Department not later than 90 days before the expiration of the current CO₂ budget permit and in accordance with this regulation. **(COMAR 26.09.02.04E)**
2. Each CO₂ budget source shall apply for and have in effect a CO₂ budget permit that contains all applicable requirements. **(COMAR 26.09.02.04A(1))**
 3. The CO₂ budget permit issued by the Department shall be separate but attached to the budget source's Part 70 permit. **(COMAR 26.09.02.04B)**
 4. A CO₂ budget permit expires 5 years from the date of issuance by the Department, unless an earlier expiration date is specified in the permit. **(COMAR 26.09.02.04D)**

E. Monitoring, Initial Certification and Recertification Requirements

1. For each control period in which a CO₂ budget source is subject to the CO₂ budget emissions limitation, the CO₂ authorized account representative of the source shall submit a compliance certification report by the March 1 following the relevant control period. A compliance certification report is not required as part of the compliance obligation during an interim control period. **(COMAR 26.09.02.05A(1))**
2. The CO₂ authorized account representative shall include in the compliance certification report the following:
 - (a) Identification of the source and each CO₂ budget unit at the source;
 - (b) At the CO₂ authorized account representative's option, the serial numbers of the CO₂ allowances that are to be deducted from the source's compliance account for the control period, including the serial numbers of any CO₂ offset allowances that are to be deducted subject to applicable limitations; and
 - (c) The compliance certification required by §A(3) of COMAR 26.11.02.05. **(COMAR 26.09.02.05A(2))**
3. Compliance Certification. In the compliance certification report, the CO₂ authorized account representative shall certify whether the source and each CO₂ budget unit at the source for which the compliance certification is submitted was operated during the control period in compliance with the requirements of this subtitle, including:

- (a) Whether each CO₂ budget unit at the source was operated in compliance with the CO₂ budget emissions limitation;
- (b) Whether the monitoring plan applicable to each unit at the source: (i) has been maintained to reflect the actual operation and monitoring of the unit and (ii) contains all information necessary to track CO₂ emissions from the unit;
- (c) Whether all CO₂ emissions from each unit at the source were monitored or accounted for through the missing data procedures and reported in the quarterly monitoring reports, including: (i) whether all conditional data reported in the quarterly reports; or (ii) if conditional data were reported, whether the status of all conditional data has been resolved and all necessary quarterly report resubmissions have been made;
- (d) Whether the basis for certification or for using an excepted monitoring method or approved alternative monitoring method has changed;
- (e) If a change is required to be reported, include: (i) the nature and reasons for the change; (ii) when the change occurred; and (iii) how the unit's compliance status was determined after the change, including the method used to determine emissions when a change mandated the need for monitor recertification.

(COMAR 26.09.02.05A(3)(a)-(e))

- 4. The Department, at its discretion, may review and conduct independent audits of any compliance certification or other submission required by this permit. **(COMAR 26.09.02.05B(1))**
- 5. The Department may deduct CO₂ allowances from, or transfer CO₂ allowances to, a compliance account to correct errors in the account or to accurately reflect CO₂ emissions, based on the information in the compliance certification or other submissions. **(COMAR 26.09.02.05B(2))**
- 6. The owner or operator of a CO₂ budget unit shall:
 - (a) Install monitoring systems to monitor CO₂ concentration, stack gas flow rate, oxygen concentration, heat input, and fuel flow rate;
 - (b) Install all monitoring systems in accordance with 40 CFR Part 75, except for equation G-1 in Appendix G (see below); and

$$W_{CO_2} = \frac{(MW_C + MW_{O_2}) \times W_C}{2,000 MW_C} \text{ (Eq. G-1)}$$

Where:

W_{CO₂}=CO₂ emitted from combustion, tons/day.

MW_C=Molecular weight of carbon (12.0).

MW_{O₂}=Molecular weight of oxygen (32.0)

W_C= Carbon burned, lb/day, determined using fuel sampling and analysis and fuel feed rates.

- (c) Record, report, and verify the data from the monitoring systems.

(COMAR 26.09.02.10A(1) (a)-(c))

7. Install and certify the monitoring system on or before the following dates:
 - (a) For a CO₂ budget unit that commences commercial operation before July 1, 2008, the owner or operator shall comply on or before January 1, 2009; and
 - (b) For a CO₂ budget unit that commences commercial operation or constructs a new stack or flue on or after July 1, 2008, the owner or operator shall comply by January 1, 2009, or 90 operating days after the date on which the unit commences commercial operation.
(COMAR 26.09.02.10A(1)(d))
8. The owner or operator of a CO₂ budget unit that does not meet the applicable compliance date shall, in accordance with the provisions in 40 CFR §75.31(b)(2) or (c)(3), or §2.4 of Appendix D, determine, record, and report maximum potential or, as appropriate, minimum potential for the following:
 - (a) CO₂ concentration;
 - (b) CO₂ emissions rate;
 - (c) Stack gas moisture content;
 - (d) Fuel flow rate; and
 - (e) Any other parameter required to determine CO₂ mass emissions.
(COMAR 26.09.02.10A(2)(a)-(e))
9. The owner or operator of a CO₂ budget unit that does not meet the applicable compliance date for any monitoring system shall determine, record, and report substitute data using the applicable missing data procedures in 40 CFR Part 75 Subpart D, or Appendix D, instead of the maximum potential values or, as appropriate, minimum potential values for a parameter, if the owner or operator demonstrates that there is continuity between the data streams for that parameter before and after the construction or installation. **(COMAR 26.09.02.10A(3))**
10. An owner or operator of a CO₂ budget unit or a non-CO₂ budget unit monitored under 40 CFR §75.72 (b) (2) (ii) may not:
 - (a) Use any alternative monitoring system, alternative reference method, or any other alternative for the required continuous emissions monitoring system without having obtained prior written approval from the Department;
 - (b) Operate the unit so as to discharge, or allow to be discharged, CO₂ emissions to the atmosphere without accounting for all emissions in accordance with the applicable provisions of this chapter and 40 CFR Part 75;
 - (c) Disrupt the operation of the CEMS, any portion of the CEMS, or any other approved emissions monitoring method, and thereby avoid monitoring and recording CO₂ mass emissions discharged into the atmosphere, except for periods of recertification or periods when calibration, quality assurance testing, or maintenance is performed; or

(d) Permanently discontinue use of the approved CEMS unless the owner or operator monitors emissions with a system approved in accordance with this chapter and 40 CFR Part 75.

(COMAR 26.09.02.10 A(4)(a)-(d))

11. For purposes of this subtitle only, the owner or operator of a CO₂ budget unit is exempt from demonstrating compliance with the initial certification requirements of 40 CFR §75.20 for a monitoring system if the following conditions are met:

(a) The monitoring system has been previously certified in accordance with 40 CFR §75.20; and

(b) The applicable quality assurance and quality-control requirements of 40 CFR §75.21 and Appendix B and Appendix D of 40 CFR Part 75 are fully met for the certified monitoring system.

(COMAR 26.09.02.10B(1)(a)-(b))

12. The recertification provisions of this regulation apply to a monitoring system exempt from the initial certification requirements of this regulation. **(COMAR 26.09.02.10B(2))**

13. If the Department has previously approved a petition under 40 CFR §75.72(b)(2)(ii) or 40 CFR §75.16(b)(2)(ii)(B) pursuant to 40 CFR §75.13 for apportioning the CO₂ emissions rate measured in a common stack or a petition under 40 CFR §75.66 for an alternative requirement in 40 CFR Part 75, the CO₂ authorized account representative shall resubmit the petition to the Department to determine whether the approval applies under this chapter. **(COMAR 26.09.02.10B(3))**

14. The owner or operator of a CO₂ budget unit shall comply with the initial certification and recertification procedures for a CEMS and an excepted monitoring system under 40 CFR Part 75, Appendix D. **(COMAR 26.09.02.10B(4))**

15. The owner or operator of a unit that qualifies to use the low mass emissions excepted monitoring methodology in 40 CFR §75.19 or that qualifies to use an alternative monitoring system under 40 CFR Part 75, Subpart E, shall comply with this regulation. **(COMAR 26.09.02.10B(5))**

16. When the owner or operator replaces, modifies, or changes a CEMS that the Department determines significantly affects the ability of the system to accurately measure or record CO₂ mass emissions or to meet the quality assurance and quality control requirements of 40 CFR §75.21 or Appendix B, the owner or operator shall recertify the monitoring system according to 40 CFR §75.20(b). **(COMAR 26.09.02.10C(1))**

17. When the owner or operator replaces, modifies, or changes the flue gas handling system or the unit's operation in a manner that the Department determines has significantly changed the flow or concentration profile, the owner or operator shall recertify the CEMS according to 40 CFR §75.20(b). **(COMAR 26.09.02.10C(2))**

18. Approval Process for Initial Certifications and Recertification. The procedures in 40 CFR §75.20(b)(5) and (g)(7) apply for recertification. The CO₂ authorized account representative shall submit to the Department:

(a) A written notice of the dates of certification; and

(b) A recertification application for each monitoring system, including the information

specified in 40 CFR §75.63.
(COMAR 26.09.02.10C(3)(a)-(b))

19. Provisional certification data for a monitor shall be:

- (a) Determined in accordance with 40 CFR §75.20(a)(3);
- (b) A provisionally certified monitor may be used for a period not to exceed 120 days after receipt of the complete certification application for the monitoring system or component; and
- (c) Data measured and recorded by the provisionally certified monitoring system or component is considered valid quality assured data, retroactive to the date and time of provisional certification, if the Department does not issue a notice of disapproval within 120 days of receipt of the complete certification application.

(COMAR 26.09.02.10C(4)(a)-(c))

20. The Department shall issue a written notice of approval or disapproval of the certification application to the owner or operator within 120 days of receipt of the complete certification application. (COMAR 26.09.02.10D(1))

21. If the Department does not issue the notice within the 120-day period, each monitoring system that meets the applicable performance requirements of 40 CFR Part 75 and is included in the certification application shall be deemed certified for use. (COMAR 26.09.02.10D(2))

22. If the certification application is complete and shows that each monitoring system meets the applicable performance requirements of 40 CFR Part 75, the Department shall issue a written notice of approval of the certification application within 120 days of receipt. (COMAR 26.09.02.10D(3))

23. If the certification application is not complete, the Department shall issue a written notice of incompleteness that sets a reasonable date by which the CO₂ authorized account representative is to submit the additional information required to complete the certification application. (COMAR 26.09.02.10D(4))

24. If the CO₂ authorized account representative does not comply with the notice of incompleteness by the specified date, the Department may issue a notice of disapproval. (COMAR 26.09.02.10D(5))

25. If the Department issues a notice of disapproval of a certification application or a notice of disapproval of certification status, the owner or operator shall substitute the following values for each disapproved monitoring system, for each hour of unit operation during the period of invalid data beginning with the date and hour of provisional certification and continuing until the time, date, and hour specified under 40 CFR §75.20(a)(5)(i) or 75.20(g)(7):

- (a) For units using or intending to monitor for CO₂ mass emissions using heat input or for units using the low mass emissions excepted methodology under 40 CFR §75.19, the maximum potential hourly heat input of the unit; or
- (b) For units intending to monitor for CO₂ mass emissions using a CO₂ pollutant concentration monitor and a flow monitor, the maximum potential concentration of CO₂

and the maximum potential flow rate of the unit under 40 CFR Part 75, Appendix A, §2.1.

(COMAR 26.09.02.10 D(6)(a)-(b))

26. The CO₂ authorized account representative shall submit a notification of certification retest dates and a new certification application. The owner or operator shall repeat all certification tests or other requirements that were failed by the monitoring system, as indicated in the Department's notice of disapproval, not later than 30 operating days after the date of issuance of the notice of disapproval. (COMAR 26.09.02.10D(7))
27. The owner or operator of a unit qualified to use the low mass emissions excepted methodology under 40 CFR §75.19 shall meet the applicable certification and recertification requirements of 40 CFR §§75.19(a) (2) and 75.20(h). (COMAR 26.09.02.10E(1))
28. If the owner or operator of this unit elects to certify a fuel flow meter system for heat input determinations, the owner or operator shall also meet the certification and recertification requirements in 40 CFR §75.20(g). (COMAR 26.09.02.10E(2))
29. Certification and Recertification Procedures for Alternative Monitoring Systems. For each unit for which the owner or operator intends to use an alternative monitoring system approved by the Department, 40 CFR Part 75, Subpart E, shall be used to comply with the applicable notification and application procedures of 40 CFR §75.20(f). (COMAR 26.09.02.10F)
30. When any monitoring system fails to meet the quality assurance and quality control requirements or data validation requirements of 40 CFR Part 75, data shall be substituted using the applicable procedures in 40 CFR Part 75, Subpart D, Appendix D. (COMAR 26.09.02.10G(1))
31. Audit Decertification.
 - (a) Whenever both an audit of a monitoring system and a review of the initial certification or recertification application reveal that any monitoring system should not have been certified or recertified because it did not meet a particular performance specification or the applicable provisions of 40 CFR Part 75, both at the time of the initial certification or recertification application submission and at the time of the audit, the Department shall issue a notice of disapproval of the certification status of the monitoring system.
 - (b) By issuing the notice of disapproval, the certification status of the monitoring system is prospectively revoked.
(COMAR 26.09.02.10G(2))
32. The data measured and recorded by the monitoring system may not be considered valid quality-assured data from the date of issuance of the notification of the revoked certification status. (COMAR 26.09.02.10G(3))

F. Record Keeping and Reporting Requirements

1. The CO₂ authorized account representative shall comply with all record-keeping and reporting requirements in COMAR 26.09.02.10 and the applicable record-keeping and reporting requirements under 40 CFR §75.73. (COMAR 26.09.02.11A)
2. The CO₂ authorized account representative shall submit quarterly reports as described below in

this section. (COMAR 26.09.02.11B(1))

3. The report shall contain the CO₂ mass emissions data for the CO₂ budget unit in an electronic format, unless otherwise required by the Department, for each calendar quarter beginning with:
 - (a) The calendar quarter covering January 1, 2009 — March 31, 2009, for a unit that commences commercial operation before July 1, 2008; or (COMAR 26.09.02.11B(2)(a))
 - (b) For a unit commencing commercial operation on or after July 1, 2008, the calendar quarter corresponding to the earlier of the: (i) date of provisional certification; or (ii) applicable deadline for initial certification. (COMAR 26.09.02.11B(2)(b))
 - (c) If the quarter is the third or fourth quarter of 2008, reporting shall commence in the quarter covering January 1, 2009 through March 31, 2009. (COMAR 26.09.02.11B(3))
4. The CO₂ authorized account representative shall submit each quarterly report within 30 days following the end of the calendar quarter covered by the report and in accordance with 40 CFR Part 75, Subpart H, §75.64 and 40 CFR Part 75, Subpart G except for the opacity, NO_x and SO₂ provisions. (COMAR 26.09.02.11B(4))
5. Compliance Certification. The CO₂ authorized account representative shall submit a compliance certification in support of each quarterly report. The certification shall state that:
 - (a) The monitoring data submitted were recorded in accordance with the applicable requirements of this chapter and 40 CFR Part 75, including the quality assurance procedures and specifications;
 - (b) For a unit with add-on CO₂ emissions controls and for all hours where data are substituted in accordance with 40 CFR §75.34(a)(1), the add-on emissions controls were operating within the range of parameters listed in the quality assurance and quality control program under 40 CFR Part 75, Appendix B, and the substitute values do not systematically underestimate CO₂ emissions; and
 - (c) The CO₂ concentration values substituted for missing data under 40 CFR Part 75, Subpart D, do not systematically underestimate CO₂ emissions.
(COMAR 26.09.02.11 B(5)(a)-(c))
6. The CO₂ authorized account representative of a CO₂ budget unit may submit a petition to the Department under 40 CFR §75.66 requesting approval to apply an alternative to any requirement of this chapter. (COMAR 26.09.02.11C)
7. The CO₂ authorized account representative or alternate CO₂ authorized account representative of a CO₂ budget unit that burns eligible biomass as a compliance mechanism under this chapter shall report the following information for each calendar quarter:
 - (a) For each shipment of solid eligible biomass fuel fired at the CO₂ budget unit:
 - (i) Total eligible biomass fuel input, on an as-fired basis, in pounds; and
 - (ii) The moisture content, on an as-fired basis, as a fraction of weight;

- (b) For each distinct type of gaseous eligible biomass fuel fired at the CO₂ budget unit:
 - (i) The density of the biogas, on an as-fired basis, in pounds per standard cubic foot; and
 - (ii) The moisture content of the biogas, as a fraction by total weight;
- (c) For each distinct type of eligible biomass fuel fired at the CO₂ budget unit:
 - (i) The dry basis carbon content of the fuel type, as a fraction by dry weight;
 - (ii) The dry basis higher heating value, in MMBtu per dry pound;
 - (iii) The total dry basis eligible biomass fuel input, in pounds;
 - (iv) The total eligible biomass fuel heat input; and
 - (v) Chemical analysis, including heat value and carbon content;
- (d) The total amount of CO₂ emitted from the CO₂ budget unit due to firing eligible biomass fuel, in tons, calculated as in §D(2)(b) of this regulation;
- (e) The total heat input to the CO₂ budget unit due to firing eligible biomass fuel, in MMBtu, calculated below; and
- (f) Description and documentation of monitoring technology and fuel sampling methodology employed, including sampling frequency.

(COMAR 26.09.02.11D(1)(a)-(f))

8. An owner or operator of a CO₂ budget unit shall calculate and submit on a quarterly basis the total dry weight for each distinct type of eligible biomass fired by the CO₂ budget unit during the reporting quarter:

- (a) For solid eligible biomass fuel, determined as follows:

$$F_j = \sum_{i=1}^m (1 - M_i) x F_i$$

where:

- (i) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j;
- (ii) F_i = Eligible biomass as fired fuel input (pounds) for fired shipment i;
- (iii) M_i = Moisture content (fraction) for fired shipment i;
- (iv) i = fired fuel shipment;
- (v) j = fuel type; and
- (vi) m = number of shipments.

- (b) For gaseous eligible biomass fuel, as determined as follows:

$$F_j = D_j x V_j x (1 - M_j)$$

where:

- (i) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j;
- (ii) D_j = Density of biogas (pounds/scf) for fuel type j;
- (iii) V_j = Total volume (scf) for fuel type j;
- (iv) M_j = Moisture content (fraction) for fuel type j; and
- (v) j = fuel type

(COMAR 26.09.02.11D(2)(a)-(b))

9. The amount of CO₂ emissions that is produced from the firing of eligible biomass for any full calendar quarter, during which either no fuel other than eligible biomass is combusted or during which fuels other than eligible biomass are combusted, is determined as follows:

$$CO_2 \text{ tons} = \sum_{j=1}^n F_j \times C_j \times O_j \left(\frac{44 \left(\frac{g}{molCO_2} \right)}{12 \left(\frac{g}{molC} \right)} \right) (0.0005)$$

where:

- (a) CO₂ tons = CO₂ emissions due to firing of eligible biomass for the reporting quarter;
- (b) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j, as calculated in §D(2)(a) of this regulation;
- (c) C_j = Carbon fraction (dry basis) for fuel type j;
- (d) O_j = Oxidation factor for eligible biomass fuel type j, derived for solid fuels based on the ash content of the eligible biomass fired and the carbon content of this ash or for gaseous eligible biomass fuels, a default oxidation factor of 0.995 may be used;

(e)
$$\frac{44 \left(\frac{g}{molCO_2} \right)}{12 \left(\frac{g}{molC} \right)}$$

The number of tons of carbon dioxide that are created when one ton of carbon is combusted;

- (f) 0.0005 = The number of short tons which is equal to one pound;
- (g) j = Fuel type; and
- (h) n = number of distinct fuel types.

(COMAR 26.09.02.11D(3))

10. Heat input due to firing of eligible biomass for each quarter shall be determined as follows:

- (a) For each distinct fuel type:

$$H_j = F_j \times HHV_j$$

where:

- (i) H_j = Heat input (MMBtu) for fuel type j;
- (ii) F_j = Total eligible biomass dry basis fuel input (pounds) for fuel type j;
- (iii) HHV_j = Higher heating value (MMBtu/pound), dry basis, for fuel type j, as determined through chemical analysis;
- (iv) j = Fuel type.

- (b) For all fuel types:

$$\text{HeatInputMMBtu} = \sum_{j=1}^n H_j$$

where:

- (i) H_j = Heat input (MMBtu) for fuel type j ;
- (ii) j = fuel type; and
- (iii) n = number of distinct fuel types.

Fuel sampling methods and fuel sampling technology shall be consistent with the New York State Renewable Portfolio Standard Biomass Guidebook, May 2006.

(COMAR 26.09.02.11D(4) & D(5))

11. A CO₂ budget unit shall submit to the Department the megawatt-hour value and a statement certifying that the megawatt-hour of electrical output reported reflects the total actual electrical output for all CO₂ budget units at the facility used by the independent system operator (ISO) to determine settlement resources of energy market participants. **(COMAR 26.09.02.11E(1))**
12. A CO₂ budget unit shall report gross hourly megawatts to the Department in the same electronic data report (EDR) for gross output as submitted to the EPA Administrator, for the operating time in the hour, added for all hours in a year. **(COMAR 26.09.02.11E(2))**
13. A CO₂ budget unit shall submit the net electrical output to the Department in accordance with this regulation. A CO₂ budget source whose electrical output is not used in the independent system operator (ISO) energy market settlement determinations shall propose a method for quantification of net electrical output. **(COMAR 26.09.02.11E(3))**
14. Report of net Steam Output.
 - (a) CO₂ budget sources selling steam shall use billing meters to determine net steam output or an alternative method to measure net steam output approved by the Department.
 - (b) If data for steam output is not available, the CO₂ budget source may report heat input, substituting useful steam output for steam output.
(COMAR 26.09.02.11E(4)(a)-(b))
15. Each CO₂ budget source shall submit an output monitoring plan with a description and diagram that include the following:
 - (a) If the CO₂ budget unit monitors net electric output, the diagram shall contain all CO₂ budget units and all generators served by each CO₂ budget unit and the relationship between CO₂ budget units and generators;
 - (b) If a generator served by a CO₂ budget unit is also served by a nonaffected unit, the nonaffected unit and its relationship to each generator shall be indicated on the diagram;
 - (c) The diagram shall indicate where the net electric output is measured and include all electrical inputs and outputs to and from the plant;
 - (d) If net electric output is determined using a billing meter, the diagram shall show each

billing meter used to determine net sales of electricity and show that all electricity measured at the point of sale is generated by the CO₂ budget units;

- (e) If the CO₂ budget unit monitors net thermal output, the diagram shall indicate all steam or hot water coming into the net steam system, including steam from CO₂ budget units and nonaffected units, and all exit points of steam or hot water from the net steam system;
- (f) Each input and output stream shall have an estimated temperature, pressure and phase indicator, and an enthalpy in Btu per pound;
- (g) The diagram of the net steam system shall identify all useful loads, house loads, parasitic loads, any other steam loads, and all boiler feedwater returns;
- (h) The diagram shall represent all energy losses in the system as either usable or unusable losses;
- (i) The diagram shall indicate all flow meters, temperature or pressure sensors, or other equipment used to calculate gross thermal output; and
- (j) If a sales agreement is used to determine net thermal output, the diagram shall show the monitoring equipment used to determine the sales of steam.

(COMAR 26.09.02.11F(2)(a)-(j))

16. The description of the output monitoring system shall include:

- (a) A written description of the output system and the equations used to calculate output, and, for net thermal output systems, descriptions and justifications of each useful load;
- (b) A detailed description of all quality assurance and quality control activities that will be performed to maintain the output system; and
- (c) Documentation supporting any output value to be used as a missing data value if there are periods of invalid output data.
- (d) The missing data output value shall be either zero or an output value that is likely to be lower than a measured value and approved as part of the required monitoring plan.

(COMAR 26.09.02.11F(3)(a)-(b))

17. A certification statement shall be submitted by the CO₂ authorized account representative stating that either:

- (a) The output monitoring system consists entirely of billing meters; or
- (b) The output monitoring system meets one of the accuracy requirements for nonbilling meters.

(COMAR 26.09.02.11G(1)(a)-(b))

18. The billing meter shall record the electric or thermal output. Any electric or thermal output values reported shall be the same as the values used in billing for the output. (COMAR 26.09.02.11G(2))
19. For nonbilling meters, either the output monitoring system shall meet an accuracy of within 10 percent of the reference value, or each component monitor for the output system shall meet an accuracy of within 3 percent of the full scale value, whichever is less stringent. (COMAR 26.09.02.11G(3))
20. The system approach to accuracy shall include:
 - (a) A determination of how the system accuracy of 10 percent is achieved using the individual components in the system; and
 - (b) Data loggers and any watt meters used to calculate the final net electric output data or any flowmeters for steam or condensate, temperature measurement devices, absolute pressure measurement devices, and differential pressure devices used for measuring thermal energy.
(COMAR 26.09.02.11G(4)(a)-(b))
21. If, upon testing a piece of output measurement equipment, it is determined that the output readings are not accurate to within 3 percent of the full scale value, then the equipment shall be repaired or replaced to meet that requirement. (COMAR 26.09.02.11G(5))
22. Data is invalid until the output measurement equipment passes an accuracy test or is replaced with another piece of equipment that passes the accuracy test. (COMAR 26.09.02.11G(6))
23. Ongoing quality assurance and quality control activities shall be performed in order to maintain the output system. (COMAR 26.09.02.11H(1))
24. If billing meters are used to determine output, quality assurance and quality control activities are not required beyond what are already performed. (COMAR 26.09.02.11H(2))
25. Certain types of equipment such as potential transformers, current transformers, nozzle and venture type meters, and the primary element of an orifice plate only require an initial certification of calibration and do not require periodic recalibration unless the equipment is physically changed.
 - (a) Pressure and temperature transmitters accompanying an orifice plate will require periodic retesting.
 - (b) For other types of equipment, the meter accuracy shall be recalibrated or verified at least once every 2 years, unless a consensus standard allows for less frequent calibrations or accuracy tests.
 - (c) For nonbilling meters, either the output monitoring system shall meet an accuracy of within 10 percent of the reference value, or each component monitor for the output system shall meet an accuracy of within 3 percent of the full scale value, whichever is less stringent.
 - (d) If, upon testing a piece of output measurement equipment, it is determined that the

output readings are not accurate to within 3 percent of the full scale value, then the equipment shall be repaired or replaced to meet that requirement.

(COMAR 26.09.02.11H(3)(a)-(e))

26. Out-of-Control Periods.

(a) If, upon testing a piece of output measurement equipment, it is determined that the output readings are not accurate to the certification value, data is invalid until the output measurement equipment passes an accuracy test or is replaced with another piece of equipment that passes the accuracy test.

(b) All invalid data shall be replaced by either zero or an output value that is likely to be lower than a measured value and that is approved as part of the required monitoring plan.

(COMAR 26.09.02.11H(4)(a)-(b))

27. The CO₂ authorized account representative shall submit annual output reports, as follows:

(a) Data shall be sent both electronically and in hardcopy by March 1 for the immediately preceding calendar year; and (COMAR 26.09.02.11I(1))

(b) The annual report shall include unit level megawatt hours, all useful steam output, and a certification statement from the CO₂ authorized account representative stating the following, "I am authorized to make this submission on behalf of the owners and operators of the CO₂ budget sources or CO₂ budget units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment."

(COMAR 26.09.02.11I(2))

G. CO₂ Emission Offset Projects

1. In order to qualify for the award of CO₂ offset allowances, the following offset projects shall satisfy all applicable requirements identified in COMAR 26.09.03 and initially commence on or after December 20, 2005:

(a) Landfill methane capture and destruction;

(b) Sequestration of carbon due to reforestation, improved forest management, or avoided conversion; and

(c) Avoided methane emissions from agricultural manure management operations.

(COMAR 26.09.03.02A(1)-(3))

4. Permit Application (See Attachment)



**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

BACKGROUND

The Rock Springs Generation Facility, located at 1423 Rock Springs Road in Rising Sun, Maryland 21911 (Cecil County), is a simple-cycle natural gas-fired power generation plant. Its applicable Standard Industrial Classification (SIC) Code is 4911-Electric Services.

The facility is permitted for six (6) General Electric 7 FA gas combustion turbines; each rated 190 MW at base load, zero degrees ambient temperature. Each turbine operates in simple cycle mode and combusts only pipeline quality natural gas. Each turbine is equipped with dry, low-NO_x burners. Each of the four operating combustion turbines is equipped with a single discharge stack.

Four of the six turbines were installed in October 2001, and the remaining two (EU-5 and EU-6) were never installed. All four turbines (EU 1 thru E-4) are limited to a combined 8,000 hours of operation per year, based on a cumulative 12-month rolling average.

The facility was originally permitted to inject wastewater into the turbine exhaust stacks. However, the facility has not been using this practice. The prior renewal permit required the facility to submit to the Department for approval of an alternate compliance monitoring plan for particulate matter and volatile organic compound emission limits prior to resuming injection of wastewater into the turbine exhaust. For this renewal, the facility requested the removal of the option to inject wastewater into the turbine exhaust stacks.

The plant also includes two (2) [7.5 & 9.0] million British Thermal Units per hour (MMBtu/hr) natural gas-fired heaters and one (1) 200 horsepower (hp) emergency diesel firewater pump and one (1) 4-stroke cycle, 6 cylinder switchyard diesel-fired emergency generator.

The facility received a Maryland Public Service commission (PSC) Certificate of Public Convenience and Necessity (CPCN) Final Order Number 7652 (Case No. 8821) on November 30, 2000 and a Prevention of Significant Deterioration (PSD) approval and non-attainment Major New source Review approval under the CPCN pursuant to the Code of Maryland Regulations (COMAR 26.11.02.17).

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

The following table summarizes the actual emissions from Rock Springs Generation Facility based on its Annual Emission Certification Reports:

Table 1: Actual Emissions

Year	NO_x (TPY)	SO_x (TPY)	PM₁₀ (TPY)	CO (TPY)	VOC (TPY)	Total HAP (TPY)
2017	78.77	1.60	4.75	14.06	5.27	0.00
2016	140.91	2.60	8.69	20.96	9.62	0.00
2015	126.64	2.40	7.97	24.10	8.88	0.00
2014	84.28	1.00	3.02	16.72	3.37	0.00
2013	54.10	0.08	3.10	15.85	3.45	0.00

Cecil County is located in the Philadelphia Nonattainment Area for ozone. Therefore, the major source threshold for triggering Title V permitting requirements in Cecil County is 25 tons per year for VOC, 25 tons for NO_x, and 100 tons per year for any other criteria pollutants and 10 tons for a single HAP or 25 tons per year for total HAPS. Since the actual NO_x emissions from the facility are greater than the major source threshold, Rock Springs Generation Facility is required to obtain a Title V – Part 70 Operating Permit under COMAR 26.11.03.01.

On October 30, 2018, the Department received the Rock Springs Generation Facility’s Part 70-permit renewal application, which was submitted by the Essential Power Rock Springs, LLC. An administrative completeness review was conducted and the application was deemed to be complete. A completeness determination letter was sent to the Rock Springs Generation Facility on November 2, 2018 granting the facility an application shield

Changes and Modifications to the Part 70 Operating Permit

The following changes and/or modifications have been incorporated into the renewal Title V – Part 70 Operating Permit for Rock Springs Generation Facility:

November 16, 2017: A general permit was applied for and approval granted for a 7.5 MMBtu/hr natural gas-fired heater to condition natural gas from the pipeline [015-0202-5-0148].

Title V renewal application noted the following:

- Essential Power Rock Springs was now the sole owner of the facility;
- Removal of the option to inject wastewater into the turbine exhaust stacks.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

New Source Performance Standards (NSPS) – 40 CFR Part 60

Subpart GG for Stationary Gas Turbines applies stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules (10 million Btu) per hour, based on the lower heating value of the fuel fired which commences construction, modification, or reconstruction after October 3, 1977.

The combustion turbines were installed in 2001 and are subject to the requirements of Subpart GG.

National Emission Standard for Hazardous Air Pollutants (NESHAP) – 40 CFR Part 63

The Rock Springs Generation Facility is not a major HAP Emissions Source. Instead it is an area HAP emission source and is subject to the following MACTs:

Subpart ZZZZ — Stationary Reciprocating Internal Combustion Engines. Requirements for Existing Stationary RICE Located at Area Sources of HAP Emission Units: 200 hp emergency diesel fired water engine and pump; and 100 kW emergency diesel switchyard generator are subject to this subpart.

Subpart JJJJJJ – Area Source Boiler MACT- Industrial, Commercial and Institutional boilers and process heaters located at area sources of HAPs. The [7.5 & 9.0 MMBtu/hr] heaters are exempt from the requirements of this MACT because they are all natural gas fired units.

Compliance Assurance Monitoring (CAM) Requirement.

Rock Springs Generation Facility conducted a Compliance Assurance Monitoring (CAM) analysis for the facility and determined that the facility is not subject to the (CAM) Rule 40 CFR Subpart 64. CAM is intended to provide a reasonable assurance of compliance with applicable requirements under the Clean Air Act for large emission units that rely on air pollution control (APC) equipment to achieve compliance. The CAM approach establishes monitoring for the purpose of: (1) documenting continued operation of the control measures within ranges of specified indicators of performance (such as emissions, control device parameters, and process parameters) that are designed to provide a reasonable assurance of compliance with applicable requirements; (2) indicating any excursions from these ranges; and (3) responding to the data so that the cause or causes of the excursions are corrected. In order for a unit to be subject to CAM, the unit must be located at a major source, be subject to an emission limitation or standard; use a control device to achieve compliance; have post-control emissions of at least 100% of the major source amount (for initial CAM

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

submittals); and must not otherwise be exempt from CAM. Applicability determinations are made on a pollutant-by-pollutant basis for each emission unit.

Rock Springs Generation Facility has no emissions sources which utilize any APC devices to achieve compliance, therefore CAM is not applicable.

Acid Rain Permit

Title IV of the Clean Air Act set a goal of reducing annual SO₂ emissions by 10 million tons below 1980 levels. To achieve these reductions, the law required a two-phase tightening of the restrictions placed on fossil fuel-fired power plants.

Phase I began in 1995 and affected 263 units at 110 mostly coal-burning electric utility plants located in 21 eastern and midwestern states. An additional 182 units joined Phase I of the program as substitution or compensating units, bringing the total of Phase I affected units to 445. Emissions data indicate that 1995 SO₂ emissions at these units nationwide were reduced by almost 40 percent below their required level.

Phase II, which began in the year 2000, tightened the annual emissions limits imposed on these large, higher emitting plants and also set restrictions on smaller, cleaner plants fired by coal, oil, and gas, encompassing over 2,000 units in all. The program affects existing utility units serving generators with an output capacity of greater than 25 megawatts and all new utility units.

Cross State Air Pollution Rule (CSAPR)

The U.S. Environmental Protection Agency (EPA) issued the Cross-State Air Pollution Rule (CSAPR) in July 2011 to address Clean Air Act requirements concerning interstate transport of air pollution and to replace the previous Clean Air Interstate Rule (CAIR) which the D.C. Circuit remanded to the EPA for replacement. Following the original rulemaking, CSAPR was amended by three further rules known as the Supplemental Rule, the First Revisions Rule, and the Second Revisions Rule. As amended, CSAPR requires 28 states to limit their state-wide emissions of sulfur dioxide (SO₂) and/or nitrogen oxides (NO_x) in order to reduce or eliminate the states' contributions to fine particulate matter and/or ground-level ozone pollution in other states. The emissions limitations are defined in terms of maximum state-wide "budgets" for emissions of annual SO₂, annual NO_x, and/or ozone season NO_x by each state's large electricity generating units (EGUs). The emissions budgets are implemented in two phases of generally increasing stringency. As the mechanism for achieving compliance with the emissions limitations, CSAPR establishes federal implementation plans (FIPs) that require large EGUs in each affected state to participate in one or

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

more new emission trading programs that supersede the existing CAIR emissions trading programs. On December 30, 2011, in response to petitions challenging CSAPR, the D.C. Circuit granted a stay of the rule, ordering the EPA to continue administering CAIR on an interim basis. In a subsequent decision, the Court vacated CSAPR but on April 29, 2014, the U.S. Supreme Court reversed that decision and remanded the case to the D.C. Circuit Court for further proceedings. In order to allow CSAPR to replace CAIR in an orderly manner, EPA filed a motion asking the D.C. Circuit to lift the stay and to toll, by three years, all CSAPR compliance deadlines that had not yet passed. On October 23, 2014, the Court granted the EPA's motion.

Consistent with the Court's order, compliance with CSAPR's Phase 1 emissions budgets is now required in 2015 and 2016 and compliance with the rule's Phase 2 emissions budgets and assurance provisions is now required in 2017 and beyond.

This renewal Part 70 permit identifies the applicable regulations of the CSAPR rule as found in 40 CFR Part 97 subparts AAAAAA- NO_x Annual Trading Program, subparts BBBB- NO_x Ozone Season Trading Program, and subpart CCCCC SO₂ Group 1 Trading Program.

Regional Greenhouse Gas Initiative

The Regional Greenhouse Gas Initiative (RGGI) is a market-based carbon dioxide (CO₂) cap and trade program designed to reduce CO₂ emissions from fossil fuel-fired power plants. It is a Maryland State-only enforceable program. The Healthy Air Act required Maryland to join RGGI by July 2007. Maryland joined RGGI by signing RGGI's multi-state Memorandum of Understanding (MOU) on April 20, 2007. The MOU requires Maryland to adopt regulations by December 31, 2008, implementing the RGGI program. The Maryland CO₂ Budget Trading Program, Code of Maryland Regulations (COMAR) 26.09.01 to .03, became effective on July 17, 2008. COMAR 26.09.04 became effective as an emergency action on April 4, 2008 and as a permanent action on August 25, 2008.

The regulations require the following:

- 1) Implement a cap and trade program for CO₂ emissions from fossil fuel-fired electric generating units located in Maryland having a capacity of at least 25 megawatts;
- 2) Distribute CO₂ allowances to stakeholders through auction, sale and/or allocation;
- 3) Require each affected source to have a CO₂ budget account representative and a compliance account;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

- 4) Require each budget unit to hold in its source's compliance account at the end of each 3-year control period one allowance for each ton of CO₂ emissions emitted in that period;
- 5) Require sources to monitor emissions and submit quarterly and annual emission reports;
- 6) Establish set-aside accounts for voluntary renewable purchase, limited industrial generator exemptions, and long-term contract generators;
- 7) Establish a consumer benefit or strategic energy purpose fund to support energy efficiency, directly mitigate electricity ratepayer impacts, promote renewable or non-carbon emitting energy technologies, stimulate or reward investment in the development of innovative carbon emissions abatement technologies with significant carbon reduction potential, and fund administration of the program; and
- 8) Establish procedures to evaluate and award allowances to persons who undertake offset projects that will reduce CO₂ emissions.
- 9) Require affected sources to submit an application for a CO₂ Budget Permit. A CO₂ Budget Permit when issued will be an attachment to the Part 70 permit.

Greenhouse Gas (GHG) Emissions

Rock Springs Generation Facility emits the following greenhouse gases (GHGs) related to Clean Air Act requirements: carbon dioxide, methane, and nitrous oxide. These GHGs originate from various processes contained within the facility premises applicable Rock Springs Generation Facility. The facility has not triggered Prevention of Significant Deterioration (PSD) requirements for GHG emissions; therefore, there are no applicable GHG Clean Air Act requirements. While there may be no applicable requirements as a result of PSD, emission certifications reports for the years 2015, 2016, and 2017, showed that Rock Springs Generation Facility is a major source (threshold: 100,000tpy CO₂e) for GHG's (see Table 2 below). The Permittee shall quantify facility wide GHGs emissions and report them in accordance with Section 3 of the Part 70 permit.

The following table summarizes the actual emissions from Rock Springs Generation Facility based on its Annual Emission Certification Reports:

GHG	Conversion factor	2015 tpy CO₂e	2016 tpy CO₂e	2017 tpy CO₂e
Carbon dioxide CO ₂	1	498,885.05	542,301.27	296,912.31
Methane CH ₄	25	8.35	9.11	4.99
Nitrous Oxide N ₂ O	298	0.835	0.911	0.500
Total GHG CO₂eq		498,894.24	542,311.28	296,917.80

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

EMISSION UNIT IDENTIFICATION

Rock Springs Generation Facility has identified the following emission units as being subject to Title V permitting requirements and having applicable requirements.

Table 3: Emission Unit Identification

Emissions Unit Number	ARA Registration Number	Emissions Unit Name and Description	Date of Installation
EU-1	5-0076	Four (4) General Electric 7 FA gas combustion turbines, each with a maximum output of 190 MW	October 2001
EU-2	5-0077		
EU-3	5-0078		
EU-4	5-0079		
EU-7	6-0205	One (1) 9 million Btu per hour natural gas fired heater equipped with low NO _x burners.	October 2001
EU-8	N/A	One (1) 200 horsepower (hp) emergency diesel fire-water engine and pump.	September 2002
EU-9	N/A	One (1) 100 kilowatt (kW) emergency diesel switchyard generator.	September 2002
EU-10	015-0202-5-0148	One (1) 7.5 million Btu per hour natural gas fired heater equipped with low NO _x burners.	November 2017

AN OVERVIEW OF THE PART 70 PERMIT

The Fact Sheet is an informational document. If there are any discrepancies between the Fact Sheet and the Part 70 permit, the Part 70 permit is the enforceable document.

Section I of the Part 70 Permit contains a brief description of the facility and an inventory list of the emissions units for which applicable requirements are identified in Section IV of the permit.

Section II of the Part 70 Permit contains the general requirements that relate to administrative permit actions. This section includes the procedures for renewing, amending, reopening, and transferring permits, the relationship to permits to construct and approvals, and the general duty to provide information and to comply with all applicable requirements.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Section III of the Part 70 Permit contains the general requirements for testing, record keeping and reporting; and requirements that affect the facility as a whole, such as open burning, air pollution episodes, particulate matter from construction and demolition activities, asbestos provisions, ozone depleting substance provisions, general conformity, and acid rain permit. This section includes the requirement to report excess emissions and deviations, to submit an annual emissions certification report and an annual compliance certification report, and results of sampling and testing.

Section IV of the Part 70 Permit identifies the emissions standards, emissions limitations, operational limitations, and work practices applicable to each emissions unit located at the facility. For each standard, limitation, and work practice, the permit identifies the basis upon which the Permittee will demonstrate compliance. The basis will include testing, monitoring, record keeping, and reporting requirements. The demonstration may include one or more of these methods.

Section V of the Part 70 Permit contains a list of insignificant activities. These activities emit very small quantities of regulated air pollutants and do not require a permit to construct or registration with the Department. For insignificant activities that are subject to a requirement under the Clean Air Act, the requirement is listed under the activity.

Section VI of the Part 70 Permit contains State-only enforceable requirements. Section VI identifies requirements that are not based on the Clean Air Act, but solely on Maryland air pollution regulations. These requirements generally relate to the prevention of nuisances and implementation of Maryland's Air Toxics Program.

**REGULATORY REVIEW/TECHNICAL REVIEW/COMPLIANCE
METHODOLOGY**

Emission Units: Combustion Turbines

EU-1 thru EU-4 – Four (4) identical simple cycle mode combustion turbines fueled by natural gas and rated 190 MW at base load, zero degrees ambient temperature. Each turbine operates in simple cycle mode and combusts only pipeline quality natural gas. Each turbine is equipped with dry, low-NO_x burners. **(5-0076 thru 5-0079)**

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Rock Springs Generation facility was issued a Certificate of Public Convenience and Necessity (CPCN) Final Order Number 7652 (Case No. 8821) on November 30, 2000 and a Prevention of Significant Deterioration (PSD) approval and non-attainment Major New Source review approval under the CPCN pursuant to the Code of Maryland Regulations (COMAR 26.11.02.17). Construction of the combustion turbines began in October 2001. Only four units **[EU-1 thru EU-4]** have been built. The combustion turbines are also subject to 40 CFR Part 60, Subpart GG. The approved BACT and LAER determinations are based upon the combustion turbines burning only pipeline quality natural gas.

Compliance Status:

During the November 28, 2016 full compliance inspection, the turbines were offline. The facility was working on an issue with the pipeline.

Initial performance testing conducted by the Permittee in 2002 & 2003 as follows:

Unit #1 tested June 2 – June 4, 2003,

Unit #2 tested June 7 & 8, 2003,

Unit # 3 tested December 18 & 19, 2002, and

Unit #4 tested Jan 9, 2003

Results reported as follows:

PM emissions less than 18 lb/hr. [Ranged 2.7-5.5 lb/hr]

NO_x emissions less than 64.0 lb/hr. [Ranged 37.2 – 50.0 lbs/hr]. Also reported NO_x emissions less than 9.0 ppmvd. [Ranged 7.3 thru 7.7 ppmvd].

VOC emissions of less than 3.0 lb/hr [Ranged from 0 thru 2.7 lb/hr].

CO emissions less than 32 lb/hr. [Ranged 0.0 – 1.6 lb/hr]. Also CO concentrations are less than 9.0 ppmvd. [Ranged 0.0 – 0.4 ppmvd].

A CEMS Relative Accuracy Test Audit (RATA) was conducted in 2016 on July 11 (Unit 1) and July 12 (Units 3 and 4) and August 9 (Unit 2) for CO & NO_x ppm, NO_x Lb/mmbtu and %O₂ on all four units. The CEMS on all units passed the test and are in compliance.

The 2017 ECR stated the run hours for the units as follows: Unit 1 = 526 hrs; Unit 2 = 450 hrs; Unit 3 = 1208 hrs and Unit 4 = 1050.

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05A(1)–Fuel Burning Equipment.

“In Areas, I, II, V, and VI, a person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is greater than 20 percent opacity.”

Exceptions. “Section A(1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, start-up, or adjustments or occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

percent opacity; and (b) The visible emissions do not occur for more than sixty consecutive minute period.”

Compliance Demonstration:

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.

[Reference: COMAR 26.11.03.06C]

Rationale for Periodic Monitoring

The turbines burn only pipeline quality natural gas, a very clean burning fuel. The turbines are designed to operate with no visible emissions, and would have to have a serious malfunction in order for visible emissions to occur. If the Permittee performs preventative maintenance as recommended by the turbine manufacturer and supplemented with the facility’s maintenance experiences, the turbines will continue to operate with no visible emissions and minimize the possibility of malfunctions. The Permittee has the general requirement to report any excess emissions.

B. Control of Particulate Matter Emissions

Concentration of PM₁₀ shall not exceed 18 lb/hr when not injecting wastewater into the turbine exhaust stacks and 31.2 lb/hr for each turbine when wastewater is being injected into the turbine exhaust and shall not exceed 134.5 tpy for all six combustion turbines (*only 4 units installed*) combined on a 12-month rolling cumulative basis. **[Reference: CPCN #8821, Condition #14(a)(iii) & #17].**

Compliance Demonstration:

The Permittee is required to perform preventive maintenance to maintain the turbines in a condition such that they operate as designed. Records of the preventive maintenance that relates to combustion performance shall be maintained on site for 5 years and be submitted to the Department upon request.

The Permittee shall stack test one of the four identical units at least once during the life of the permit. The Permittee shall submit a test protocol to the Department for approval at least 30 days prior to the proposed test date. The Permittee shall maintain records of the stack test results and submit the results of any stack tests within 45 days after completion of the stack test.

[Reference: COMAR 26.11.03.06C]

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Rationale for Periodic Monitoring

The turbines burn only pipeline quality natural gas, a very clean burning fuel. The particulate matter PSD emission standard is based upon the design of the turbines. If the Permittee performs preventive maintenance as recommended by the turbine manufacturer and supplemented with the facility's maintenance experiences, the turbines will continue to achieve the limitation.

Particulate emissions are directly related to combustion performance. One measure of combustion performance is the content of carbon monoxide in the exhaust gases. The facility continuously monitors CO emissions. During the initial performance tests for PM, CO content was measured and it demonstrates that if the CO is within the applicable limits, the PM emissions are in compliance with the applicable emission limit.

The Permittee will also perform stack test at least once during the life of the permit on one of the units to confirmed continued compliance with the PM limit.

C. Control of Sulfur Oxide Emissions

40 CFR 60.333 – NSPS Subpart GG which limits sulfur content in any fuel burned a gas turbine to 0.8 wt %.

“SO₂ emissions shall not exceed 2.5 lb/hr for each combustion turbine, and 15 tpy for all six combustion turbines (*only 4 units installed*) combined in on a 12-month rolling cumulative basis.” **[Reference: CPCN #8821, Condition #17]**

Note: Compliance with these limitations will be the use of fuel supplier certifications.

Compliance Demonstration:

The Permittee shall monitor the sulfur content and nitrogen content of the fuel being burned in the turbine. The frequency of determination of these values shall be as follows:

- (1) If the turbine is supplied its fuel from a bulk storage tank, the value shall be determined on each occasion that fuel is transferred to the storage tank from any other source.
- (2) If the turbine is supplied without intermediate bulk storage the values shall be determined and recorded daily. The Permittee may develop custom schedules for determination of values based on design and operation of the affected facility and the characteristics of the fuel supply. These custom schedules shall be substantiated with data and must be approved by the Administrator before they can be used to comply with paragraph (b) of this section.

[Reference: 40 CFR 60.334(b)]

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

The Permittee shall maintain on site for at least five years documents certifying the sulfur content of gas received or copies of the sulfur in fuel analyses.

[Reference: COMAR 26.11.03.06C]

For the purpose of reports required under §60.7(c), periods of excess emissions are any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8 percent. The Permittee shall submit a summary report of excess emissions semiannually. All reports shall be postmarked by the 30th day following the end of each six-month period.

[Reference: 40CFR 60.334(c) and 60.7(c)]

Rationale for compliance demonstration:

The Permittee is required to comply with the monitoring, record keeping, and reporting requirements of NSPS Subpart GG. This limitation is based upon the Permittee burning pipeline natural gas. The Permittee will only burn pipeline quality natural gas so the Permittee will never violate this limitation

Phase II Acid Rain Permit:

A renewal Phase II Acid Rain Permit is being reissued in conjunction with the issuance of this Part 70 permit (Appendix A). The Phase II Acid Rain permit requires the Permittee to limit the actual emissions of sulfur dioxide to the number of allowances that the Permittee holds in its account with the Environmental Protection Agency's Clean Air Markets Program at the end of each calendar year. An allowance is one ton of sulfur dioxide emissions. The Permittee is required to purchase allowances to cover all the actual emissions in each calendar year. However, the Acid Rain Permit prohibits the Permittee from emitting sulfur dioxide emissions in excess of sulfur oxides emissions allowed by the CPCN.

Cross-State Air Pollution Rule

See Table IV-1a. – CSAPR for requirements

D. Control of Nitrogen Oxide Emissions

40 CFR 60.332 – NSPS Subpart GG which limits each turbine to 75 ppmvd NO_x emissions at 15% O₂.

BACT shall be the use of natural gas fuel only, operation of advanced dry low-NO_x burner technology, and application of good combustion practices so that: “Concentrations of NO_x shall not exceed 9 parts per million by volume on dry basis (ppmvd) at 15% oxygen on a 30-day rolling average

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

basis for each combustion turbine and the maximum one-hour average NO_x concentrations shall not exceed 10.5 ppmvd at 15% oxygen for each combustion turbine.” **[Reference: CPCN #8821, Condition 14(a)(i)]**

Note: Compliance shall be demonstrated by use of CEM.

“LAER for NO_x shall be the use of natural gas only, operation of advanced dry low-NO_x burner technology, and application of good combustion practices. Concentrations of NO_x shall not exceed 9 ppmvd at 15% oxygen on a 30-day rolling average basis (except during startup and shutdown) for each combustion turbine. Maximum 1-hour average (except during startup and shutdown) shall not exceed 10.5 ppmvd at 15% oxygen. NO_x emissions shall not exceed 64 lb/hr per turbine and 384 tons per year for all six turbines (*only 4 units installed*) combined on a 12-month rolling cumulative basis.” **[Reference: CPCN #8821, Condition #14a(i), 15, 17a & MDE April 29, 2003 Letter]**

Note: Compliance shall be demonstrated by use of CEM

Compliance Demonstration:

The Permittee shall perform QC/QA procedures as required by 40 CFR 75.10(a)(2). **[Reference: COMAR 26.11.03.06C]**

The Permittee shall operate, calibrate and maintain a CEMS to monitor the NO_x emissions from each turbine. **[Reference: CPCN #8821, Condition #9(o)]**. The Permittee shall certify CEM system in accordance with 40 CFR 75, Appendix A. **[Reference: 40 CFR §75.70]**. (*All quarterly reports show compliance*).

40 CFR 60.334(a) - NSPS Subpart GG which require any stationary turbine using water injection to control NO_x emissions to install and operate a Continuous Emissions Monitoring system to monitor and record the fuel being fired and the consumption and the ratio of water to fuel being fired in the turbine (and shall be accurate to within +/- 5.0% and shall be approved by the Administrator).

40 CFR 60.334(b) - NSPS Subpart GG which require the Permittee to monitor the nitrogen content of the fuel. (See Condition C above)

The Permittee shall maintain records necessary to prepare a quarterly emissions reports that contain the requirements of COMAR 26.11.01.10G(2)(d).

[Reference: COMAR 26.11.03.06C].

The Permittee shall submit a quarterly summary report to the Department not later than 30 days following each calendar quarter. The report shall be in a format approved by the Department, and shall include the following:

- (1) The cause, time periods, and magnitude of all emissions which exceed the applicable emission standards;
- (2) The source downtime including the time and date of the beginning and end of each downtime period and whether the source downtime was planned or unplanned;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

- (3) The time periods and cause of all CEM downtime including records of any repairs, adjustments, or maintenance that may affect the validity of emission data;
- (4) Quarterly totals of excess emissions, installation downtime, and CEM downtime during the calendar quarter;
- (5) Quarterly quality assurance activities; and
- (6) Daily calibration activities that include reference values, actual values, absolute or percent of span differences, and drift status; and
- (7) Other information required by the Department that is determined to be necessary to evaluate the data, to ensure that compliance is achieved, or to determine the applicability of this regulation." **[Reference: COMAR 26.11.09.08K(1) and COMAR 26.11.01.10G(2)(d)]**

Cross-State Air Pollution Rule

See Table IV-1a. – CSAPR for requirements

E. Control of VOC Emissions

VOC emissions shall not exceed 3 lb/hr for each combustion turbine, and 18 tpy for all six combustion turbines (*only 4 units installed*) combined in on a 12-month rolling cumulative basis. **[Reference: CPCN #8821, Condition #17]**

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the turbine in a condition such that it operates as designed. The Permittee shall maintain for at least five years records of the preventive maintenance that relates to combustion performance and submit records of maintenance to the Department upon request.

The Permittee shall stack test one of the four identical units at least once during the life of the permit. The Permittee shall submit a test protocol to the Department for approval at least 30 days prior to the proposed test date. The Permittee shall maintain records of the stack test results and submit the results of any stack tests within 45 days after completion of the stack test. **[Reference: COMAR 26.11.03.06C]**

Rationale for Periodic Monitoring

VOC emissions from the turbines are directly related to combustion performance. One measure of combustion performance is the content of carbon monoxide in the exhaust gases. The facility continuously monitors CO emissions. During the initial performance tests for VOC, CO content was measured and it demonstrates that if the CO is within the applicable limits, the VOC emissions are in compliance with the applicable emission limit.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

The VOC emission limit in the CPCN was based upon the Vendor's guarantee of performance. If the Permittee performs preventive maintenance as recommended by the turbine manufacturer and supplemented with the facility's maintenance experiences, the turbines will continue to achieve the limitation. The Permittee will also perform stack test at least once during the life of the permit on one of the units to confirmed continued compliance with the VOC limit.

F. Control of Carbon Monoxide Emissions

“BACT for CO shall be good combustion practices. Concentration of CO shall not exceed 9 ppmvd at 15% oxygen for each combustion turbine on a 30-day rolling average basis for each combustion turbine. Emissions of CO shall not exceed 32 lb/hr (except during startup and shutdown) from each combustion turbine and 192 tons per year for all six combustion turbines (*only 4 units installed*) combined on a 12-month rolling cumulative basis.”

[Reference: CPCN #8821, Condition #14(a)(ii), 17 & MDE April 29, 2003 Letter].

Compliance Demonstration:

The Permittee shall perform QC/QA procedures as required by 40 CFR 60, Appendix F and use a CEM to monitor CO emissions. The Permittee shall maintain records of the CO CEMs data and submit quarterly, the summaries of valid CEMs data for CO concentrations. The quarterly summary reports shall satisfy the reporting requirements of COMAR 26.11.01.10G(2)(d). **[Reference: COMAR 26.11.03.06C].** (*All quarterly reports show compliance*).

G. Operational Limitations

“The Operating hours for the six combustion turbines (*only 4 units installed*) combined shall not exceed 12,000 hours per year, on a 12-month rolling cumulative basis. The period of time during which the Permittee shall inject a wastewater stream into the turbine exhaust stack shall be limited to 4000 hours per year total.” **[Reference: CPCN #8821, Condition #16]**

Note: Based on the installation of four combustion turbines, the allowable aggregate hours of operation cannot exceed 8000 hrs, an average of 2000 hours per combustion turbine.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the turbine as designed. The Permittee shall record the hours of operation and submit to the Department hours of operation. [Reference: **COMAR 26.11.03.06C**].

Emission Units: Combustion Turbines (Cont'd)

EU-1 thru EU-4 – Four (4) identical simple cycle mode combustion turbines fueled by natural gas and rated 190 MW at base load, zero degrees ambient temperature. Each turbine operates in simple cycle mode and combusts only pipeline quality natural gas. Each turbine is equipped with dry, low-NO_x burners. (5-0076 thru 5-0079)

Applicable Standards and limits:

TR SO₂ Group 1 - Trading Program 40 CFR Part 97 Subpart CCCCC

The Permittee shall comply with the provisions and requirements of §97.601 through §97.635.

Note: §97.606(c) SO₂ emissions requirements. For TR SO₂ Group 1 emissions limitation: As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR SO₂ Group 1 source and each TR SO₂ Group 1 unit at the source shall hold, in the source's compliance account, TR SO₂ Group 1 allowances available for deduction for such control period under §97.624(a) in an amount not less than the tons of total SO₂ emissions for such control period from all TR SO₂ Group 1 units at the source.

Allowance transfer deadline means, for a control period in a given year, midnight of March 1 (if it is a business day), or midnight of the first business day thereafter (if March 1 is not a business day), immediately after such control period and is the deadline by which a TR SO₂ Group 1 allowance transfer must be submitted for recordation in a TR SO₂ Group 1 source's compliance account in order to be available for use in complying with the source's TR SO₂ Group 1 emissions limitation for such control period in accordance with §§97.606 and 97.624.

TR NO_x Annual Trading Program 40 CFR Part 97 Subpart AAAAA

The Permittee shall comply with the provisions and requirements of §97.401 through §97.435.

Note: §97.406(c) NO_x emissions requirements. For TR NO_x Annual emissions limitation: As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Annual source and each TR

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

NO_x Annual unit at the source shall hold, in the source's compliance account, TR NO_x Annual allowances available for deduction for such control period under §97.424(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Annual units at the source.

Allowance transfer deadline means, for a control period in a given year, midnight of March 1 (if it is a business day), or midnight of the first business day thereafter (if March 1 is not a business day), immediately after such control period and is the deadline by which a TR NO_x Annual allowance transfer must be submitted for recordation in a TR NO_x Annual source's compliance account in order to be available for use in complying with the source's TR NO_x Annual emissions limitation for such control period in accordance with §§97.406 and 97.424.

TR NO_x Ozone Season Trading Program 40 CFR Part 97 Subpart BBBBB

The Permittee shall comply with the provisions and requirements of §97.501 through §97.535.

Note: §97.506(c) NO_x emissions requirements. For TR NO_x Ozone Season emissions limitation: As of the allowance transfer deadline for a control period in a given year, the owners and operators of each TR NO_x Ozone Season source and each TR NO_x Ozone Season unit at the source shall hold, in the source's compliance account, TR NO_x Ozone Season allowances available for deduction for such control period under §97.524(a) in an amount not less than the tons of total NO_x emissions for such control period from all TR NO_x Ozone Season units at the source.

Allowance transfer deadline means, for a control period in a given year, midnight of December 1 (if it is a business day), or midnight of the first business day thereafter (if December 1 is not a business day), immediately after such control period and is the deadline by which a TR NO_x Ozone Season allowance transfer must be submitted for recordation in a TR NO_x Ozone Season source's compliance account in order to be available for use in complying with the source's TR NO_x Ozone Season emissions limitation for such control period in accordance with §§97.506 and 97.524.

Compliance Demonstration

The Permittee shall comply with the monitoring, recordkeeping and reporting requirements found in §97.606, §97.630, §97.631, §97.632, and §97.633.

The Permittee operates continuous emission monitoring system (CEMS) pursuant to 40 CFR Part 75, Subpart H (for NO_x monitoring).

The Permittee shall comply with the monitoring, recordkeeping and reporting requirements found in §97.406, §97.430, §97.431, §97.432, and §97.433 for the

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

NO_x Annual Trading Program and §97.506, §97.530, §97.531, §97.532, and §97.533 for the NO_x Ozone Season Trading Program.

Emission Units: Natural Gas heater

EU-7 – One (1) 9 million Btu/hr natural gas fuel-fired heater equipped with low NO_x burners. [6-0205]

The heater is not subject to the NESHAP requirements of 40 CFR 63, Subpart JJJJJ because it is natural gas-fired. Gas-fired boilers are exempt from the regulation.

Compliance Status

During the November 28, 2016 full compliance inspection, the heater was not operating. The 2017 ECR stated the run hours for the heater as 775 hrs.

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05A(1) – Visible Emissions.

“A person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is greater than 20 percent opacity.

Exceptions. “Section A (1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, start-up, or adjustments or occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40 percent opacity; and (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period.”

Compliance Demonstration:

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.

Rationale for Periodic Monitoring

The heater burns only natural gas, a very clean burning fuel. The heater is designed to operate with no visible emissions. The heater would have to have a serious malfunction in order for visible emissions to occur. If the Permittee performs preventative maintenance as recommended by the heater manufacturer and supplemented with the facility’s maintenance experiences, the heater will

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

continue to operate with no visible emissions and minimize the possibility of malfunctions.

B. Control of Particulate Matter Emissions

CPCN #8821 BACT - For the natural gas-fired heater, BACT shall be the use of natural gas fuel only, operation of low-NO_x burner technology, and application of good combustion controls. In addition, the heater shall be designed to achieve a PM emission rate not to exceed **0.01 lb/MMBtu**.

CPCN #8821, Condition #18 – The gas heater shall be designed to achieve PM emissions not to exceed the following:

PM ₁₀	0.09 lb/hr
------------------	------------

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the gas heater as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

Rationale for Periodic Monitoring

The limitation for the heater was placed in the CPCN because the projected emissions of PM from the proposed Rock Springs project exceed the PSD significant level of 15 tons/year. The PM limitation was based upon the vendor guarantees of the design of the heater. The projected PM emissions from the gas heater are 180 pounds per year.

C. Control of Sulfur Oxide Emissions

SO₂ Emissions from the gas heater shall not exceed **0.05 lb/hr**. **[Reference: CPCN #8821, Condition #18]**

Note: This standard was established based upon burning pipeline natural gas, a requirement of the PSD approval.

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the gas heater as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Rationale for Periodic Monitoring

The Permittee is required to burn pipeline natural gas. The standard is based upon the sulfur content of pipeline natural gas. The Permittee will always comply with the standard when burning pipeline natural gas. The projected sulfur dioxide emissions from the gas heater are 100 pounds per year.

D. Control of Nitrogen Oxide Emissions

LAER & BACT for the natural gas heater shall be the use of natural gas fuel only, operation of advanced dry low-NO_x burner technology, and application of good combustion control. In addition, the heater shall be designed to achieve a NO_x emissions rate not exceed **0.1 lb/MMBtu**. [Reference: **CPCN #8821, Condition #14b(i) #15b**]

CPCN #8821, Condition #18 –The gas heater shall be designed to achieve NO_x emissions not to exceed the following:

NO _x	0.9 lb/hr and 3.9 tpy on a 12-month rolling cumulative basis
-----------------	--

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the gas heater as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. [Reference: **COMAR 26.11.03.06C**]

Rationale for Periodic Monitoring

The limitation for the heater was placed in the CPCN because the projected emissions of NO_x from the proposed Rock Springs project exceed the PSD significant level of 40 tons/year and the non-attainment Major New Source Review threshold of 25 tons/year. The NO_x limitation was based upon the vendor guarantees of the design of the heater. The projected NO_x emissions from the gas heater are 1800 pounds per year.

E. Control of Carbon Monoxide Emissions

BACT for the natural gas heater shall be the use of natural gas fuel only, operation of advanced dry low-NO_x burner technology, and application of good combustion control. In addition, the heater shall be designed to achieve a CO

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

emission rate not exceed **0.08 lb/MMBtu**. [Reference: **CPCN #8821, Condition #14b(ii)**]

CPCN #8821, Condition #18 –The gas heater shall be designed to achieve CO emissions not to exceed the following:

CO	0.45 lb/hr
----	------------

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the gas heater as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. [Reference: **COMAR 26.11.03.06C**]

Rationale for Periodic Monitoring

The limitation for the heater was placed in the CPCN because the projected emissions of CO from the proposed Rock Springs project exceed the PSD significant level of 100 tons/year. The CO limitation was based upon the vendor guarantees of the design of the heater. The projected CO emissions from the gas heater are 900 pounds per year.

F. Control of VOC Emissions

CPCN #8821, Condition #18 –The gas heater shall be designed to achieve VOC emissions not to exceed the following:

VOCs	0.225 lb/hr
------	-------------

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the gas heater as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. [Reference: **COMAR 26.11.03.06C**]

Rationale for Periodic Monitoring

The VOC limitation was based upon the vendor guarantees of the design of the heater. The projected VOC emissions from the gas heater are 1800 pounds per year.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Emission Units: Emergency diesel engine

EU-8: One 200 horsepower (hp) emergency diesel firewater engine used to provide facility fire protection.

Compliance Status

During the November 28, 2016 full compliance inspection, the emergency engine run hours read 121.1 hr (meter at the time of inspection); maintenance performed on October 16, 2016 and last run on November 22, 2016 for test.

Applicable Standards and limits:

A. **Control of Visible Emissions**

COMAR 26.11.09.05E(2) - Emissions During Idle Mode: “The Permittee may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.”

COMAR 26.11.09.05E(3) - Emissions During Operating Mode: “The Permittee may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.”

Exceptions:

“(i) COMAR 26.11.09.05E(2) does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system.

(ii) COMAR 26.11.09.05E(2) does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods:

(a) Engines that are idled continuously when not in service: 30 minutes

(b) all other engines: 15 minutes.

(iii) COMAR 26.11.09.05E(2) & (3) do not apply while maintenance, repair or testing is being performed by qualified mechanics.”

Compliance Demonstration:

The Permittee shall: properly operate and maintain the engine; and maintain an operations manual and preventive maintenance plan. The Permittee shall maintain a log of maintenance performed on the engine pump that relates to combustion performance. **[Reference: COMAR 26.11.03.06C]**.

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

B. Control of Particulate Matter Emissions

CPCN #8821, Condition 14c, BACT - For the diesel firewater engine, BACT shall be application of good combustion controls and lean burn technology. In addition, the engine shall be designed to achieve a PM emission rate not to exceed **0.15 g/BHP**.

CPCN #8821, Condition #19 – The engine shall be designed to achieve PM emissions not to exceed the following:

PM ₁₀	0.07 lb/hr
------------------	------------

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the engine as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

Rationale for Periodic Monitoring

The limitation for the engine was placed in the CPCN because the projected emissions of PM from the proposed Rock Springs project exceed the PSD significant level of 15 tons/year. The PM limitation was based upon the vendor guarantees of the design of the engine. The projected PM emissions from the engine are 33 pounds per year.

C. Control of Sulfur Oxide Emissions

COMAR 26.11.09.07A(1)(c) – Sulfur Content Limitations for Fuel.

“A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: Distillate fuel oils, 0.3 percent.”

SO₂ Emissions from the gas heater shall not exceed **0.29 lb/hr**. **[Reference: CPCN #8821, Condition #19]**

Compliance Demonstration:

The Permittee shall obtain fuel suppliers' certification indicating that the gas complies with the limitation on the sulfur content of the gas or obtain sulfur in fuel analyses of gas that is representative of oil burned. The Permittee shall maintain on site for at least five years documents certifying the sulfur content of gas received or copies of the sulfur in fuel analyses. **[Reference: COMAR 26.11.03.06C]**. The Permittee shall report fuel supplier certifications or sulfur

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

in fuel analyses to the Department upon request [**Reference: COMAR 26.11.09.07C**].

D. Control of Nitrogen Oxide Emissions

LAER & BACT for the emergency diesel firewater engine shall be the application of good combustion controls, lean burn technology, and operation of the unit for a period not to exceed 100 hours per year on a 12-month rolling cumulative basis. In addition, the engine shall be designed to achieve NO_x emissions not to exceed 10.5 g/BHP. [**Reference: CPCN #8821, Condition #14c and 15c**]

CPCN #8821, Condition #19 –The engine shall be designed to achieve NO_x emissions not to exceed the following:

NO _x	0.46 lb/hr and 0.02 tpy on a 12-month rolling cumulative basis
-----------------	--

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the engine as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. [**Reference: COMAR 26.11.03.06C**]

Rationale for Periodic Monitoring

The limitation for the diesel firewater engine was placed in the CPCN because the projected emissions of NO_x from the proposed Rock Springs project exceed the PSD significant level of 40 tons/year and the non-attainment Major New Source Threshold of 25 tons/year. The NO_x limitation was based upon the vendor guarantees of the design of the engine. The projected NO_x emissions from the engine are 1.2 tons per year.

E. Control of Carbon Monoxide Emissions

BACT for the emergency diesel firewater engine shall be the application of good combustion controls and lean burn technology. In addition, the engine shall be designed to achieve a CO emission rate not exceed **2.7 g/BHP**. [**Reference: CPCN #8821, Condition #14c**]

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

CPCN #8821, Condition #19 –The engine shall be designed to achieve CO emissions not to exceed the following:

CO	1.19lb/hr
----	-----------

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the engine as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

Rationale for Periodic Monitoring

The limitation for the diesel firewater was placed in the CPCN because the projected emissions of CO from the proposed Rock Springs project exceed the PSD significant level of 100 tons/year. The CO limitation was based upon the vendor guarantees of the design of the engine. The projected CO emissions from the engine are 595 pounds per year.

F. Control of VOC Emissions

CPCN #8821, Condition #19 –The emergency diesel firewater engine shall be designed to achieve VOC emissions not to exceed the following:

VOCs	0.03 lb/hr
------	------------

Compliance Demonstration:

The Permittee shall perform preventative maintenance to maintain the engine as designed and maintain for at least five years records of the preventive maintenance that relates to combustion performance. The Permittee shall submit records of maintenance to the Department upon request. **[Reference: COMAR 26.11.03.06C]**

Rationale for Periodic Monitoring

The VOC limitation was based upon the vendor guarantees of the design of the diesel firewater engine. The projected VOC emissions from the engine are 15 pounds per year.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

G. Control of Hazardous Air Pollutants

40 CFR §63.6603(a) – “If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart.”

Table 2d, Item 4 – “a. Change oil and filter every 500 hours of operation or annually, whichever comes first; b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary.”

40 CFR §63.6605(a) – “You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times.”

40 CFR §63.6605(b) – “At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.”

40 CFR §63.6640(f) – “If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

- (1) There is no time limit on the use of emergency stationary RICE in emergency situations.
- (2) You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

- i. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
- (3) Not applicable for Area Sources
 - (4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
 - (i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.
 - (ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:
 - (A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.
 - (B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
 - (C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
 - (D) The power is provided only to the facility itself or to support the local transmission and distribution system.
 - (E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.”

Compliance Demonstration:

The Permittee is required to follow work practice and management standards to maintain the engine and minimize emissions either from the manufacturer’s written instructions or a maintenance plan developed by the Permittee. The engine must be operated in a manner consistent with the definition of an emergency engine in 40 CFR §63.6640(f). The engine must be fitted with a non-resettable hour meter if one is not already installed. **[Reference: 40 CFR §63.6625(f)]** Records of all maintenance, malfunctions, and operation of the engine must be kept on site and submit to the Department upon request. **[Reference: 40 CFR §63.6655 & COMAR 26.11.03.06C]**

Emission Units: Emergency diesel engine

EU-9: One (1) 100 kilowatt (kW) emergency diesel switchyard generator.

Compliance Status

During the November 28, 2016 full compliance inspection, the emergency engine maintenance was conducted on October 13, 2016 @ 29 hrs.

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05E(2) - Emissions During Idle Mode: “The Permittee may not cause or permit the discharge of emissions from any engine, operating at idle, greater than 10 percent opacity.”

COMAR 26.11.09.05E(3) - Emissions During Operating Mode: “The Permittee may not cause or permit the discharge of emissions from any engine, operating at other than idle conditions, greater than 40 percent opacity.”

Exceptions:

“(i) COMAR 26.11.09.05E(2) does not apply for a period of 2 consecutive minutes after a period of idling of 15 consecutive minutes for the purpose of clearing the exhaust system.

(ii) COMAR 26.11.09.05E(2) does not apply to emissions resulting directly from cold engine start-up and warm-up for the following maximum periods:

(a)Engines that are idled continuously when not in service: 30 minutes

(b)all other engines: 15 minutes.

(iii) COMAR 26.11.09.05E(2) & (3) do not apply while maintenance, repair or testing is being performed by qualified mechanics.”

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Compliance Demonstration:

The Permittee shall: properly operate and maintain the engine; and maintain an operations manual and preventive maintenance plan. The Permittee shall maintain a log of maintenance performed on the engine pump that relates to combustion performance. **[Reference: COMAR 26.11.03.06C]**.

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 "Report of Excess Emissions and Deviations".

B. Control of Sulfur Oxide Emissions

COMAR 26.11.09.07A(1)(c) – Sulfur Content Limitations for Fuel. "A person may not burn, sell, or make available for sale any fuel with a sulfur content by weight in excess of or which otherwise exceeds the following limitations: Distillate fuel oils, 0.3 percent."

Compliance Demonstration:

The Permittee shall obtain fuel suppliers' certification indicating that the gas complies with the limitation on the sulfur content of the gas or obtain sulfur in fuel analyses of gas that is representative of oil burned. The Permittee shall maintain on site for at least five years documents certifying the sulfur content of gas received or copies of the sulfur in fuel analyses. **[Reference: COMAR 26.11.03.06C]**. The Permittee shall report fuel supplier certifications or sulfur in fuel analyses to the Department upon request **[Reference: COMAR 26.11.09.07C]**.

C. Control of Hazardous Air Pollutants

40 CFR §63.6603(a) – "If you own or operate an existing stationary RICE located at an area source of HAP emissions, you must comply with the requirements in Table 2d to this subpart."

Table 2d, Item 4 – "a. Change oil and filter every 500 hours of operation or annually, whichever comes first; b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first, and replace as necessary; and c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary."

40 CFR §63.6605(a) – "You must be in compliance with the emission limitations and operating limitations in this subpart that apply to you at all times."

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

40 CFR §63.6605(b) – “At all times you must operate and maintain any affected source, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require you to make any further efforts to reduce emissions if levels required by this standard have been achieved. Determination of whether such operation and maintenance procedures are being used will be based on information available to the Administrator which may include, but is not limited to, monitoring results, review of operation and maintenance procedures, review of operation and maintenance records, and inspection of the source.”

40 CFR §63.6640(f) – “If you own or operate an emergency stationary RICE, you must operate the emergency stationary RICE according to the requirements in paragraphs (f)(1) through (4) of this section. In order for the engine to be considered an emergency stationary RICE under this subpart, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in paragraphs (f)(1) through (4) of this section, is prohibited. If you do not operate the engine according to the requirements in paragraphs (f)(1) through (4) of this section, the engine will not be considered an emergency engine under this subpart and must meet all requirements for non-emergency engines.

- (1) There is no time limit on the use of emergency stationary RICE in emergency situations.
- (2) You may operate your emergency stationary RICE for any combination of the purposes specified in paragraphs (f)(2)(i) through (iii) of this section for a maximum of 100 hours per calendar year. Any operation for non-emergency situations as allowed by paragraphs (f)(3) and (4) of this section counts as part of the 100 hours per calendar year allowed by this paragraph (f)(2).
 - ii. Emergency stationary RICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The owner or operator may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the owner or operator maintains records indicating that federal, state, or local standards require maintenance and testing of emergency RICE beyond 100 hours per calendar year.
- (3) Not applicable for Area Sources
- (4) Emergency stationary RICE located at area sources of HAP may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

calendar year for maintenance and testing and emergency demand response provided in paragraph (f)(2) of this section. Except as provided in paragraphs (f)(4)(i) and (ii) of this section, the 50 hours per year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.

(i) Prior to May 3, 2014, the 50 hours per year for non-emergency situations can be used for peak shaving or non-emergency demand response to generate income for a facility, or to otherwise supply power as part of a financial arrangement with another entity if the engine is operated as part of a peak shaving (load management program) with the local distribution system operator and the power is provided only to the facility itself or to support the local distribution system.

(ii) The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:

(A) The engine is dispatched by the local balancing authority or local transmission and distribution system operator.

(B) The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.

(C) The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.

(D) The power is provided only to the facility itself or to support the local transmission and distribution system.

(E) The owner or operator identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the engine owner or operator.”

Compliance Demonstration:

The Permittee is required to follow work practice and management standards to maintain the engine and minimize emissions either from the manufacturer’s written instructions or a maintenance plan developed by the Permittee. The engine must be operated in a manner consistent with the definition of an emergency engine in 40 CFR §63.6640(f). The engine must be fitted with a non-resettable hour meter if one is not already installed. **[Reference: 40 CFR §63.6625(f)]** Records of all maintenance, malfunctions, and operation of the engine must be kept on site and submit to the Department upon request. **[Reference: 40 CFR §63.6655 & COMAR 26.11.03.06C]**

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

Emission Units: Natural Gas heater

EU-10 – One (1) 7.5 million Btu/hr natural gas fuel-fired heater equipped with low NO_x burners. [015-0202-5-0148]

A request for coverage for an Air Quality General Permit to Construct for Small Fuel Burning (Boiler/Heater) Equipment was issued November 16, 2017. This heater will be used as a backup to the existing heater.

A letter was sent to the PSC dated October 26, 2017 informing of the installation of the backup heater. An operational gas heater is an integral part of the operation because the four (4) GE 7FA combustion turbines cannot operate without a gas heater to condition the incoming natural gas. The backup gas heater is being installed to minimize the risk of facility downtime. The existing heater and the backup heater will not run concurrently during electrical generation, so there will be no emission increase.

The heater is not subject to the NESHAP requirements of 40 CFR 63, Subpart JJJJJJ because it is natural gas-fired. Gas-fired boilers are exempt from the regulation.

Applicable Standards and limits:

A. Control of Visible Emissions

COMAR 26.11.09.05A(1) – Visible Emissions.

“A person may not cause or permit the discharge of emissions from any fuel burning equipment, other than water in an uncombined form, which is greater than 20 percent opacity.

Exceptions. “Section A (1) and (2) of this regulation do not apply to emissions during load changing, soot blowing, start-up, or adjustments or occasional cleaning of control equipment if: (a) The visible emissions are not greater than 40 percent opacity; and (b) The visible emissions do not occur for more than 6 consecutive minutes in any sixty minute period.”

Compliance Demonstration:

The Permittee shall report incidents of visible emissions in accordance with Section III Condition 4 “Report of Excess Emissions and Deviations”.

Rationale for Periodic Monitoring

The heater burns only natural gas, a very clean burning fuel. The heater is designed to operate with no visible emissions. The heater would have to have a

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

serious malfunction in order for visible emissions to occur. If the Permittee performs preventative maintenance as recommended by the heater manufacturer and supplemented with the facility's maintenance experiences, the heater will continue to operate with no visible emissions and minimize the possibility of malfunctions.

B. Control of Nitrogen Oxide Emissions

COMAR 26.11.09.08B(5) - Operator Training.

(a) "For purposes of this regulation, the equipment operator to be trained may be the person who maintains the equipment and makes the necessary adjustments for efficient operation.

(b) The operator training course sponsored by the Department shall include an in-house training course that is approved by the Department."

COMAR 26.11.09.08E. - Requirements for Fuel-Burning Equipment with a Rated Heat Input Capacity of 100 Million Btu Per Hour or Less. "A person who owns or operates fuel-burning equipment with a rated heat input capacity of 100 Million Btu per hour or less shall:

- (1) Submit to the Department an identification of each affected installation, the rated heat input capacity of each installation, and the type of fuel burned in each;
- (2) Perform a combustion analysis for each installation at least once each year and optimize combustion based on the analysis;
- (3) Maintain the results of the combustion analysis at the site for at least 2 years and make this data available to the Department and the EPA upon request;
- (4) Once every 3 years, require each operator of the installation to attend operator training programs on combustion optimization that are sponsored by the Department, the EPA, or equipment vendors; and
- (5) Prepare and maintain a record of training program attendance for each operator at the site, and make these records available to the Department upon request."

Compliance Demonstration:

The Permittee shall perform combustion analysis on the heaters and boilers at least once per year and optimize combustion based on the analysis.

[Reference: COMAR 26.11.09.08E(2)]

The Permittee shall maintain the following records on-site for a period of at least five years:

- (1) Training program attendance for each operator at the site and make these records available to the Department upon request.
- (2) Results of combustion analysis.

[Reference: COMAR 26.11.09.09E(3)&(5)]

The Permittee shall submit:

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

- (1) The results of combustion analysis to the department and the EPA upon request. **[Reference: COMAR 26.11.09.08E(3)]**
 - (2) A record of training program attendance for each operator to the Department upon request. **[Reference: COMAR 26.11.09.08E(5)].**
-

COMPLIANCE SCHEDULE

Rock Springs Generation Facility is currently in compliance with all applicable air quality regulations.

TITLE IV – ACID RAIN

Rock Springs Generation Facility is subject to the Acid Rain Program requirements. The Phase II Acid Rain Permit renewal will be issued in conjunction with this Part 70 permit.

TITLE VI – OZONE DEPLETING SUBSTANCES

Rock Springs Generation Facility is not subject to Title VI requirements.

SECTION 112(r) – ACCIDENTAL RELEASE

Rock Springs Generation Facility is not subject to the requirements of Section 112(r).

PERMIT SHIELD

The Rock Springs Generation Facility requested that a permit shield be expressly included in the Permittee's Part 70 permit. Permit shields are granted on an emission unit by emission unit basis. If an emission unit is covered by a permit shield, a permit shield statement will follow the emission unit table in Section IV - Plant Specific Conditions of the permit. In this case, a permit shield was granted for each emission unit covered by the permit.

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

INSIGNIFICANT ACTIVITIES

This section provides a list of insignificant emissions units that were reported in the Title V permit application. The applicable Clean Air Act requirements, if any, are listed below the insignificant activity.

- (1) ✓ Space heaters utilizing direct heat transfer and used solely for comfort heat;

- (2) Containers, reservoirs, or tanks used exclusively for:
 - (a) ✓ Storage of butane, propane, or liquefied petroleum, or natural gas;

 - (b) No. ✓ Storage of lubricating oils;

 - (c) No. 2 Storage of Numbers 1, 2, 4, 5, and 6 fuel oil and aviation jet engine fuel;

- (3) ✓ Potable water treatment equipment, not including air stripping equipment;

- (4) ✓ Comfort air conditioning subject to requirements of Title VI of the Clean Air Act;

**ROCK SPRINGS GENERATION FACILITY
1423 ROCK SPRINGS ROAD
RISING SUN, MD 21911
PERMIT NO. 24-015-0202
PART 70 OPERATING PERMIT FACT SHEET**

STATE ONLY ENFORCEABLE REQUIREMENTS

This section of the permit contains state-only enforceable requirements. The requirements in this section will not be enforced by the U.S. Environmental Protection Agency. The requirements in this section are not subject to COMAR 26.11.03 10 - Public Petitions for Review to EPA Regarding Part 70 Permits.

Applicable Regulations:

- (A) COMAR 26.11.06.08, Nuisance.
“An installation or premises may not be operated or maintained in such a manner that a nuisance or air pollution is created. Nothing in this regulation relating to the control of emissions may in any manner be construed as authorizing or permitting the creation of, or maintenance of, nuisance or air pollution.”

- (B) COMAR 26.11.06.09, Odors.
“A person may not cause or permit the discharge into the atmosphere of gases, vapors, or odors beyond the property line in such a manner that a nuisance or air pollution is created.”