

Bay Restoration Fund Singalair Monitoring And Analysis

Singalair

ProjAddress	Sample Date	Effluent TN	Percent Reduction *
Project Site 1	29-Jan-08	60.6	-1.0%
Project Site 1	02-Jul-08	14.7	75.5%
Project Site 1	02-Oct-08	40.9	31.8%
Project Site 1	31-Jul-09	24.6	59.0%
Project Site 1	18-Dec-09	18.9	68.5%
Project Site 2	02-Jul-08	9	85.0%
Project Site 2	02-Oct-08	31.1	48.2%
Project Site 2	27-Jan-09	30.1	49.8%
Project Site 2	29-Jul-09	16.9	71.8%
Project Site 2	08-Dec-09	35	41.7%
Project Site 3	02-Jul-08	5.1	91.5%
Project Site 3	02-Oct-08	30.7	48.8%
Project Site 3	29-Jan-09	9.9	83.5%
Project Site 3	31-Jul-09	31.8	47.0%
Project Site 3	18-Dec-09	6.6	89.0%
Project Site 4	03-Jul-07	12.4	79.3%
Project Site 4	02-Oct-08	33	45.0%
Project Site 4	30-Jan-09	9.9	83.5%
Project Site 4	31-Jul-09	11.2	81.3%
Project Site 4	18-Dec-09	9.2	84.7%
Project Site 5	01-Jul-08	65	-8.3%
Project Site 5	02-Oct-08	12.4	79.3%
Project Site 5	28-Jan-09	28.2	53.0%
Project Site 5	29-Jul-09	32.7	45.5%
Project Site 5	17-Dec-09	35.5	40.8%
Project Site 6	17-Dec-10	16.9	71.8%
Project Site 7	30-Jun-08	17.8	70.3%
Project Site 7	01-Oct-08	15.8	73.7%
Project Site 7	26-Jan-09	23.6	60.7%
Project Site 7	29-Jul-09	20	66.7%
Project Site 7	04-Dec-09	37.7	37.2%
Project Site 8	28-Jul-09	29.6	50.7%
Project Site 8	03-Dec-09	20.8	65.3%
Project Site 9	02-Oct-08	42.8	28.7%
Project Site 9	28-Jan-09	28.2	53.0%
Project Site 9	29-Jul-09	19.4	67.7%
Project Site 9	08-Dec-09	8.8	85.3%
Project Site 10	30-Jun-08	32.5	45.8%
Project Site 10	30-Sep-08	18.5	69.2%
Project Site 10	27-Jan-09	37	38.3%
Project Site 10	27-Jul-09	16.8	72.0%
Project Site 10	03-Dec-09	27.5	54.2%
Project Site 11	30-Jun-08	64	-6.7%
Project Site 11	30-Sep-08	68	-13.3%
Project Site 11	27-Jan-09	29	51.7%
Project Site 11	28-Jul-09	17.6	70.7%
Project Site 11	03-Dec-09	12.2	79.7%
Project Site 12	04-Dec-09	38.2	36.3%
Project Site 13	30-Jun-08	9	85.0%
Project Site 13	30-Sep-08	39.4	34.3%
Project Site 13	27-Jan-09	36.4	39.3%
Project Site 13	28-Jul-09	36.4	39.3%
Project Site 13	03-Dec-09	42	30.0%
Project Site 14	05-Dec-09	23	61.7%

* Influent TN concentration assumed at 60 mg/l

Mean Percent Reduction = 55%
 Mean TN effluent (mg/l) = 27