

Annual Drinking Water Quality Report for 2021

Summerhill Park

PWSID # 0020221

April, 2022

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the water quality and services we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is two (2) wells which draws from an underground aquifer known as The Magothy. The approximate depth of our wells are approximately 180 feet and they are located within the properties of the trailer park.

I'm pleased to report that our drinking water is safe and meets federal and state requirements.

A source water assessment plan that provides more information such as potential sources of contamination has been prepared. This plan is available at the Anne Arundel County Public Library or from Maryland Department of the Environment (MDE). For more information call 1-800-633-6101

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or concerning your water, please contact Gary Chenowith at (410) 849-3901. We want our residents to be informed about their water.

Summerhill Park routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Picocuries per liter (pCi/L) - picocuries per liter is a measure of the radioactivity in water.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measureme	MCLG	MCL	Likely Source of Contamination
Disinfection and Disinfection By-Products						
Chlorine (2021)	N	0.5	ppm	4	4	Water additive to control microbes
Inorganic Contaminants						
Copper (Distribution) (2017)	N	0.119	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (Distribution) (2017)	N	1.1	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Nitrate (Measured as Nitrogen) 12/31/2020	N	4.6	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Radioactive Contaminants						
Combined Radium 226/228 (2021)	N	1.43	pCi/l	0	5	Erosion of natural deposits
Stage 2 Disinfection Byproducts:						
TTHM (Distribution) (2017) (Total trihalomethanes)	N	7.8	ppb	0	80	By-product of drinking water chlorination
HAA5 (Distribution) (2017)	N	1.1	ppb	0	60	By-product of drinking water chlorination

Note: Test results are for year 2021 or as otherwise indicated; all contaminants are not required to be tested for annually.

We have learned through monitoring and testing that some contaminants have been detected. The EPA has determined that your water IS SAFE at these levels.

Violation

Lead and Copper Rule- FOLLOW UP OR ROUTINE TAP M/R (LCR)- Begin 10/01/2020 : We failed to test our drinking water for the contaminant and the period indicated. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated

Violation

Revised Total Coliform Rule (RTCR)- MONITORING, ROUTINE, MAJOR (RTCR) Begin 05/1/2021 End 5/31/21. We failed to test our drinking water for the contaminant and period indicated, Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

“If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Summerhill Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.”

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These

substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

We have a water softening system operated by Culligan to improve the overall quality of the water which is furnished to your residence. We also have licensed operators who are certified by MDE to operate our water and waste water systems on a daily basis.

Please call our office if you have questions about this report. 410-849-3901