

***Annual Drinking Water Quality Report for CY2021***  
***Thunderbird Motel***  
***PWSID 0080069***  
***April, 2022***

We're pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the excellent water and services we have delivered to you over the past year. Our goal is to provide to you a safe and dependable supply of drinking water. Our water source is one well which draws from a confined underground aquifer (name unknown) which is located within the motel properties.

This report shows our water quality and what it means.

A source water assessment plan has been prepared that provides more information such as potential sources of contamination. This plan is available thru the Charles County Public Library or Maryland Department of the Environment (MDE). For more information call 1-800-633-6101.

***Results of the assessment can be found on the MDE website:***

[https://mde.maryland.gov/programs/Water/water\\_supply/Source\\_Water\\_Assessment\\_Program/Pages/by\\_county.aspx](https://mde.maryland.gov/programs/Water/water_supply/Source_Water_Assessment_Program/Pages/by_county.aspx)

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or concerning your water, please contact Kirit Patel at (301) 934-4614. He may be reached daily Monday thru Friday during normal business hours. We want our residents to be informed about their water.

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Thunderbird Motel routinely monitors for contaminants in your drinking water according to Federal and State laws. The following table shows the results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2021. In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or a single penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter* - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

*Action Level* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Maximum Contaminant Level* - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Contaminant Level Goal* - The “Goal”(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Picocuries per liter (pCi/L)* - picocuries per liter is a measure of the radioactivity in water.

<b>TEST RESULTS</b>						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
<b>Stage 2 Disinfection Byproducts</b>						
HAA5 (Distribution) (2019) (range and Average) (Haloacetic Acids)	N	0 – 1.2 1.2	ppb	0	60	By-product of drinking water chlorination
<b>Inorganic Contaminants</b>						
Copper (distribution) (2020)	N	0.06	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Chlorine (2021)	N	1	ppm	4	4	Water Additive used to control microbes
Fluoride (2020)	N	0.48	ppm	4	4	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Barium (2020)	N	0.055	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits

*Note: Test results are for year 2021 or as otherwise indicated; All contaminants are not required to be tested for annually.*

### **Violation**

#### **Consumer Confidence Rule – CCR ADEQUACY/AVAILABILITY CONTENT Begin 10/01/2021 End 2021**

We failed to provide you, our drinking water customers, an annual report that adequately informed you about the quality of our drinking water and the risk of exposure from contaminants in our drinking water .

### **Violation**

**Revised Total Coliform Rule (RTCR)- MONITORING, ROUTINE, MAJOR (RTCR) Begin 04/1/2021 End 4/30/21.** We failed to test our drinking water for the contaminant and period indicated, Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

**Revised Total Coliform Rule (RTCR)- MONITORING, ROUTINE, MAJOR (RTCR) Begin 10/1/2021 End 10/31/21.** We failed to test our drinking water for the contaminant and period indicated, Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

**Revised Total Coliform Rule (RTCR)- MONITORING, ROUTINE, MAJOR (RTCR) Begin 11/1/2021 End 11/30/21.** We failed to test our drinking water for the contaminant and period indicated, Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

**Revised Total Coliform Rule (RTCR)- MONITORING, ROUTINE, MAJOR (RTCR) Begin 12/1/2021 End 12/31/21.** We failed to test our drinking water for the contaminant and period indicated, Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

### **Violation**

**Nitrate (measured as nitrogen) Monitoring, Routine, Major Begin-01/01/2021 End 12/31/2021.** We failed to test our drinking water for the contaminant and period indicated, Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Thunderbird Motel is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

The Maryland Rural Water Association assisted with this report. Please call Mr. Patel if you have questions about this report.