

Annual Drinking Water Quality Report for 2021
Crow's Nest Lodge/Campground
PWSID # 1101230
May, 2022

We're pleased to present to you this year's Annual Water Quality Report. This report is designed to inform you about the water quality and services we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source is one (1) well which is located within the properties of the campground.

A source water assessment plan has been completed that provides more information such as potential sources of contamination. This plan is available from the Frederick County Public Library or from Maryland Department of the Environment (MDE). ***Results of the assessment can be found on the MDE website:***
https://mde.maryland.gov/programs/Water/water_supply/Source_Water_Assessment_Program/Pages/by_county.asp
[X](#)

I'm pleased to report that our drinking water is safe and meets federal and state requirements.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

If you have any questions about this report or concerning your water, please contact: William Beavan at 301-401-0026.

Crow's Nest Lodge/Campground routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2021. As water travels over the land or underground, it can pick up substances or contaminants such as microbes, inorganic and organic chemicals, and radioactive substances. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. It's important to remember that the presence of these contaminants does not necessarily pose a health risk.

In this table you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

TEST RESULTS						
Contaminant	Violation Y/N	Level Detected	Unit Measurement	MCLG	MCL	Likely Source of Contamination
Inorganic Contaminants						
Haloacetic Acids (HAA5) (2021)	N	2.97	ppb	No goal for the total	60	By-product of water disinfection
Barium (2020)	N	0.021	ppm	2	2	Discharge of drilling waste; Discharge from metal refineries; Erosion of natural deposits
Copper (Distribution) (2020)	N	0.05	ppm	1.3	AL=1.3	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead (Distribution) (2020)	N	27.4	ppb	0	AL=15	Corrosion of household plumbing systems; Erosion of natural deposits.
Chlorine (2021) Range Highest level detected	N	0.6	ppm	4	4	Water Additive used to control microbes
Nitrate (as Nitrogen) (2020)	N	0.4	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

Note: Test results are for year 2021 or as otherwise noted; all contaminants are not required to be tested for annually.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Crow's Nest Lodge is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the EPA Safe Drinking Water Hotline at 1-800-426-4791 or at <http://www.epa.gov/safewater/lead>.

An action level exceedance is not a violation but can trigger other requirements that include water quality parameter monitoring, corrosion control treatment, source water monitoring/treatment, public education and lead service line replacement

PFAS – short for per- and polyfluoroalkyl substances- refers to a large group of more than 4000 human made chemicals that have been used since the 1940's in a range of products, including stain- and water-resistant fabrics and carpeting, cleaning products, paints, cookware, food packaging, and fire fighting foams. These uses of PFAS have led to PFAS entering our environment, where they have been measured by several states in the soil, surface water, groundwater and seafood. Some PFAS can last a long time in the environment and in the human body and can accumulate in the food chain.

Currently, there are no federal regulations (i.e. Maximum Contaminant Levels (MCLs) for PFAS in drinking water. However, the US Environmental Protection Agency (EPA) has issued a health advisory level (HAL) of 70 parts per trillion (PPT) for the sum of PFOA and PFOS concentrations in drinking water. While not enforceable regulatory standard, when followed, the EPA HAL does provide drinking water customers, even the most sensitive populations, with a margin of protection from lifetime exposure to PFOA and PFOS in drinking water. Beginning in 2020, the Maryland Department of the Environment (MDE) initiated a PFAS monitoring program. In 2021, results from samples taken at the Crows Nest Lodge's drinking water treatment system showed a ND (non/detect) for PFOA and PFOS concentration. No additional actions are planned at this time. MDE anticipates that EPA will establish an MCL for PFOA and PFOS in the near future. This would entail additional monitoring. Additional information about PFAS can be found on the MDE website: mde.maryland.gov

All sources of drinking water are subject to potential contamination by substances that are naturally occurring or man made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Radon is a radioactive gas that you cannot see, taste, or smell. It is found throughout the U.S. Radon can move up through the ground and into a home through crack and holes in the foundation. Radon can build up to high levels in all types of homes. Radon can also get into indoor air when released from tap water from showering, washing dishes, and other household activities. Compared to radon entering the home through soil, radon entering the home through tap water will in most cases be a small source of radon in indoor air. Radon is a known human carcinogen. Breathing air containing radon can lead to lung cancer. Drinking water containing radon may also cause increased risk of stomach cancer. If you are concerned about radon in your home, test the air in your home. Testing is inexpensive and easy. (You should pursue radon removal for your home if the level of radon in your air is 4 picocuries per liter of air (pCi/L) or higher. There are simple ways to fix a radon problem that are not too costly. For additional information, call your state radon program or call EPA's Radon Hotline (800-SOS-RADON).

MCL's are set at very stringent levels. To understand the possible health effects described for many regulated contaminants, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Violation: Consumer Confidence Rule; CCR Adequacy/Availability/Content- 10/01/2021- Date: We failed to provide to you, our drinking water customers, an annual report that adequately informed you about the quality of our drinking water and the risk from exposure from contaminants detected in our drinking water.

Violation: CCR REPORT- 07/01/2021-Date: We failed to provide to you, our drinking water customers, an annual report that adequately informed you about the quality of our drinking water and the risk from exposure from contaminants detected in our drinking water.

Please call our office if you have questions.